




Énergie NB Power


Point Lepreau Generating Station

POINT LEPREAU GENERATING STATION

Environmental Radiation
Monitoring Data

January 1, 2003 to December 31, 2003






Quality today ... for an assured future



POINT LEPREAU GENERATING STATION

**Environmental Radiation
Monitoring Data**

January 1, 2003 to December 31, 2003



PREPARED BY: J.C. McCulley

Joe McCulley

DATE: 2004-04-30

REVIEWED BY: R.P. Mapplebeck

Ralph Mapplebeck

DATE: 2004-04-30

APPROVED BY: J.C. Nason

J. Nason

DATE: 2004-04-30

NB Power Corporate Drawing Browser
Document Number 0087-07000-HP03-EMR-A-00

Health Physics Department
Report HP-07000-2004-1
April, 2004

Executive Summary

This annual report is a compilation of the 2003 results from the Environmental Radiation Monitoring Program for the Point Lepreau Generating Station (PLGS).

Since 1976, the monitoring program has analysed more than 29 000 samples to define background radiation from natural and human sources. The contribution from human sources has declined significantly since atmospheric bomb tests have ceased. The program detected radionuclide fallout in New Brunswick after a Chinese atmospheric bomb test in 1980, and fallout from the accident at Chernobyl in 1986. There have been no regionally detectable releases of radiation from any human activity since these two events.

In 2003, there were 1779 analyses on 1275 samples to monitor environmental radiation around Point Lepreau and across the province in general. There were 531 analyses performed on 320 other samples, including 389 analyses of 255 Quality Assurance (QA) samples.

The analyses indicate that radiation dose from PLGS emissions continues to be well below the public dose limit (1000 microsieverts per annum), and also well below the design and operating target for PLGS (50 microsieverts per annum). These emissions are the lowest since 1984.

<i>Source of Dose to Critical Group</i>	<i>Individual Dose ($\mu\text{Sv}\cdot\text{a}^{-1}$)</i>
PLGS airborne emissions	0.27
PLGS liquid emissions	0.06
natural background (estimate)	2000

The following trends were observed in the historical data:

- increasing concentration of tritium in Parshall Flume water from the Solid Radioactive Waste Management Facility (SRWMF) Phase 1. However, it continues to be below the peak concentrations observed in 1999 and 2000.
- decreasing dose to members of the Critical Groups due to decreasing emissions since 1995.
- decreasing concentration of tritium in water vapour (onsite locations) since 1994.
- decreasing concentration of tritium in monitoring wells (near plant) since 2001.
- continuing detection of tritium in air and water samples (higher onsite than offsite).
- continuing difference between onsite and offsite thermoluminescent dosimeter (TLD) measurements.

Several reports were issued during the year, including a study of groundwater movement⁽¹⁾, an ecological effects review⁽²⁾, and an environmental assessment of the proposed SRWMF modifications⁽³⁾ (supporting PLGS refurbishment).

The stated objectives of the program were met in 2003.

This page is intentionally blank.

Table of Contents

1	Introduction.....	1
2	Point Lepreau Emission Data	3
3	Sample Media, Locations and Frequencies	6
4	Summary and Discussion of Data.....	17
4.01	Airborne Particulates	18
4.02	Airborne Iodines	21
4.03	Water Vapour.....	21
4.04	Carbon Dioxide.....	26
4.05	Ambient Gamma (TLD)	30
4.06	Milk.....	33
4.07	Airborne Strontiums (GEM).....	34
4.08	Well Water.....	36
4.09	Pond/Puddle/Surface Water.....	39
4.10	Berries.....	41
4.11	Garden Vegetables.....	41
4.12	Vegetation (Lichen).....	41
4.13	Soil.....	46
4.14	Rain Water	48
4.15	Monitoring Well Water (Near Plant)	50
4.16	Seawater.....	52
4.17	Tritium and Carbon-14 Analyses of Seafood	52
4.18	Clams	55
4.19	Fish.....	55
4.20	Lobster	55
4.21	Periwinkles.....	59
4.22	Aquaculture Salmon	59
4.23	Scallops.....	59
4.24	Crab.....	59
4.25	Dulse	59
4.26	Other Sea Plants.....	60
4.27	Sediment	67
4.28	Gamma Surveys (Beaches).....	69
4.29	Liquid Strontiums (LEM)	70
4.30	Bore Hole Water (SRWMF)	70
4.31	Parshall Flume Water (SRWMF)	74
4.32	Drop-off TLDs (SRWMF - Phase 2)	77
4.33	Hemlock Knoll Regional Sanitary Landfill.....	78
4.34	Meteorological Data	80
5	Trends	83
5.01	Dose from Airborne and Liquid Pathways	83
5.02	Gross Beta in Air	84
5.03	Tritiated Water in Air	86

5.04	Atmospheric Dispersion Factors.....	89
5.05	Carbon-14 in Air.....	91
5.06	TLD Measurements.....	92
5.07	Strontium-90 in Air (GEM).....	93
5.08	Gross Beta in Well Water.....	94
5.09	Tritium in Well Water.....	95
5.10	Cs-137 in Soil.....	96
5.11	Tritium in Monitoring Well Water (Near Plant).....	97
5.12	Tritium and C-14 in Seawater.....	98
5.13	Cs-137 in Sediment.....	100
5.14	Strontium-90 in LEM.....	101
5.15	Tritium in Bore Hole Water.....	102
5.16	Tritium in Parshall Flume Water.....	104
5.17	Drop-off TLDs.....	105
6	Dose Estimation.....	107
7	Quality Assurance Results.....	108
7.01	Quality Control Checks.....	108
7.01.01	<i>Intrinsic Ge Gamma Spectrometer.....</i>	<i>109</i>
7.01.02	<i>Beckman Liquid Scintillation Counter (model LS 6000TA).....</i>	<i>110</i>
7.01.03	<i>Tennelec LB-5100 Gross Alpha/Beta Detector.....</i>	<i>110</i>
7.01.04	<i>Panasonic UD-710A TLD Reader.....</i>	<i>110</i>
7.01.05	<i>Other Instruments.....</i>	<i>110</i>
7.02	External QA.....	110
7.03	Internal QA.....	135
7.04	Program Audit.....	147
7.05	Annual Review.....	147
7.05.01	<i>Routine Monitoring Results.....</i>	<i>147</i>
7.05.02	<i>Procedures.....</i>	<i>148</i>
7.05.03	<i>Analytical QA Results.....</i>	<i>148</i>
7.05.04	<i>Equipment.....</i>	<i>148</i>
7.05.05	<i>Personnel.....</i>	<i>149</i>
7.05.06	<i>Safety.....</i>	<i>149</i>
7.05.07	<i>Emissions.....</i>	<i>149</i>
7.05.08	<i>Meteorological Data.....</i>	<i>150</i>
7.05.09	<i>Emergency Measures Organisation Demographic Data.....</i>	<i>150</i>
7.05.10	<i>Appropriateness of Media, Locations and Frequency.....</i>	<i>150</i>
7.05.11	<i>High LLDs.....</i>	<i>151</i>
7.05.12	<i>Records.....</i>	<i>151</i>
7.05.13	<i>Contamination.....</i>	<i>151</i>
7.05.14	<i>Problem Resolution.....</i>	<i>152</i>
7.05.15	<i>Changes to Reference Document.....</i>	<i>152</i>
7.05.16	<i>Program Audit.....</i>	<i>153</i>
7.05.17	<i>Program Improvement.....</i>	<i>153</i>
8	Reports and Studies.....	155

List of Appendices

Appendix A: Statistics, Detection Limits, and Dose at Detection Limits	157
Appendix B: Sample Collection and Analytical Techniques	170
Appendix C: Location Codes.....	178
Appendix D: Abbreviations	184
Appendix E: Environmental Reports of Previous Years	185
Appendix F: References.....	186
Appendix G: Distribution List	188

List of Figures

Figure 3.01: Map of New Brunswick	12
Figure 3.02: Air Monitoring Stations.....	13
Figure 3.03: Well Water Sites.....	14
Figure 3.04: TLD Sites	15
Figure 3.05: Marine Monitoring Sites	16
Figure 4.01: Gross Beta in Air for Each Offsite Air Station	20
Figure 4.02: Gross Beta in Air for Each Onsite Air Station	20
Figure 4.03: Water Vapour (Tritium) for Each Offsite Air Station.....	24
Figure 4.04: Water Vapour (Tritium) for Each Onsite Air Station.....	24
Figure 4.05: Gaseous Tritium Emissions.....	25
Figure 4.06: Gaseous Tritium Emissions and Tritium in Air Results	25
Figure 4.07: Carbon Dioxide (Carbon-14).....	26
Figure 4.08: Gaseous Carbon-14 Emissions.....	27
Figure 4.09: Gaseous Carbon-14 Emissions and Carbon-14 in Air Results.....	27
Figure 4.10: Mean TLD Results	33
Figure 4.11: Gross Beta in Well Water.....	38
Figure 4.12: Tritium in Well Water	38
Figure 4.13: Tritium in Pond/Puddle/Surface Water	39
Figure 4.14: Cs-137 in Soil.....	46
Figure 4.15: Tritium in Rain Water	48
Figure 4.16: Tritium in Monitoring Well Water.....	50
Figure 4.17: Liquid Tritium Emissions.....	53
Figure 4.18: Liquid Carbon-14 Emissions.....	53
Figure 4.19: Cs-137 in Sediment	67
Figure 4.20: Liquid Strontium-90 Emissions	70
Figure 4.21: Tritium in Bore Hole Water	71
Figure 4.22: Tritium in Parshall Flume Water.....	74
Figure 4.23: Drop-off TLDs	78
Figure 4.24: Wind Rose for Point Lepreau (2003)	82
Figure 4.25: Pasquill Stability Factors for Point Lepreau (1986 to 1991).....	82

Figure 5.01: Dose from Airborne and Liquid Pathways.....	83
Figure 5.02: Gross Beta in Air (Offsite Air Stations).....	84
Figure 5.03: Gross Beta in Air (Onsite Air Stations).....	85
Figure 5.04: Gross Beta Activity in Air at Dipper Harbour.....	85
Figure 5.05: Annual Average Gross Beta Activity in Air for Canada 1959 to 1991 (Health and Welfare Canada Data).....	86
Figure 5.06: Gaseous Tritium Emissions.....	87
Figure 5.07: Gaseous Tritium Emissions and Water Vapour (Tritium) Results.....	87
Figure 5.08: Water Vapour (Tritium) for Offsite Air Stations.....	88
Figure 5.09: Water Vapour (Tritium) for Onsite Air Stations.....	88
Figure 5.10: Gaseous Carbon-14 Emissions.....	91
Figure 5.11: Gaseous C-14 Emissions and C-14 for Onsite Air Stations.....	91
Figure 5.12: TLD Measurements.....	92
Figure 5.13: Sr-90 in Air (GEM).....	93
Figure 5.14: Gross Beta in Well Water.....	94
Figure 5.15: Tritium in Well Water.....	95
Figure 5.16: Cs-137 in Soil.....	96
Figure 5.17: H-3 in Monitoring Well Water (near plant).....	97
Figure 5.18: H-3 in Monitoring Well Water (near plant).....	97
Figure 5.19: Liquid Tritium Emissions.....	98
Figure 5.20: Liquid C-14 Emissions.....	99
Figure 5.21: Tritium in Seawater.....	99
Figure 5.22: Cs-137 in Sediment.....	100
Figure 5.23: Sr-90 in LEM.....	101
Figure 5.24: H-3 in Bore Hole Water.....	102
Figure 5.25: H-3 in Bore Hole Water.....	102
Figure 5.26: H-3 in Bore Hole Water.....	103
Figure 5.27: H-3 in Bore Hole Water.....	103
Figure 5.28: H-3 in Bore Hole Water.....	104
Figure 5.29: H-3 in Parshall Flume Water.....	104
Figure 5.30: Drop-off TLDs.....	105
Figure 5.31: Drop-off TLDs.....	106
Figure 5.32: Drop-off TLDs.....	106

Figure 7.01: Alpha Performance (External QA).....	126
Figure 7.02: Beta Performance (External QA).....	126
Figure 7.03: C-14 Performance (External QA).....	127
Figure 7.04: Ce-141 Performance (External QA).....	127
Figure 7.05: Co-58 Performance (External QA).....	128
Figure 7.06: Co-60 Performance (External QA).....	128
Figure 7.07: Cr-51 Performance (External QA).....	129
Figure 7.08: Cs-134 Performance (External QA).....	129
Figure 7.09: Cs-137 Performance (External QA).....	130
Figure 7.10: Fe-59 Performance (External QA).....	130
Figure 7.11: H-3 Performance (External QA).....	131
Figure 7.12: I-131 Performance (External QA).....	131
Figure 7.13: Mn-54 Performance (External QA).....	132
Figure 7.14: Sr-90 Performance (External QA).....	132
Figure 7.15: Zn-65 Performance (External QA).....	133
Figure 7.16: Ba-133, Cd-109 and Ce-139 Performance (External QA).....	133
Figure 7.17: Co-57, Gamma and Hg-203 Performance (External QA).....	134
Figure 7.18: K-40, Sn-113 and Sr-85 Performance (External QA).....	134
Figure 7.19: Sr-89 and Y-88 Performance (External QA).....	135
Figure 7.20: Alpha Performance (Internal QA).....	137
Figure 7.21: Beta Performance (Internal QA).....	137
Figure 7.22: Ac-228 Performance (Internal QA).....	138
Figure 7.23: Be-7 Performance (Internal QA).....	138
Figure 7.24: C-14 Performance (Internal QA).....	139
Figure 7.25: Co-60 Performance (Internal QA).....	139
Figure 7.26: Cs-137 Performance (Internal QA).....	140
Figure 7.27: Gamma Performance (Internal QA).....	140
Figure 7.28: H-3 Performance (Internal QA).....	141
Figure 7.29: K-40 Performance (Internal QA).....	141
Figure 7.30: Nb-95 Performance (Internal QA).....	142
Figure 7.31: Sb-124 Performance (Internal QA).....	142
Figure 7.32: Sr-90 Performance (Internal QA).....	143
Figure 7.33: Gd-153, Sb-125, Sr-89 and Zr-95 Performance (Internal QA).....	143

Figure 7.34: Gamma Performance (Internal QA).....	144
Figure 7.35: C-14 Performance (Internal QA).....	145
Figure 7.36: H-3 Performance (Internal QA)	145
Figure 7.37: Am-241, Cd-109 and Co-57 Performance (Internal QA).....	146
Figure 7.38: Co-60, Cs-137 and Y-88 Performance (Internal QA).....	146

List of Tables

Table 2.01: PLGS Production Performance.....	3
Table 2.02: Radionuclides Detected in Effluents	4
Table 3.01: Schedule of Sample Collection and Analysis.....	7
Table 3.02: Sample Information	9
Table 3.03: General Location Codes	11
Table 4.01: Airborne Particulates ($\text{Bq}\cdot\text{m}^{-3}$).....	19
Table 4.02: Water Vapour - Tritium ($\text{Bq}\cdot\text{m}^{-3}$).....	22
Table 4.03: Water Vapour - Tritium ($\text{Bq}\cdot\text{m}^{-3}$).....	23
Table 4.04: Carbon Dioxide – Carbon-14 ($\text{Bq}\cdot\text{m}^{-3}$)	28
Table 4.05: Carbon Dioxide – Carbon-14 ($\text{Bq}\cdot\text{m}^{-3}$)	29
Table 4.06: Ambient Gamma – TLD (μGy)	31
Table 4.07: Milk ($\text{Bq}\cdot\text{L}^{-1}$).....	35
Table 4.08: Well Water ($\text{Bq}\cdot\text{L}^{-1}$)	37
Table 4.09: Pond/Puddle/Surface Water ($\text{Bq}\cdot\text{L}^{-1}$)	40
Table 4.10: Berries, Various ($\text{Bq}\cdot\text{kg}^{-1}$).....	43
Table 4.11: Garden Vegetables ($\text{Bq}\cdot\text{kg}^{-1}$).....	44
Table 4.12: Vegetation ($\text{Bq}\cdot\text{kg}^{-1}$).....	45
Table 4.13: Soil ($\text{Bq}\cdot\text{kg}^{-1}$).....	47
Table 4.14: Rain Water ($\text{Bq}\cdot\text{L}^{-1}$)	49
Table 4.15: Monitoring Well Water – Near Plant ($\text{Bq}\cdot\text{L}^{-1}$).....	51
Table 4.16: Seawater ($\text{Bq}\cdot\text{L}^{-1}$).....	54
Table 4.17: Clams, Edible, Raw Mass ($\text{Bq}\cdot\text{kg}^{-1}$).....	56
Table 4.18: Fish, Various, Edible, Raw Mass ($\text{Bq}\cdot\text{kg}^{-1}$)	57
Table 4.19: Lobster, Edible, Cooked Mass ($\text{Bq}\cdot\text{kg}^{-1}$).....	58
Table 4.20: Periwinkles, Edible, Raw Mass ($\text{Bq}\cdot\text{kg}^{-1}$)	61
Table 4.21: Aquaculture Salmon, Raw Mass ($\text{Bq}\cdot\text{kg}^{-1}$)	62
Table 4.22: Scallops, Edible, Raw Mass ($\text{Bq}\cdot\text{kg}^{-1}$)	63
Table 4.23: Crab, Edible, Cooked Mass ($\text{Bq}\cdot\text{kg}^{-1}$)	64
Table 4.24: Dulse, Wet Mass ($\text{Bq}\cdot\text{kg}^{-1}$).....	65
Table 4.25: Sea Plants, Wet Mass ($\text{Bq}\cdot\text{kg}^{-1}$)	66
Table 4.26: Sediment ($\text{Bq}\cdot\text{kg}^{-1}$)	68

Table 4.27: Beach Surveys - Intertidal Zone - Ion Chamber ($\mu\text{Sv}\cdot\text{h}^{-1}$).....	69
Table 4.28: Bore Hole Water, SRWMF - Phase 1 ($\text{Bq}\cdot\text{L}^{-1}$).....	72
Table 4.29: Bore Hole Water, SRWMF - Phase 2 ($\text{Bq}\cdot\text{L}^{-1}$).....	73
Table 4.30: Parshall Flume Water, SRWMF - Phase 1 ($\text{Bq}\cdot\text{L}^{-1}$).....	75
Table 4.31: Parshall Flume Water, SRWMF - Phase 2 ($\text{Bq}\cdot\text{L}^{-1}$).....	76
Table 4.32: TLD, Drop-off (μGy).....	77
Table 4.33: Liquid ($\text{Bq}\cdot\text{L}^{-1}$), Hemlock Knoll Regional Sanitary Landfill.....	79
Table 4.34: Meteorological Data for Point Lepreau (2003)	80
Table 4.35: Meteorological Data for Point Lepreau (average 1986 to 1991).....	81
Table 5.01: Normalised Mean Dispersion Factor at 1 km for All Indicator Locations	89
Table 5.02: Average Atmospheric Dispersion Factor for Each Air Monitoring Location	90
Table 6.01: Annual Dose	107
Table 7.01: QC Passes & Failures	109
Table 7.02: External Quality Assurance Frequency	111
Table 7.03: Radionuclide Performance (External QA).....	112
Table 7.04: Filter Performance (External QA)	119
Table 7.05: Charcoal Cartridge Performance (External QA)	120
Table 7.06: Environmental TLD Performance (External QA)	120
Table 7.07: Milk Performance (External QA)	121
Table 7.08: Water Performance (External QA)	122
Table 7.09: Food/Vegetation Performance (External QA)	124
Table 7.10: Soil Performance (External QA)	125
Table 7.11: Urine Performance (External QA).....	125
Table 7.12: Internal Quality Assurance Frequency	136

This page is intentionally blank.

1 Introduction

The licence to operate PLGS, issued by the Canadian Nuclear Safety Commission (CNSC), requires that NB Power maintain an Operational Environmental Radiation Monitoring Program (OERMP) during normal plant operations. This document describes the results of the program for the year 2003.

The requirement for this program is stated in *Radiation Protection Directives*⁽⁴⁾ and *Solid Radioactive Waste Management Facility 2002 Safety Report*⁽⁵⁾. The underlying reason for this is the large inventory of radionuclides that exist on site. The program operates in conjunction with *Online Monitoring and Control of Liquid and Airborne Effluents*⁽⁶⁾, which monitors and controls effluents at their source. The Derived Emission Limits (DELs) are calculated in *Derived Emission Limits for Radionuclides in Airborne and Liquid Effluents*⁽⁷⁾.

As part of its overall Management System, Point Lepreau has an Environmental Management System (EMS)⁽⁸⁾ in place that is registered to International Organization for Standardization (ISO) 14001⁽⁹⁾. All activities and products that could impact the environment have been identified and logged in a database. From this, a list of significant environmental aspects (SEAs) was developed and it forms the foundation for the EMS. Management programs are in place for each of the SEAs to ensure compliance with the standards. The SEAs include radiological and non-radiological releases to water and air, waste management and accident management. Environmental assessment and improvement programs have been developed for the SEAs to ensure continual improvement.

All activities that support PLGS will be controlled by the PLGS Management System that is under development. The environmental monitoring program falls under the primary process *SU-02 Provide Environmental Services*⁽¹⁰⁾. This process was mapped in 2002, and all sub-processes related to routine environmental monitoring now come under it.

Monitoring of the site began in 1976 with the Pre-operational Program⁽¹¹⁾, which became the OERMP in 1982⁽¹²⁾. PLGS was declared "in-service" in February 1983. All radionuclide analyses in 2003 were performed in the Health Physics Fredericton Laboratory at 420 York Street, Fredericton, NB by the three full-time staff members (Health Physicist, Senior Technical Specialist and Engineer/Scientist I-IV).

The radiation monitoring program for PLGS is reviewed annually. This ensures that the samples collected, their frequency of collection, and the analytical techniques used are appropriate to achieve the objectives of the program. Late in 1999, the basis of the OERMP was extensively revised to comply with *Guidelines for Radiological Monitoring of the Environment*⁽¹³⁾, which did not exist when this program was first implemented.

The Environmental Radiation Monitoring Program for PLGS fulfils several objectives. These are to:

- 1) permit the estimation of dose to critical groups and populations from the radioactive emissions from PLGS and its Solid Radioactive Waste Management

Facility (SRWMF). This is achieved through the analyses of environmental and effluent samples.

- 2) provide data to confirm compliance of PLGS and the SRWMF with release guidelines and regulations and to provide public assurance of compliance. This is achieved through the issuance of the annual report to all interested parties.
- 3) establish and maintain the capability for environmental monitoring so that an effective response can be made to emergency conditions. This is achieved by maintaining the resources to step up the monitoring program during increased emissions that are only likely during an accident. The ability to interpret the data and make recommendations is also maintained.
- 4) maintain a database to facilitate the detection of trends. This is achieved by storing all results on a computer system that has the capability of reporting and graphing any desired subsets of the data.
- 5) verify or refine environmental models used in the calculation of Derived Emission Limits (DELs). This is achieved by comparing the theoretical dispersion factor with one calculated empirically. As well, other exposure routes to the public are continually evaluated.
- 6) determine the fate of released radioactive materials to show whether any significant pathway to humans has been overlooked. This is achieved through the collection and analysis of sample media outside of the established program. As well, any results that are not consistent with effluent results are investigated.

The capability of the radiation monitoring laboratory is assessed through the QA program. Analytical checks are also conducted daily. Indicator radionuclides, for example K-40 in milk, seawater and in other samples, show that the analyses are reproducible and that the operation of the laboratory has not changed significantly since it began.

The following sections will briefly describe the program. Details are provided on PLGS emissions, analyses results, trends, dose estimates, and the quality assurance program.

2 Point Lepreau Emission Data

Table 2.01 lists the production performance for PLGS since its beginning. Experience has shown that the years of lower capacity factors are usually the years with the lowest airborne emissions of most radionuclides, especially noble gases. The opposite is true for liquid emissions.

Table 2.01: PLGS Production Performance

<i>Year</i>	<i>Annual Gross Capacity Factor (%)</i>
1983	86
1984	90
1985	97
1986	94
1987	92
1988	96
1989	95
1990	96
1991	98
1992	87
1993	95
1994	94
1995	29
1996	83
1997	62
1998	68
1999	74
2000	71
2001	80
2002	68
2003	85
Lifetime (Since In-service)	83

Emissions from PLGS continue to be at low levels as indicated in Table 2.02. By the time these emissions reach the edge of the exclusion zone, they are diluted below the detection limits of most analytical procedures. Laboratory staff monitor the results of the emissions programs so that adjustments can be made to sampling and analysis protocols. There were no unusual emissions during the year 2003.

Table 2.02: Radionuclides Detected in Effluents

Nuclide	Gaseous Effluent DEL (Bq·a⁻¹)	Emission (Bq)	Liquid Effluent DEL (Bq·a⁻¹)	Emission (Bq)
H-3	4.3E+17	1.0E+14	1.6E+19	8.1E+13
C-14	3.3E+15	2.1E+11	3.0E+14	1.8E+09
Na-24	5.6E+15		-----	
Ar-41	6.4E+16	1.7E+12	-----	
Sc-46	1.7E+14		-----	
Cr-51	2.4E+16		2.2E+15	3.5E+07
Mn-54	1.1E+14		6.4E+13	3.3E+06
Fe-55	-----		5.1E+14	
Fe-59	4.0E+14		3.1E+13	7.6E+06
Co-58	3.0E+14		7.5E+13	
Co-60	6.5E+12		1.8E+13	3.0E+08
Zn-65	7.1E+13		1.5E+13	9.7E+05
As-76	-----		3.2E+14	
Kr-85	1.9E+19		-----	
Kr-85m	5.2E+17	2.3E+10	-----	
Kr-87	9.4E+16	1.5E+09	-----	
Kr-88	2.8E+16		-----	
Sr-89	3.7E+14		4.4E+16	2.9E+04
Sr-90	1.2E+13		2.2E+15	1.5E+06
Y-90	8.2E+15		4.0E+15	
Y-91	-----		3.1E+15	
Zr-95	1.7E+14		3.7E+13	2.3E+08
Nb-95	1.3E+14		1.1E+14	6.3E+08
Mo-99	5.4E+15		1.3E+16	
Ru-103	1.2E+15		1.8E+14	
Ru-106	7.7E+13		2.7E+14	
Ag-110m	3.8E+13		1.8E+13	1.1E+06
Sb-122	-----		1.8E+14	1.3E+07
Sb-124	2.5E+14		4.8E+13	7.0E+07
Sb-125	-----		1.9E+14	5.0E+05
Te-132	1.4E+15		2.9E+13	
I-123	-----		4.2E+16	

Table 2.02 (continued): Radionuclides Detected in Effluents

Nuclide	Gaseous Effluent DEL (Bq·a ⁻¹)	Emission (Bq)	Liquid Effluent DEL (Bq·a ⁻¹)	Emission (Bq)
I-125	-----		2.3E+14	
I-129	-----		1.9E+13	
I-131	2.2E+13		3.0E+14	
I-132	1.5E+16		2.4E+16	
I-133	8.9E+14		3.5E+15	
I-134	1.9E+16		3.6E+17	
I-135	7.7E+15		9.2E+15	
Xe-131m	9.9E+18		-----	
Xe-133	2.4E+18	1.9E+12	-----	
Xe-133m	2.8E+18		-----	
Xe-135	3.4E+17	9.2E+11	-----	
Xe-135m	2.0E+17	1.2E+10	-----	
Xe-138	2.2E+16	3.3E+10	-----	
Cs-134	1.9E+13		2.5E+14	
Cs-135	-----		3.4E+15	
Cs-136	-----		6.3E+14	
Cs-137	5.4E+12		4.0E+14	1.5E+06
Ba-140	7.4E+14		9.4E+15	
La-140	1.1E+16		4.7E+14	
Ce-141	2.1E+15		7.4E+14	
Ce-144	1.1E+14		2.8E+14	3.9E+05
Np-239	1.0E+16		-----	
Noble Gas	7.3E+16 (Bq·MeV)		-----	
Cu-64	-----		-----	
Sn-113	-----		-----	5.8E+05
Xe-137	-----	2.1E+10	-----	
Gd-153	-----		-----	2.0E+07
Gd-159	-----		-----	
Tb-160	-----		-----	1.8E+07
Hf-181	-----		-----	
W-187	-----		-----	9.1E+05
Alpha	-----		-----	1.3E+07
Beta	-----		-----	9.4E+07

Emissions from some locations require the use of a different DEL to compensate for flow rates.

3 Sample Media, Locations and Frequencies

The data contained in this report are for samples collected from January 1 to December 31, 2003, with some overlap for air, precipitation and TLD samples. During this time, the major media analysed and their frequency of collection were as indicated in Table 3.01. Sample collection usually takes place at least once each week throughout the year. The number of each sample type and the major radionuclide measurements performed are listed in Table 3.02.

The miscellaneous sample group includes those that do not fit into any of these listed categories or are not routinely collected. These include numerous in-station samples (e.g., drinking water) relating to the operation of PLGS.

The major sample locations are listed in Table 3.03 (details in Appendix C) and shown in Figures 3.02 to 3.05. Each "Indicator" site has a three or four-character identification code (e.g., F01, I10A). An Indicator site is one within the possible influence of PLGS emissions. "Reference" locations, chosen to lie outside the influence of PLGS emissions, are identified by the letter R at the end of the location code (e.g., A01R).

Sample locations for mobile seafood species (lobster, fish, etc.) caught in the Point Lepreau area are specified as accurately as reasonably possible. The location of capture, however, may bear little relationship to where the animal has been in the recent past. The availability of such samples is not generally predictable and is outside of the control of the laboratory.

Table 3.01: Schedule of Sample Collection and Analysis

Sample Medium	Typical Frequency
<i>Atmospheric Sampling</i>	
Airborne Particulates	Monthly (integrated sample)
Airborne Iodines	Monthly (integrated sample)
Airborne Water Vapour	Monthly (integrated sample)
Airborne Carbon Dioxide	Monthly (integrated sample)
Ambient Gamma (TLDs)	Quarterly (integrated sample)
Gaseous Effluent Monitor (GEM) Filters	Weekly Composite (integrated sample)
<i>Terrestrial Sampling</i>	
Ambient Gamma (TLDs)	Quarterly (integrated sample)
Milk - commercial dairy - dairy farms	Monthly Quarterly
Well Water	Semi-annually
Pond, Puddle and Surface Water	Quarterly
Berries	Weekly in Season
Garden Vegetables	Weekly in Season
Vegetation	Quarterly
Soil	Quarterly
Near Plant Monitoring Wells	Annually
Precipitation	Monthly (integrated sample)
<i>Marine Sampling</i>	
Seawater	Quarterly
Clams	Quarterly When Available
Fish	Quarterly When Available
Lobster	Quarterly When Available
Periwinkles	Quarterly When Available
Aquaculture Salmon	Quarterly When Available
Scallops	Quarterly When Available
Crabs	Quarterly When Available
Dulse	Quarterly When Available
Other Sea Plants	Quarterly
Sediment	Quarterly
Gamma Surveys (Beaches)	Quarterly
Liquid Effluent Monitor (LEM) Composite	Monthly Composite (integrated sample)

Table 3.01 (continued): Schedule of Sample Collection and Analysis

<i>Sample Medium</i>	<i>Typical Frequency</i>
<i>Solid Radioactive Waste Management Facility</i>	
Bore Hole Water	Three Times Per Year
Parshall Flume Water	Weekly
Ambient Gamma (TLDs)	Quarterly (integrated sample)
<i>Hemlock Knoll Regional Sanitary Landfill</i>	
Monitoring Well Water	Annually
Water (leachate and settling/holding ponds)	Monthly to Semi-annually
Ambient Gamma (TLDs)	Quarterly (integrated sample)

Table 3.02: Sample Information

<i>Sample Medium</i>	<i>Number of Samples</i>	<i>Radionuclide Measurements</i>
<i>Atmospheric Sampling</i>		
Airborne Particulates	96	gamma emitters & gross alpha/beta
Airborne Iodines	96	I-130,131,132,133,135
Airborne Water Vapour	96	H-3
Airborne Carbon Dioxide	36	C-14
Ambient Gamma (TLDs)*	127*	gamma exposure
GEM Filters	52	Sr-89,90 & gamma emitters
<i>Terrestrial Sampling</i>		
Ambient Gamma (TLDs)*	127*	gamma exposure
Milk - commercial dairy	11	gamma emitters & H-3
- dairy farms	12	
Well Water	31	gamma emitters, gross alpha/beta & H-3
Pond, Puddle and Surface Water	22	gamma emitters & H-3
Berries	5	gamma emitters
Garden Vegetables	19	gamma emitters
Vegetation	15	gamma emitters
Soil	36	gamma emitters
Near Plant Monitoring Wells	11	gamma emitters & H-3
Precipitation	44	gamma emitters & H-3
<i>Marine Sampling</i>		
Seawater	15	gamma emitters & H-3
Clams	9	gamma emitters
Fish	1	gamma emitters
Lobster	6	gamma emitters
Periwinkles	10	gamma emitters
Aquaculture Salmon	5	gamma emitters
Scallops	2	gamma emitters
Crabs	1	gamma emitters
Dulse	10	gamma emitters
Other Sea Plants	12	gamma emitters
Sediment	40	gamma emitters
Gamma Surveys (Beaches)	40	gamma exposure
LEM Composite	13	Sr-89,90, gamma emitters, gross alpha/beta

*The same TLD measures gamma dose from radionuclides in the air and on the ground.

Table 3.02 (continued): Sample Information

<i>Sample Medium</i>	<i>Number of Samples</i>	<i>Radionuclide Measurements</i>
<i>Solid Radioactive Waste Management Facility</i>		
Bore Hole Water	67	gamma emitters & H-3
Parshall Flume Water	103	gamma emitters & H-3
Ambient Gamma (TLDs)	164	gamma exposure
<i>Hemlock Knoll Regional Sanitary Landfill</i>		
Monitoring Well Water	31	gamma emitters & H-3
Water (leachate and settling/holding ponds)	17	gamma emitters & H-3
Ambient Gamma (TLDs)	20	gamma exposure
<i>Other</i>		
Miscellaneous	65	as required
Quality Assurance	255	as scheduled

Table 3.03: General Location Codes

<i>Code</i>	<i>Location</i>
A	West of Pennfield Ridge
B	Pennfield to New River Beach (inclusive)
C	Lepreau and Lepreau Harbour
D	Little Lepreau and Little Lepreau Basin
E	Maces Bay
F	Welch Cove
G	Pt. Lepreau lighthouse and surrounding area
H	Duck Cove
I	PLGS site – northeast quadrant
J	PLGS site – southeast quadrant
K	PLGS site – southwest quadrant
L	PLGS site – northwest quadrant
M	PLGS
N	Dipper Harbour
P	East of Dipper Harbour East to Musquash
Q	Lorneville
S	Saint John and surrounding area
T	Taymouth
X	Fredericton and surrounding area
Y	Hemlock Knoll Regional Sanitary Landfill



Figure 3.01: Map of New Brunswick




Figure 3.02: Air Monitoring Stations



Figure 3.02: Air Monitoring Stations




Figure 3.03: Well Water Sites




Figure 3.04: TLD Sites



Figure 3.03: Well Water Sites



Figure 3.04: TLD Sites



Figure 3.05: Marine Monitoring Sites




Figure 3.05: Marine Monitoring Sites

4 Summary and Discussion of Data

The following is a summary and discussion of the data on environmental samples collected for the year 2003.

Most samples contained detectable levels of naturally occurring K-40 or cosmogenically produced Be-7. Some contained Cs-137 (soils, sediments, lichen) from the atmospheric bomb tests of past years and the Chernobyl accident. Tritium (in air and fresh water) is the only radionuclide originating from PLGS that is detected consistently. In 2003, analyses that indicated emissions traceable to PLGS were:

- H-3 in airborne water vapour and fresh water
- TLD measurements at onsite locations
- H-3 in Parshall flume and bore hole water from the Solid Radioactive Waste Management Facility (SRWMF)
- H-3 in water from onsite monitoring wells

The only assessable radiation dose from PLGS on the local population is that from tritiated water vapour in air. Offsite, the activity of H-3 in air ranges from less than about $2\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$ (below the lower limit of detection by the method used) to about $5\text{E-}01 \text{ Bq}\cdot\text{m}^{-3}$ of air. The natural concentration of H-3 is up to $7\text{E-}01 \text{ Bq}\cdot\text{L}^{-1}$ in most surface waters and up to $1\text{E-}03 \text{ Bq}\cdot\text{m}^{-3}$ in air.

The natural concentration of C-14 in the atmosphere is approximately $4\text{E-}2 \text{ Bq}\cdot\text{m}^{-3}$. This level is usually detected by the sensitive analytical method used in the monitoring program.

Only detected radionuclides are listed in the following tables. Refer to Tables A.01 to A.11 in Appendix A for detailed listings of detection limits. Refer to Appendix C for a listing of location codes. Most tables contain the following data:

Column 1 - Shows the type of analysis or nuclide.

Column 2 - Shows the total number of samples analysed.

Column 3 - Shows the mean of the Critical Levels (CLs) for all samples. Any measurement greater than the CL is considered detected at the 99% confidence level (an explanation of the statistical protocol is given in Appendix A).

Column 4 - Shows the range of the Critical Levels (CLs) for all samples. Any measurement greater than the CL is considered detected at the 99% confidence level (an explanation of the statistical protocol is given in Appendix A).

Column 5 - Shows the mean of the detected values (i.e., values exceeding the CL) for all Indicator stations.

Column 6 - Shows the ratio of the number of detected values to the total number of Indicator samples.

Column 7 - Shows the range of detected values for the Indicator stations.

Column 8 - Shows the mean of detected values at the Reference location(s).

Column 9 - Shows the ratio of detected values to the total number of samples at this location.

Column 10 - Shows the range of detected values for the Reference location(s).

4.01 Airborne Particulates

Of the 96 filters analysed, Be-7 was detected on 94, gross alpha was detected on 95, and gross beta was detected on 96. None of these are attributable to the operation of PLGS.

Air is continuously monitored from the eight locations shown in Figure 3.02. Once a month the filters are changed and analysed. There were 17 collection days lost at G02 due to a power failure.

Gross alpha and gross beta measurements are an indication of total activity in the environment. This includes naturally occurring radon progeny, cosmogenic (Be-7), and man-made sources of radiation. The maximum concentration of gross beta in air onsite was $6.0\text{E-}04 \text{ Bq}\cdot\text{m}^{-3}$ of air. Offsite it reached $4.7\text{E-}04 \text{ Bq}\cdot\text{m}^{-3}$.

When Sr-89,90 emissions are low, the expected concentration in environmental air samples is below the detection limit. The GEM monitors PLGS gaseous emissions continuously at their source. The GEM filters are changed daily and the weekly composite is sent to the lab for analysis. Fifty-two sets of these GEM filters were analysed for Sr-89,90. If the emission rate is more than 1% DEL, or if significant beta activity is detected in environmental air samples, a Sr-89,90 analysis is performed on those samples. Since no Sr-89,90 emissions were detected in 2003, no further analyses were required.

Table 4.01 is a summary of detected radionuclides. Figures 4.01 and 4.02 show the gross beta results for each location throughout the year. There is a slight seasonal trend in the data.

Table 4.01: Airborne Particulates ($\text{Bq}\cdot\text{m}^{-3}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
<i>Alpha</i>	96	3.5E-06	1.4E-06 to 1.3E-05	2.1E-05	83/84	6.5E-06 to 6.0E-05	1.9E-05	12/12	7.0E-06 to 4.1E-05
<i>Beta</i>	96	7.3E-06	2.5E-06 to 2.8E-05	2.2E-04	84/84	6.1E-05 to 6.0E-04	2.3E-04	12/12	1.1E-04 to 4.7E-04
<i>Bc-7</i>	96	2.9E-04	4.9E-05 to 1.7E-03	8.8E-04	82/84	2.5E-04 to 2.5E-03	9.0E-04	12/12	3.7E-04 to 1.5E-03




Figure 4.01: Gross Beta in Air for Each Offsite Air Station




Figure 4.02: Gross Beta in Air for Each Onsite Air Station

4.02 Airborne Iodines

No radioiodines were detected in any of the 96 samples analysed.

Air is monitored continuously, using charcoal cartridges, from the eight locations shown in Figure 3.02. Once a month the cartridges are changed and analysed. There were 17 collection days lost at G02 due to a power failure.

Iodine-131 was consistently below the Critical Level (average $7.4\text{E-}06 \text{ Bq}\cdot\text{m}^{-3}$).

4.03 Water Vapour

Tritium was detected in 73 of the 84 samples collected from the air monitoring stations on the Point Lepreau peninsula, and was not detected in any of the 12 samples at the reference location.

Water vapour is collected continuously in molecular sieve bombs from the eight locations shown in Figure 3.02. Once a month the bombs are changed and analysed. There were 17 collection days lost at G02 due to a power failure.

The maximum concentration of tritium in air onsite was $2.9\text{E}+00 \text{ Bq}\cdot\text{m}^{-3}$ of air. Offsite it reached $5.1\text{E-}01 \text{ Bq}\cdot\text{m}^{-3}$. Tritium has been detected from time to time at the reference location, even before PLGS became operational.

Table 4.02 is the summary table of the tritium data and Table 4.03 gives details of the tritium results by location. Figures 4.03 and 4.04 show the H-3 results for each location. "Less Than" values are plotted for non-detected results. Locations to the northeast (H04, I01 and N01) have elevated H-3 measurements in the warmer months due to the predominant summer wind direction, which changes in the winter to impact the southwest locations (G02 and L04).

When H-3 emissions are low, the expected concentration in other environmental samples is below the detection limit. If the H-3 emission rate is more than 1% DEL, a H-3 analysis is performed on berries and garden vegetables. This was not the case in 2003. Figure 4.05 shows the weekly H-3 emissions and Figure 4.06 compares the emissions with the environmental air monitoring results.

Table 4.02: Water Vapour - Tritium ($\text{Bq}\cdot\text{m}^{-3}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	96	6.3E-02	1.5E-02 to 1.3E-01	6.0E-01	73/84	4.8E-02 to 2.9E+00	*	*	*

*The activity is less than or equal to the Critical Level (99% Confidence Level).

Table 4.03: Water Vapour - Tritium ($\text{Bq}\cdot\text{m}^{-3}$)

Location Code	A01R	E01	F01	G02	H04	I01	L04	N01
Location	Bocabec	Maces Bay	Welch Cove	Lepreau Lighthouse	Old Site of Information Centre	SRWMF	Construction Stores	Dipper Harbour
Distance from PLGS	45 km	4.5 km	1.6 km	1.0 km	0.75 km	1.2 km	0.55 km	3.7 km
Collection Start Date The sample collection periods are approximately one month in duration. All sample stations are changed at the same time. The start date is the stop date for the previous sample.	2003-01-09	<1.5E-02	<1.8E-02	4.9E-02	1.9E-01	1.7E-01	2.3E-01	<2.5E-02
	2003-02-17	<1.1E-01	<4.5E-02	5.6E-02	2.4E-01	4.9E-01	1.7E-01	6.8E-02
	2003-03-19	<7.7E-02	<6.6E-02	6.9E-02	3.3E-01	9.2E-01	2.7E-01	8.6E-02
	2003-04-15	<6.0E-02	<4.1E-02	1.4E-01	2.7E-01	2.4E+00	5.5E-01	2.2E-01
	2003-05-08	<6.9E-02	<1.1E-01	1.4E-01	8.3E-02	5.4E-01	8.8E-01	1.8E-01
	2003-06-11	<7.1E-02	7.4E-02	2.1E-01	6.6E-02	2.2E+00	2.5E-01	4.7E-01
	2003-07-10	<1.1E-01	1.4E-01	2.7E-01	<1.3E-01	1.4E+00	4.1E-01	2.8E-01
	2003-08-20	<4.4E-02	<1.4E-01	1.7E-01	3.3E-01	1.1E+00	<1.6E-01	3.5E-01
	2003-09-15	<6.5E-02	2.6E-01	4.3E-01	1.8E-01	1.8E+00	1.9E+00	5.1E-01
	2003-10-07	<8.8E-02	<1.5E-01	1.8E-01	3.8E-01	9.4E-01	8.3E-01	2.1E-01
	2003-11-05	<6.1E-02	1.8E-01	2.0E-01	5.9E-01	8.9E-01	3.4E-01	8.5E-02
	2003-12-03	<3.4E-02	<5.1E-02	1.1E-01	1.6E-01	4.4E-01	3.3E-01	4.8E-02




Figure 4.03: Water Vapour (Tritium) for Each Offsite Air Station




Figure 4.04: Water Vapour (Tritium) for Each Onsite Air Station




Figure 4.05: Gaseous Tritium Emissions




Figure 4.06: Gaseous Tritium Emissions and Tritium in Air Results

4.04 Carbon Dioxide

Carbon-14 was detected in 24 of the 24 samples from the onsite monitors and 11 of the 12 samples from the offsite monitor. This is not attributable to the operation of PLGS because the maximum levels offsite (Fredericton) were the same as onsite.

Air is continuously bubbled through a caustic solution at two onsite locations (G02 and H04 in Figure 3.02) and one reference location. The caustic bubblers are changed monthly and returned to the lab for analysis. There were 17 collection days lost at G02 due to a power failure.

The maximum concentration of C-14 in air onsite was $6.2\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$ of air. Offsite it also reached $6.2\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$. The results for the two onsite monitors (mean of $4.3\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$) were very similar to the reference monitor (mean of $5.0\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$). Based on stack emissions, the calculated average annual concentration of C-14 in air at the boundary fence for 2003 was less than $2\text{E-}03 \text{ Bq}\cdot\text{m}^{-3}$ (well below the natural level of $4\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$).

Individual analysis results are given in Table 4.04 by location (graphically shown in Figure 4.07). Table 4.05 gives details of C-14 results.

When C-14 emissions are low, the expected concentration in other environmental samples is below the detection limit. If the C-14 emission rate is more than 1% DEL, a C-14 analysis is performed on berries, milk, water and garden vegetables. This was not the case in 2003. Figure 4.08 shows the weekly C-14 emissions and Figure 4.09 compares the emissions with the environmental air monitoring results.




Figure 4.07: Carbon Dioxide (Carbon-14)




Figure 4.08: Gaseous Carbon-14 Emissions




Figure 4.09: Gaseous Carbon-14 Emissions and Carbon-14 in Air Results

Table 4.04: Carbon Dioxide – Carbon-14 ($\text{Bq}\cdot\text{m}^{-3}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
C-14	36	2.2E-02	1.9E-02 to 4.7E-02	4.3E-02	24/24	3.0E-02 to 6.2E-02	5.0E-02	11/12	2.9E-02 to 6.2E-02

Table 4.05: Carbon Dioxide – Carbon-14 ($\text{Bq}\cdot\text{m}^{-3}$)

Location Code	G02	H04	X03R
Location	Lepreau Lighthouse	Old Site of Information Centre	Fredericton Laboratory
Distance from PLGS	1.0 km	0.75 km	100 km
2003-01-09	3.8E-02	4.6E-02	5.2E-02
2003-02-17	3.6E-02	4.3E-02	4.6E-02
2003-03-19	4.9E-02	4.0E-02	5.0E-02
2003-04-15	6.2E-02	3.5E-02	4.5E-02
2003-05-08	4.8E-02	4.3E-02	5.8E-02
2003-06-11	3.0E-02	4.2E-02	5.1E-02
2003-07-10	4.3E-02	3.8E-02	2.9E-02
2003-08-20	3.8E-02	4.3E-02	6.2E-02
2003-09-15	3.9E-02	4.9E-02	<9.2E-02
2003-10-07	3.4E-02	3.2E-02	5.1E-02
2003-11-05	4.8E-02	5.8E-02	5.8E-02
2003-12-03	6.0E-02	4.1E-02	4.9E-02

Collection Start Date

The sample collection periods are approximately one month in duration. All sample stations are changed at the same time. The start date is the stop date for the previous sample.

4.05 Ambient Gamma (TLD)

Gamma exposure measurements were slightly higher onsite, especially near the SRWMF and reactor building, than they were offsite.

Ambient gamma radiation is measured by TLDs at the 78 locations shown in Figure 3.04. Forty-one of these are near the Solid Radioactive Waste Management Facility. TLDs are changed quarterly. The result on one of the 312 dosimeters placed in the environment was not used due to water damage.

The average for the SRWMF ($890 \mu\text{Gy}\cdot\text{a}^{-1}$) is slightly higher than other onsite locations ($760 \mu\text{Gy}\cdot\text{a}^{-1}$) and boundary locations ($600 \mu\text{Gy}\cdot\text{a}^{-1}$). These other onsite locations are not significantly different from offsite locations ($590 \mu\text{Gy}\cdot\text{a}^{-1}$) and the reference location ($600 \mu\text{Gy}\cdot\text{a}^{-1}$). A new location was added in 2001 in a community remote from PLGS. The area is noted for its natural uranium content. The measurement there ($1590 \mu\text{Gy}\cdot\text{a}^{-1}$) is higher than any location at PLGS.

Data are given in Table 4.06. The locations J70 and M02, close to the reactor building and the air emissions stack, show increases in gamma radiation due to chronic emissions of low levels of noble gases. Increases at the SRWMF locations (I11A to I11L on the perimeter fence of the SRWMF-Phase 1 and I21A to I21L on the perimeter of the SRWMF-Phase 2) are due to low-level waste and used fuel emplacement, and not to station emissions. There is a small, but undefinable, component of radiation on the TLDs at the SRWMF that is due to enhanced natural radiation from the aggregate in the concrete structures. The results for the drop-off TLDs for SRWMF-Phase 2 are shown in Table 4.32. Figure 4.10 compares the reference location results with the results for other locations.

Ten sampling locations were discontinued at the end of 2001. The discontinued locations were near the SRWMF. They were below the line of site to the SRWMF and were hazardous to access.

Table 4.06: Ambient Gamma – TLD (μGy)

Location	Dose ($\mu\text{Gy} \pm 10\%$)				
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	Year
A01R	125 $\pm$ 13	144 $\pm$ 14	168 $\pm$ 17	166 $\pm$ 17	600 $\pm$ 30
B03	116 $\pm$ 12	156 $\pm$ 16	179 $\pm$ 18	166 $\pm$ 17	620 $\pm$ 30
C03	116 $\pm$ 12	131 $\pm$ 13	161 $\pm$ 16	152 $\pm$ 15	560 $\pm$ 30
D02	119 $\pm$ 12	162 $\pm$ 16	193 $\pm$ 19	183 $\pm$ 18	660 $\pm$ 30
E01	144 $\pm$ 14	142 $\pm$ 14	165 $\pm$ 16	160 $\pm$ 16	610 $\pm$ 30
E04	100 $\pm$ 10	91 $\pm$ 9	118 $\pm$ 12	111 $\pm$ 11	420 $\pm$ 20
E05	140 $\pm$ 14	143 $\pm$ 14	182 $\pm$ 18	169 $\pm$ 17	630 $\pm$ 30
E06	208 $\pm$ 21	187 $\pm$ 19	244 $\pm$ 24	235 $\pm$ 24	870 $\pm$ 40
F01	102 $\pm$ 10	117 $\pm$ 12	135 $\pm$ 13	133 $\pm$ 13	490 $\pm$ 20
G02	166 $\pm$ 17	171 $\pm$ 17	207 $\pm$ 21	196 $\pm$ 20	740 $\pm$ 40
H04	134 $\pm$ 13	146 $\pm$ 15	160 $\pm$ 16	156 $\pm$ 16	600 $\pm$ 30
H05	110 $\pm$ 11	114 $\pm$ 11	147 $\pm$ 15	137 $\pm$ 14	510 $\pm$ 30
I11A	167 $\pm$ 17	210 $\pm$ 21	254 $\pm$ 25	234 $\pm$ 23	860 $\pm$ 40
I11B	186 $\pm$ 19	230 $\pm$ 23	267 $\pm$ 27	231 $\pm$ 23	910 $\pm$ 50
I11C	181 $\pm$ 18	206 $\pm$ 21	249 $\pm$ 25	230 $\pm$ 23	870 $\pm$ 40
I11D	160 $\pm$ 16	199 $\pm$ 20	233 $\pm$ 23	221 $\pm$ 22	810 $\pm$ 40
I11E	169 $\pm$ 17	221 $\pm$ 22	233 $\pm$ 23	218 $\pm$ 22	840 $\pm$ 40
I11F	183 $\pm$ 18	216 $\pm$ 22	255 $\pm$ 25	228 $\pm$ 23	880 $\pm$ 40
I11G	171 $\pm$ 17	231 $\pm$ 23	249 $\pm$ 25	224 $\pm$ 22	880 $\pm$ 40
I11H	180 $\pm$ 18	226 $\pm$ 23	253 $\pm$ 25	226 $\pm$ 23	890 $\pm$ 40
I11I	186 $\pm$ 19	247 $\pm$ 25	254 $\pm$ 25	230 $\pm$ 23	920 $\pm$ 50
I11J	166 $\pm$ 17	226 $\pm$ 23	265 $\pm$ 26	219 $\pm$ 22	880 $\pm$ 40
I11K	180 $\pm$ 18	206 $\pm$ 21	230 $\pm$ 23	213 $\pm$ 21	830 $\pm$ 40
I11L	158 $\pm$ 16	218 $\pm$ 22	234 $\pm$ 23	195 $\pm$ 20	810 $\pm$ 40
I21A	187 $\pm$ 19	189 $\pm$ 19	228 $\pm$ 23	193 $\pm$ 19	800 $\pm$ 40
I21B	242 $\pm$ 24	248 $\pm$ 25	263 $\pm$ 26	225 $\pm$ 23	980 $\pm$ 50
I21C	194 $\pm$ 19	200 $\pm$ 20	229 $\pm$ 23	196 $\pm$ 20	820 $\pm$ 40
I21D	296 $\pm$ 30	388 $\pm$ 39	363 $\pm$ 36	356 $\pm$ 36	1400 $\pm$ 70
I21E	247 $\pm$ 25	312 $\pm$ 31	341 $\pm$ 34	286 $\pm$ 29	1190 $\pm$ 60
I21F	197 $\pm$ 20	192 $\pm$ 19	233 $\pm$ 23	218 $\pm$ 22	840 $\pm$ 40
I21G	177 $\pm$ 18	182 $\pm$ 18	286 $\pm$ 29	256 $\pm$ 26	900 $\pm$ 50
I21H	181 $\pm$ 18	194 $\pm$ 19	266 $\pm$ 27	264 $\pm$ 26	910 $\pm$ 50
I21I	150 $\pm$ 15	173 $\pm$ 17	218 $\pm$ 22	194 $\pm$ 19	730 $\pm$ 40
I21J	182 $\pm$ 18	194 $\pm$ 19	224 $\pm$ 22	205 $\pm$ 20	800 $\pm$ 40
I21K	176 $\pm$ 18	193 $\pm$ 19	218 $\pm$ 22	227 $\pm$ 23	810 $\pm$ 40
I21L	156 $\pm$ 16	179 $\pm$ 18	219 $\pm$ 22	210 $\pm$ 21	760 $\pm$ 40

Table 4.06 (continued): Ambient Gamma – TLD (μGy)

Location	Dose ($\mu\text{Gy} \pm 10\%$)				
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	Year
I75	170 $\pm$ 17	172 $\pm$ 17	211 $\pm$ 21	179 $\pm$ 18	730 $\pm$ 40
I86	159 $\pm$ 16	157 $\pm$ 16	188 $\pm$ 19	173 $\pm$ 17	680 $\pm$ 30
I87	142 $\pm$ 14	152 $\pm$ 15	186 $\pm$ 19	NA	640 $\pm$ 30
I88	143 $\pm$ 14	154 $\pm$ 15	191 $\pm$ 19	170 $\pm$ 17	660 $\pm$ 30
I89	132 $\pm$ 13	163 $\pm$ 16	179 $\pm$ 18	172 $\pm$ 17	650 $\pm$ 30
I90	suspended at the end of 2001				
I91	suspended at the end of 2001				
I92	suspended at the end of 2001				
I93	suspended at the end of 2001				
I94	suspended at the end of 2001				
I95	suspended at the end of 2001				
I98	suspended at the end of 2001				
I99	suspended at the end of 2001				
J00	142 $\pm$ 14	162 $\pm$ 16	192 $\pm$ 19	179 $\pm$ 18	670 $\pm$ 30
J20	146 $\pm$ 15	160 $\pm$ 16	195 $\pm$ 19	180 $\pm$ 18	680 $\pm$ 30
J35	174 $\pm$ 17	185 $\pm$ 19	205 $\pm$ 20	190 $\pm$ 19	750 $\pm$ 40
J70	316 $\pm$ 32	305 $\pm$ 30	309 $\pm$ 31	314 $\pm$ 31	1240 $\pm$ 60
K01	148 $\pm$ 15	180 $\pm$ 18	218 $\pm$ 22	188 $\pm$ 19	730 $\pm$ 40
K02	187 $\pm$ 19	175 $\pm$ 18	200 $\pm$ 20	196 $\pm$ 20	760 $\pm$ 40
L01	134 $\pm$ 13	137 $\pm$ 14	173 $\pm$ 17	160 $\pm$ 16	600 $\pm$ 30
L02	154 $\pm$ 15	230 $\pm$ 23	238 $\pm$ 24	221 $\pm$ 22	840 $\pm$ 40
L03	143 $\pm$ 14	131 $\pm$ 13	145 $\pm$ 14	137 $\pm$ 14	560 $\pm$ 30
L04	171 $\pm$ 17	177 $\pm$ 18	206 $\pm$ 21	195 $\pm$ 19	750 $\pm$ 40
M02	283 $\pm$ 28	243 $\pm$ 24	264 $\pm$ 26	251 $\pm$ 25	1040 $\pm$ 50
N01	128 $\pm$ 13	152 $\pm$ 15	174 $\pm$ 17	173 $\pm$ 17	630 $\pm$ 30
P01	109 $\pm$ 11	114 $\pm$ 11	130 $\pm$ 13	116 $\pm$ 12	470 $\pm$ 20
P03	112 $\pm$ 11	131 $\pm$ 13	157 $\pm$ 16	136 $\pm$ 14	530 $\pm$ 30
X12	430 $\pm$ 43	370 $\pm$ 37	407 $\pm$ 41	384 $\pm$ 38	1590 $\pm$ 80
YTL1	132 $\pm$ 13	136 $\pm$ 14	158 $\pm$ 16	151 $\pm$ 15	580 $\pm$ 30
YTL2	134 $\pm$ 13	129 $\pm$ 13	156 $\pm$ 16	137 $\pm$ 14	560 $\pm$ 30
YTL3	101 $\pm$ 10	93 $\pm$ 9	123 $\pm$ 12	117 $\pm$ 12	430 $\pm$ 20
YTL4	102 $\pm$ 10	86 $\pm$ 9	124 $\pm$ 12	118 $\pm$ 12	430 $\pm$ 20
YTL5	125 $\pm$ 12	150 $\pm$ 15	185 $\pm$ 19	176 $\pm$ 18	640 $\pm$ 30

NA :Data Not Available -- Lost or destroyed TLD for this collection interval.




Figure 4.10: Mean TLD Results

4.06 Milk

Of the 23 samples analysed, K-40 was detected in 12, Cs-137 was detected in three, and H-3 was detected in one. None of these are attributable to the operation of PLGS.

There are no commercial herds or individual cows producing milk in the Point Lepreau area. The closest herds to PLGS are in Oak Bay (60 km to the northwest), Fredericton Junction (70 km to the north), and Hammond River (60 km to the northeast), and the milk from these locations is analysed quarterly. Milk from a commercial dairy is purchased each month from a supermarket in Fredericton. All samples are analysed for gamma emitting radionuclides and tritium.

Since C-14 emissions are low, the expected concentration in milk is below the detection limit. If the C-14 emission rate is more than 1% DEL, a C-14 analysis is performed on milk. This was not the case in 2003. Figure 4.08 shows the weekly C-14 emissions.

Tritium was detected in one of the 23 samples collected ($2.4 \text{ E}+01 \text{ Bq}\cdot\text{L}^{-1}$). This was very near the average Critical Level of $1.3\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$ and is believed to be a statistical "false positive".

Cesium-137 was detected in three samples (range $4.0\text{E}-02$ to $8.6\text{E}-02 \text{ Bq}\cdot\text{L}^{-1}$). The Cs-137 originated from fallout of bomb tests and the Chernobyl accident, and concentrations have been declining ever since. Milk samples analysed between 1977 and 1982, before PLGS began operations, contained an average Cs-137 concentration of $1.2\text{E}+00 \text{ Bq}\cdot\text{L}^{-1}$. The cow preferentially absorbs cesium if there is a dietary deficiency in potassium.

Naturally occurring K-40 (average of $5.0\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$) was also detected in milk.

PLGS emissions of tritium and gamma emitters were too low throughout the year to be detected in these milk samples.

Table 4.07 is a summary of the detected radionuclides in milk.

4.07 Airborne Strontiums (GEM)

When Sr-89,90 emissions are low, the expected concentration in environmental air samples is below the detection limit. The GEM monitors PLGS gaseous emissions continuously at their source. The GEM filters are changed daily and the weekly composite is sent to the lab for analysis. Fifty-two sets of these GEM filters were analysed for Sr-89,90. If the emission rate is more than 1% DEL, or if significant beta activity is detected in environmental air samples, a Sr-89,90 analysis is performed on those samples. Since no Sr-89,90 emissions were detected in 2003, no further analyses were required.

Table 4.07: Milk ($\text{Bq}\cdot\text{L}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	23	1.3E+01	1.1E+01 to 1.4E+01	*	*	*	2.4E+01	1/11	2.4E+01 to 2.4E+01
Cs-137	23	4.7E-02	3.8E-02 to 5.5E-02	6.6E-02	2/12	4.6E-02 to 8.6E-02	4.0E-02	1/11	4.0E-02 to 4.0E-02
K-40	23	2.0E+00	9.7E-02 to 3.5E+00	5.0E+01	12/12	4.6E+01 to 5.4E+01	5.0E+01	11/11	4.8E+01 to 5.2E+01

*The activity is less than or equal to the Critical Level (99% Confidence Level).

4.08 Well Water

Of the 31 samples analysed, K-40 was detected in one, gross alpha was detected in 12, gross beta was detected in 26, and H-3 was detected in 11. Only H-3 is attributable to the operation of PLGS.

Water is collected semi-annually from the 11 locations shown in Figure 3.03. Two of these wells are onsite. The second sample of the year was not collected from A01R due to unavailability. Ten additional wells are sampled once per year. These are located just outside the exclusion boundary and belong to local residents.

The alpha (up to $7.5\text{E-}01 \text{ Bq}\cdot\text{L}^{-1}$) and beta (up to $3.8\text{E-}01 \text{ Bq}\cdot\text{L}^{-1}$) activities are due to the presence of naturally occurring radionuclides peculiar to certain locations. Detected H-3 concentrations ranged from $1.3\text{E+}01$ to $5.6\text{E+}01 \text{ Bq}\cdot\text{L}^{-1}$. Tritium from PLGS emissions washes out into precipitation and subsequently drains into some of the wells. Rainwater analyses (Section 4.14) indicate H-3 concentrations ranging from $1.5\text{E+}01$ to $4.0\text{E+}02 \text{ Bq}\cdot\text{L}^{-1}$ in 33 of 44 samples.

Since C-14 emissions are low, the expected concentration in water is below the detection limit. If the C-14 emission rate is more than 1% DEL, a C-14 analysis is performed on water. This was not the case in 2003. Figure 4.08 shows the weekly C-14 emissions.

Table 4.08 is a summary of the detected radionuclides in well water. Figures 4.11 and 4.12 show the gross beta and H-3 results for each sample. "Less Than" values are plotted for non-detected results. The H-3 measurements were made after samples had been allowed to sit for up to two weeks to reduce radioactive interference from the relatively abundant, but short half-life, radon progeny which are common in most well waters.

The 1996 *Guidelines for Canadian Drinking Water Quality*⁽¹⁴⁾ recommends $7.0\text{E+}03 \text{ Bq}\cdot\text{L}^{-1}$ as the maximum acceptable concentration for H-3 in drinking water. The highest well water H-3 content was less than one percent of the recommended maximum concentration.

Table 4.08: Well Water ($\text{Bq}\cdot\text{L}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
<i>Alpha</i>	31	8.0E-02	2.8E-02 to 2.0E-01	2.0E-01	11/30	3.5E-02 to 7.5E-01	6.3E-02	1/1	6.3E-02 to 6.3E-02
<i>Beta</i>	31	4.5E-02	2.3E-02 to 1.1E-01	1.1E-01	25/30	3.3E-02 to 3.8E-01	8.7E-02	1/1	8.7E-02 to 8.7E-02
<i>H-3</i>	31	1.2E+01	1.1E+01 to 1.4E+01	2.4E+01	11/30	1.3E+01 to 5.6E+01	*	*	*
<i>K-40</i>	31	2.8E+00	1.3E+00 to 3.7E+00	2.0E+00	1/30	2.0E+00 to 2.0E+00	*	*	*

*The activity is less than or equal to the Critical Level (99% Confidence Level).




Figure 4.11: Gross Beta in Well Water




Figure 4.12: Tritium in Well Water

4.09 Pond/Puddle/Surface Water

Tritium was detected in 15 of the 22 samples. No gamma emitters that are attributable to PLGS emissions were detected.

This category includes ponds, lakes, streams, and runoff samples. Most of these samples are from onsite locations. Two important offsite locations, sampled quarterly, are the freshwater supply reservoirs for Saint John and PLGS, at Spruce Lake and Hanson Stream respectively.

Detected H-3 activities ranged from $1.5\text{E}+01$ to $8.9\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$. Variability can be due to the size of the reservoir and the residence time at the location. Tritium from PLGS emissions washes out into precipitation. Rainwater analyses (Section 4.14) indicate H-3 concentrations ranging from $1.5\text{E}+01$ to $4.0\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$ in 33 of 44 samples.

Since C-14 emissions are low, the expected concentration in water is below the detection limit. If the C-14 emission rate is more than 1% DEL, a C-14 analysis is performed on water. This was not the case in 2003. Figure 4.08 shows the weekly C-14 emissions.

Table 4.09 is a summary of the detected radionuclides in surface water. Figure 4.13 shows H-3 results for each location. "Less Than" values are plotted for non-detected results.




Figure 4.13: Tritium in Pond/Puddle/Surface Water

Table 4.09: Pond/Puddle/Surface Water (Bq·L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	22	1.4E+1	1.3E+1 to 1.6E+1	4.2E+1	15/22	1.5E+1 to 8.9E+1	*	*	*

*There is no reference location.

4.10 Berries

Potassium-40 was detected in two of the 5 samples analysed. This is not attributable to the operation of PLGS.

Berries are sampled weekly when in season. Four samples of blueberries were from the commercial fields at Pennfield. One sample of raspberries was from Dipper Harbour.

It is not unusual to detect Cs-137 in berries throughout North America (from fallout of past atmospheric bomb tests), although none was seen this year. As in many food samples, naturally occurring K-40 was detected in two samples ($2.2\text{E}+01$ and $7.3\text{E}+01$ $\text{Bq}\cdot\text{kg}^{-1}$).

Since H-3 and C-14 emissions are low, the expected concentration in berries is below the detection limit. If the H-3 or C-14 emission rates are more than 1% DEL, a H-3 or C-14 analysis is performed on berries. This was not the case in 2003. Figure 4.05 shows the weekly H-3 emissions and Figure 4.08 shows the weekly C-14 emissions.

Table 4.10 is a summary of the detected radionuclides in berries.

4.11 Garden Vegetables

Potassium-40 was detected in 16 of the 19 samples analysed. This is not attributable to the operation of PLGS.

All samples were taken from a local garden in Dipper Harbour (4 km from PLGS in the predominant wind direction). These samples were supplied weekly during the growing season.

As in most food samples, naturally occurring K-40 was detected in 16 samples ($8.3\text{E}+01$ to $2.4\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$).

Since H-3 and C-14 emissions are low, the expected concentration in garden vegetables is below the detection limit. If the H-3 or C-14 emission rates are more than 1% DEL, a H-3 or C-14 analysis is performed on berries. This was not the case in 2003. Figure 4.05 shows the weekly H-3 emissions and Figure 4.08 shows the weekly C-14 emissions.

Table 4.11 is a summary of the detected radionuclides in garden vegetables.

4.12 Vegetation (Lichen)

Of the 15 samples analysed, Be-7 was detected in 14 and K-40 was detected in five. Neither of these is attributable to the operation of PLGS.

These samples are collected whenever and wherever available from onsite locations.

Different species of lichen and moss concentrate a wide range of radionuclides and are sensitive indicators of radionuclides in the environment. Cosmogenically produced Be-7 was detected in 14 samples ($9.4\text{E}+01$ to $6.1\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$) and naturally occurring K-40 was detected in five samples ($1.1\text{E}+02$ to $2.0\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$). It is not unusual to detect Cs-137 in lichen throughout North America, although none was seen this year. In past years, lichen from a now abandoned reference location contained Cs-137 concentrations up to $3.2\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$ (average $6.5\text{E}+01 \text{ Bq}\cdot\text{kg}^{-1}$).

Table 4.12 is a summary of the detected radionuclides in vegetation.

Table 4.10: Berries, Various (Bq·kg⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	5	2.0E+01	1.2E+01 to 2.6E+01	4.8E+01	2/5	2.2E+01 to 7.3E+01	*	*	*

*There is no reference location.

Table 4.11: Garden Vegetables ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	19	7.7E+01	8.3E+00 to 3.7E+02	1.3E+02	16/19	8.3E+01 to 2.4E+02	*	*	*

*There is no reference location.

Table 4.12: Vegetation ($\text{Bq}\cdot\text{kg}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
Be-7	15	6.1E+01	2.8E+01 to 1.2E+02	2.1E+02	14/15	9.4E+01 to 6.1E+02	*	*	*
K-40	15	1.5E+02	4.3E+01 to 3.0E+02	1.7E+02	5/15	1.1E+02 to 2.0E+02	*	*	*

*There is no reference location.

4.13 Soil

Of the 36 samples analysed, Be-7 was detected on eight, Cs-137 was detected on 26, Ac-228 was detected on 28, and K-40 was detected on 36. None of these are attributable to the operation of PLGS.

Soil samples are taken quarterly from the eight air monitoring location sites shown in Figure 3.02 and from the local elementary school. Samples are collected at E02 rather than E01 due to a lack of readily available soil at this site.

Most samples contained naturally occurring K-40 ($1.2\text{E}+02$ to $9.5\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$) and Ac-228 ($2.0\text{E}+01$ to $6.1\text{E}+01$ $\text{Bq}\cdot\text{kg}^{-1}$), and cosmogenically produced Be-7 ($1.9\text{E}+01$ to $6.0\text{E}+01$ $\text{Bq}\cdot\text{kg}^{-1}$). Twenty-six contained Cs-137 ($8.2\text{E}-01$ to $1.6\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$) at typical levels for the region (see Table 4.13). Cesium-137 from fallout of past atmospheric bomb tests tends to accumulate in the organic layer of the soil. Any fluctuation in Cs-137 levels seems to be due to this organic load in the sample.

Table 4.13 is a summary of the detected radionuclides in soil. Figure 4.14 shows individual Cs-137. "Less Than" values are plotted for non-detected results.




Figure 4.14: Cs-137 in Soil

Table 4.13: Soil ($\text{Bq}\cdot\text{kg}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
Be-7	36	1.8E+01	8.5E+00 to 6.9E+01	3.2E+01	6/32	1.9E+01 to 6.0E+01	3.9E+01	2/4	3.7E+01 to 4.1E+01
Cs-137	36	2.0E+00	5.7E-1 to 1.4E+01	2.8E+01	22/32	8.2E-1 to 1.6E+02	3.3E+01	4/4	9.3E+00 to 4.3E+01
Ac-228	36	5.1E+00	8.8E-1 to 2.5E+01	4.1E+01	27/32	2.0E+01 to 6.1E+01	2.8E+01	1/4	2.8E+01 to 2.8E+01
K-40	36	8.9E+01	6.5E+00 to 1.7E+02	5.9E+02	32/32	1.2E+02 to 9.5E+02	4.6E+02	4/4	3.0E+02 to 5.8E+02

Table 4.13: Soil ($\text{Bq}\cdot\text{kg}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
Be-7	36	1.8E+01	8.5E+00 to 6.9E+01	3.2E+01	6/32	1.9E+01 to 6.0E+01	3.9E+01	2/4	3.7E+01 to 4.1E+01
Cs-137	36	2.0E+00	5.7E-1 to 1.4E+01	2.8E+01	22/32	8.2E-1 to 1.6E+02	3.3E+01	4/4	9.3E+00 to 4.3E+01
Ac-228	36	5.1E+00	8.8E-1 to 2.5E+01	4.1E+01	27/32	2.0E+01 to 6.1E+01	2.8E+01	1/4	2.8E+01 to 2.8E+01
K-40	36	8.9E+01	6.5E+00 to 1.7E+02	5.9E+02	32/32	1.2E+02 to 9.5E+02	4.6E+02	4/4	3.0E+02 to 5.8E+02

4.14 Rain Water

Of the 44 samples analysed, Be-7 was detected in five and H-3 was detected in 33. Only H-3 is attributable to the operation of PLGS.

Rain water is collected continuously at the four onsite air monitoring stations (locations shown in Figure 3.02). The samples are changed approximately monthly, depending on rainfall and freeze up.

Detected H-3 levels spanned $1.5\text{E}+01$ to $4.0\text{E}+02$ $\text{Bq}\cdot\text{L}^{-1}$, depending on the amount of rainfall. Cosmogenically produced Be-7 was also detected in five samples ($1.9\text{E}+00$ to $2.4\text{E}+00$ $\text{Bq}\cdot\text{L}^{-1}$).

Since C-14 emissions are low, the expected concentration in water is below the detection limit. If the C-14 emission rate is more than 1% DEL, a C-14 analysis is performed on water. This was not the case in 2003. Figure 4.08 shows the weekly C-14 emissions.

Table 4.14 is a summary of the detected radionuclides in rain water. Figure 4.15 shows individual H-3 results. "Less Than" values are plotted for non-detected results.




Figure 4.15: Tritium in Rain Water

Table 4.14: Rain Water (Bq.L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	44	1.3E+01	1.1E+01 to 1.4E+01	7.7E+01	33/44	1.5E+01 to 4.0E+02	*	*	*
Be-7	44	3.3E+00	8.5E-1 to 5.7E+00	2.2E+00	5/44	1.9E+00 to 2.4E+00	*	*	*

*There is no reference location.

4.15 Monitoring Well Water (Near Plant)

Tritium from PLGS was detected in all 11 samples analysed. No gamma emitters attributable to PLGS emissions were detected.

After evaluating groundwater movement in 2000, eleven new monitoring wells near the plant were drilled. An enhanced monitoring program was established to give a better understanding of groundwater movement. Each well was sampled three times in 2002. At the same time that the samples were taken, physical data were recorded. A report was issued by a geotechnical firm early in 2003, which confirmed previously expected groundwater movement on the peninsula. Based on this report, it was decided to sample these wells once per year. This frequency may be increased for some or all wells if H-3 concentrations greater than $7000 \text{ Bq}\cdot\text{L}^{-1}$ are detected, or if an abnormal release is suspected.

Tritium concentrations averaged $2.3\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$, ranging up to $7.6\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$. The highest concentrations are found close to the stack at locations J02A and J02B. Tritium from PLGS emissions washes out into precipitation and subsequently drains into some of the wells. Rainwater analyses (Section 4.14) indicate H-3 concentrations ranging from $1.5\text{E}+01$ to $4.0\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$ in 33 of 44 samples.

Since C-14 emissions are low, the expected concentration in water is below the detection limit. If the C-14 emission rate is more than 1% DEL, a C-14 analysis is performed on water. This was not the case in 2003. Figure 4.08 shows the weekly C-14 emissions.

Table 4.15 is a summary of the detected radionuclides in monitoring well water. Figure 4.16 shows individual H-3 results. "Less Than" values are plotted for non-detected results.




Figure 4.16: Tritium in Monitoring Well Water

Table 4.15: Monitoring Well Water – Near Plant (Bq·L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	11	1.3E+01	1.3E+01 to 1.4E+01	2.3E+02	11/11	7.3E+01 to 7.6E+02	*	*	*

*There is no reference location.

4.16 Seawater

Potassium-40 was detected in all 15 samples analysed. This is not attributable to the operation of PLGS.

Seawater is collected quarterly from three locations close to PLGS and one reference location near Saint John (shown in Figure 3.05).

Naturally occurring K-40 was detected ($4.2\text{E}+00$ to $1.6\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$) in all 15 samples. It is not unusual to detect H-3 in seawater, although none was seen this year. Calculations suggest that the long term average concentration of tritium in seawater, due to emissions from PLGS in the liquid pathway, would be about $7.0\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$ at the out-fall (samples are not usually collected at this point, but are taken at the shoreline nearby). This calculation takes into account the total tritium released over the year, the flow rate of the condenser cooling water (about $24 \text{ m}^3\cdot\text{s}^{-1}$), and tidal mixing. A dilution factor of 20 is assumed for tidal mixing at the out-fall during normal coolant flows. For collection further away, a tidal mixing factor of about 40, or even higher, is more realistic. A factor of 40 would result in an average H-3 concentration of about $1.0\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$ of seawater in 2003 at the H03 location.

When C-14 and Sr-89,90 emissions are low, the expected concentration in seawater is below the detection limit. If the emission rate is more than 1% DEL, a C-14 or Sr-89,90 analysis is performed on seawater. This was not the case in 2003. Figure 4.18 shows the monthly C-14 emissions and Figure 4.20 shows the Sr-90 emissions. The emission of Sr-89 occurred in one month only and was, therefore, not plotted.

Table 4.16 is a summary of the detected radionuclides in seawater.

4.17 Tritium and Carbon-14 Analyses of Seafood

When H-3 and C-14 emissions are low, the expected concentrations in seafood are below the detection limit. If the emission rate is more than 1% DEL, a H-3 or C-14 analysis is performed on seafood. This was not the case in 2003. Figures 4.17 and 4.18 shows the monthly emissions of these radionuclides.




Figure 4.17: Liquid Tritium Emissions




Figure 4.18: Liquid Carbon-14 Emissions

Table 4.16: Seawater (Bq·L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	15	2.8E+00	9.6E-01 to 6.3E+00	1.0E+01	12/12	6.1E+00 to 1.6E+01	8.0E+00	3/3	4.2E+00 to 1.2E+01

Table 4.16: Seawater ($\text{Bq}\cdot\text{L}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	15	2.8E+00	9.6E-01 to 6.3E+00	1.0E+01	12/12	6.1E+00 to 1.6E+01	8.0E+00	3/3	4.2E+00 to 1.2E+01

4.18 Clams

Potassium-40 was detected in eight of the nine samples analysed. This is not attributable to the operation of PLGS.

These samples are collected whenever and wherever available from the area. The nature of the fishery has changed over the last few years. The inshore fishery often faces restrictions placed upon the harvesting of shellfish, either for conservation of stocks or because of bacterial contamination, algal blooms, or other natural cycles. This restricts the availability of these sample types for analysis. Sample locations are shown in Figure 3.05.

Naturally occurring K-40 concentrations ranged from $1.4\text{E}+02$ to $3.8\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$. See Table 4.17.

4.19 Fish

Potassium-40 was detected in the only sample analysed. This is not attributable to the operation of PLGS.

Only one sample was available for analysis in 2003. The nature of the fishery has changed since the 1980s. Herring and mackerel, which used to make up the bulk of the analyses, are now less available for analysis. The fish category now tends to be made up of dogfish, cod, hake and sardines, if they are available at all.

The naturally occurring K-40 concentration was $1.1\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$. See Table 4.18.

4.20 Lobster

Potassium-40 was detected in all six samples analysed. This is not attributable to the operation of PLGS.

Several of the samples were collected close to the cooling water outflow from PLGS. Sample locations are shown in Figure 3.05. Several lobster are obtained during each of the two federally regulated fishing seasons per year.

Naturally occurring K-40 concentrations ranged from $8.2\text{E}+01$ to $1.1\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$. See Table 4.19.

Table 4.17: Clams, Edible, Raw Mass ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	9	7.9E+01	2.5E+01 to 1.5E+02	2.1E+02	7/8	1.4E+02 to 3.8E+02	2.2E+02	1/1	2.2E+02 to 2.2E+02

Table 4.18: Fish, Various, Edible, Raw Mass ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	1	6.7E+00	6.7E+00 to 6.7E+00	1.1E+02	1/1	1.1E+02 to 1.1E+02	*	*	*

*There is no reference location.

Table 4.19: Lobster, Edible, Cooked Mass ($\text{Bq}\cdot\text{kg}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	6	$2.5\text{E}+01$	$6.7\text{E}+00$ to $5.9\text{E}+01$	$9.4\text{E}+01$	6/6	$8.2\text{E}+01$ to $1.1\text{E}+02$	*	*	*

*There is no reference location.

4.21 Periwinkles

Potassium-40 was detected in 10 of the 11 samples analysed. This is not attributable to the operation of PLGS.

Naturally occurring K-40 concentrations ranged from $8.7\text{E}+01$ to $2.1\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$. See Table 4.20. Sample locations are shown in Figure 3.05.

4.22 Aquaculture Salmon

Potassium-40 was detected in all five of the samples analysed. This is not attributable to the operation of PLGS.

The aquaculture salmon industry is important to the area west of PLGS. Naturally occurring K-40 ranged from $8.3\text{E}+01$ to $1.5\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$. See Table 4.21.

4.23 Scallops

Potassium-40 was detected in both samples analysed. This is not attributable to the operation of PLGS.

The inshore fishery often faces restrictions or total bans placed upon the harvesting of scallops for the conservation of stocks. This affects the number of samples available for analysis. Samples are obtained from Maces Bay or areas distant from the plant.

Naturally occurring K-40 ranged from $1.1\text{E}+02$ to $1.2\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$. See Table 4.22.

4.24 Crab

Potassium-40 was detected in the one sample analysed. This is not attributable to the operation of PLGS.

Most years, there is no active crab fishery in the local area. The only sample available for analysis in 2003 was a Reference sample.

Naturally occurring K-40 was detected in this sample ($2.6\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$). See Table 4.23.

4.25 Dulse

Potassium-40 was detected in the 10 samples analysed. This is not attributable to the operation of PLGS.

Dulse is an edible seaweed that is a popular snack food in the area. Sample locations are shown in Figure 3.05.

Naturally occurring K-40 ranged from $2.8\text{E}+02$ to $1.1\text{E}+03 \text{ Bq}\cdot\text{kg}^{-1}$. See Table 4.24.

4.26 Other Sea Plants

Beryllium-7 was detected in two samples and K-40 was detected in every sample of the 12 samples analysed. This is not attributable to the operation of PLGS.

Sea plants other than dulse are analysed. Various species of seaweed (for example, *Ascophylum*) occur on the rocks on the Point Lepreau peninsula and are collected from time to time. Sample locations are shown in Figure 3.05.

Cosmogenically produced Be-7 ranged from $4.2\text{E}+00$ to $6.3\text{E}+00 \text{ Bq}\cdot\text{kg}^{-1}$. Naturally occurring K-40 ranged from $1.4\text{E}+02$ to $2.7\text{E}+02 \text{ Bq}\cdot\text{kg}^{-1}$. See Table 4.25.

Table 4.20: Periwinkles, Edible, Raw Mass (Bq·kg⁻¹)

<i>Analysis Type</i>	<i>Total Number</i>	<i>Critical Level</i>		<i>Indicator Locations</i>			<i>Reference Locations</i>		
		<i>Mean</i>	<i>Range</i>	<i>Mean</i>	<i>Frequency</i>	<i>Range</i>	<i>Mean</i>	<i>Frequency</i>	<i>Range</i>
K-40	11	5.2E+01	1.5E+01 to 1.1E+02	1.6E+02	10/11	8.7E+01 to 2.1E+02	*	*	*

*There is no reference location.

Table 4.21: Aquaculture Salmon, Raw Mass ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	5	1.9E+01	1.2E+00 to 3.0E+01	1.1E+02	5/5	8.3E+01 to 1.5E+02	*	*	*

*There is no reference location.

Table 4.22: Scallops, Edible, Raw Mass ($\text{Bq}\cdot\text{kg}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	2	3.9E+01	3.6E+01 to 4.1E+01	1.2E+02	2/2	1.1E+02 to 1.2E+02	*	*	*

*There is no reference location.

Table 4.23: Crab, Edible, Cooked Mass ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	1	$3.6E+01$	$3.6E+01$ to $3.6E+01$	*	*	*	$2.6E+02$	1/1	$2.6E+02$ to $2.6E+02$

*There is no indicator location.

Table 4.24: Dulse, Wet Mass ($\text{Bq}\cdot\text{kg}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
K-40	10	9.1E+01	8.8E+00 to 2.3E+02	4.4E+02	10/10	2.8E+02 to 1.1E+03	*	*	*

*There is no reference location.

Table 4.25: Sea Plants, Wet Mass ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
Be-7	12	6.3E+00	3.4E+00 to 1.0E+01	5.3E+00	2/12	4.2E+00 to 6.3E+00	*	*	*
K-40	12	3.9E+01	6.8E+00 to 6.1E+01	2.0E+02	12/12	1.4E+02 to 2.7E+02	*	*	*

*There is no reference location.

4.27 Sediment

Of the 40 samples analysed, Be-7 was detected in 25, Cs-137 was detected in nine, Ac-228 was detected in 34, and K-40 was detected in 40. None of these are attributable to the operation of PLGS.

Sediments are collected quarterly from ten locations shown in Figure 3.05. The finer grains are analysed.

All samples contained K-40 ($3.8\text{E}+02$ to $6.8\text{E}+02$ $\text{Bq}\cdot\text{kg}^{-1}$) from the natural potassium in feldspar, a common mineral. Twenty-five samples contained cosmogenically produced Be-7 ($5.1\text{E}+00$ to $5.4\text{E}+01$ $\text{Bq}\cdot\text{kg}^{-1}$). Thirty-four samples contained Ac-228 ($1.0\text{E}+01$ to $4.5\text{E}+01$ $\text{Bq}\cdot\text{kg}^{-1}$), a radioactive progeny of naturally occurring Th-232. Nine contained Cs-137 ($8.7\text{E}-01$ to $4.0\text{E}+00$ $\text{Bq}\cdot\text{kg}^{-1}$) from the diminishing levels of Cs-137 fallout from bomb tests since the 1960s. Sediment samples analysed between 1977 and 1982, before PLGS began operations, contained an average Cs-137 concentration of $5.0\text{E}+00$ $\text{Bq}\cdot\text{kg}^{-1}$. A small additional Cs-137 component from Chernobyl was added to this reservoir in 1986. Finer grain sediments have a higher radioactivity content than coarse sediments.

Table 4.26 is a summary of the detected radionuclides in sediment. Figure 4.19 shows individual Cs-137 results. "Less Than" values are plotted for non-detected results.




Figure 4.19: Cs-137 in Sediment

Table 4.26: Sediment ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
Be-7	40	8.2E+00	5.1E+00 to 1.3E+01	2.1E+01	21/36	5.1E+00 to 5.4E+01	2.5E+01	4/4	1.3E+01 to 3.8E+01
Cs-137	40	1.0E+00	6.7E-01 to 2.1E+00	2.8E+00	9/36	8.7E-01 to 4.0E+00	*	*	*
Ac-228	40	2.5E+00	6.9E-01 to 4.7E+00	2.6E+01	30/36	1.0E+01 to 4.5E+01	3.0E+01	4/4	2.0E+01 to 3.4E+01
K-40	40	6.3E+01	3.1E+00 to 1.1E+02	4.9E+02	36/36	3.8E+02 to 6.8E+02	4.9E+02	4/4	4.5E+02 to 5.2E+02

*The activity is less than or equal to the Critical Level (99% Confidence Level).

4.28 Gamma Surveys (Beaches)

Environmental gamma survey measurements are made in the intertidal zone on beaches in the Point Lepreau area and at the reference location 28 km to the east-northeast (Figure 3.05). Although TLDs are preferred in measuring such exposures since they span the entire year and provide integrated measurements, they cannot be used in these locations. Instead, beach surveys are performed and grab samples of sediments are analysed. Radiation values measured in 2003 were consistent with those measured prior to station start-up in 1982. These are summarised in Table 4.27.

Table 4.27: Beach Surveys - Intertidal Zone - Ion Chamber ($\mu\text{Sv}\cdot\text{h}^{-1}$)

<i>Location</i>	<i>1st Quarter*</i>	<i>2nd Quarter*</i>	<i>3rd Quarter*</i>	<i>4th Quarter*</i>
B01	0.16	0.13	0.20	0.12
C01	0.21	0.20	0.19	0.09
D01	0.15	0.14	0.14	0.07
D04	0.19	0.13	0.17	0.11
E03	0.20	0.14	0.20	0.13
G01	0.27	0.24	0.25	0.11
H03	0.22	0.23	0.20	0.13
N04	0.19	0.12	0.18	0.08
P02	0.21	0.19	0.19	0.13
Q01R	0.21	0.15	0.20	0.12

*Although two decimal places are quoted, none of the determinations has this degree of precision nor of accuracy. The data are quoted to two figures just as they are estimated from the low level gamma meter at each location. They should be regarded as about 0.1 to 0.2 $\mu\text{Sv}\cdot\text{h}^{-1}$.

Table 4.26: Sediment ($Bq \cdot kg^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
Be-7	40	8.2E+00	5.1E+00 to 1.3E+01	2.1E+01	21/36	5.1E+00 to 5.4E+01	2.5E+01	4/4	1.3E+01 to 3.8E+01
Cs-137	40	1.0E+00	6.7E-01 to 2.1E+00	2.8E+00	9/36	8.7E-01 to 4.0E+00	*	*	*
Ac-228	40	2.5E+00	6.9E-01 to 4.7E+00	2.6E+01	30/36	1.0E+01 to 4.5E+01	3.0E+01	4/4	2.0E+01 to 3.4E+01
K-40	40	6.3E+01	3.1E+00 to 1.1E+02	4.9E+02	36/36	3.8E+02 to 6.8E+02	4.9E+02	4/4	4.5E+02 to 5.2E+02

*The activity is less than or equal to the Critical Level (99% Confidence Level).

4.28 Gamma Surveys (Beaches)

Environmental gamma survey measurements are made in the intertidal zone on beaches in the Point Lepreau area and at the reference location 28 km to the east-northeast (Figure 3.05). Although TLDs are preferred in measuring such exposures since they span the entire year and provide integrated measurements, they cannot be used in these locations. Instead, beach surveys are performed and grab samples of sediments are analysed. Radiation values measured in 2003 were consistent with those measured prior to station start-up in 1982. These are summarised in Table 4.27.

Table 4.27: Beach Surveys - Intertidal Zone - Ion Chamber ($\mu\text{Sv}\cdot\text{h}^{-1}$)

<i>Location</i>	<i>1st Quarter*</i>	<i>2nd Quarter*</i>	<i>3rd Quarter*</i>	<i>4th Quarter*</i>
B01	0.16	0.13	0.20	0.12
C01	0.21	0.20	0.19	0.09
D01	0.15	0.14	0.14	0.07
D04	0.19	0.13	0.17	0.11
E03	0.20	0.14	0.20	0.13
G01	0.27	0.24	0.25	0.11
H03	0.22	0.23	0.20	0.13
N04	0.19	0.12	0.18	0.08
P02	0.21	0.19	0.19	0.13
Q01R	0.21	0.15	0.20	0.12

*Although two decimal places are quoted, none of the determinations has this degree of precision nor of accuracy. The data are quoted to two figures just as they are estimated from the low level gamma meter at each location. They should be regarded as about 0.1 to 0.2 $\mu\text{Sv}\cdot\text{h}^{-1}$.

4.29 Liquid Strontiums (LEM)

When Sr-89,90 emissions are low, the expected concentration in seawater is below the detection limit. The LEM collects samples of PLGS liquid emissions at their source. A monthly composite is sent to the lab for analyses. Thirteen of these composites were analysed for Sr-89,90. If the emission rate is more than 1% DEL, a Sr-89,90 analysis is performed on seawater. Since this was not the case in 2003, no further analyses were required. Figure 4.20 shows the Sr-90 emissions. The release of Sr-89 occurred in one month only and was, therefore, not plotted.




Figure 4.20: Liquid Strontium-90 Emissions

4.30 Bore Hole Water (SRWMF)

Of the 67 samples analysed, Be-7 was detected in one, H-3 was detected in 65, Ac-228 was detected in one, and K-40 was detected in one. Only H-3 is attributable to the operation of PLGS.

In the summer of 2000, a geotechnical firm evaluated the onsite groundwater movement and made recommendations for an improved monitoring program. Based on their advice, nine new bore holes in and around the SRWMF were drilled, bringing the total to 24. An enhanced monitoring program was established to give a better understanding of groundwater movement. Each well was sampled three times in 2002. Physical data were recorded at the same time that the samples were taken. At the end of 2002, these data were given to the hydrogeologists for evaluation. A report was issued by the geotechnical firm early in 2003 which described groundwater movement near the SRWMF.

Tritium concentrations averaged $6.5\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$, ranging up to $2.6\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$. Tritium washes out into precipitation and subsequently drains into some of the bore holes. Rainwater analyses indicate

H-3 concentrations ranging from $1.5\text{E}+01$ to $4.0\text{E}+02$ $\text{Bq}\cdot\text{L}^{-1}$ in 33 of 44 samples (Section 4.14). There was not enough of one of the samples to perform a gamma analysis. See Tables 4.28 and 4.29. Figure 4.21 shows the H-3 activity at each bore hole for each sample. Locations I10A-I10F are the closest to the SRWMF- Phase I structures and may be affected by the higher H-3 levels associated with them. "Less Than" values are plotted for non-detected results.




Figure 4.21: Tritium in Bore Hole Water

Table 4.28: Bore Hole Water, SRWMF - Phase I ($\text{Bq}\cdot\text{L}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	18	1.4E+01	1.3E+01 to 1.6E+01	1.1E+02	18/18	3.6E+01 to 2.6E+02	*	*	*
Be-7	18	1.7E+00	1.2E+00 to 3.4E+00	1.4E+00	1/18	1.4E+00 to 1.4E+00	*	*	*

*There is no reference location.

Table 4.28: Bore Hole Water, SRWMF - Phase 1 (Bq.L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	18	1.4E+01	1.3E+01 to 1.6E+01	1.1E+02	18/18	3.6E+01 to 2.6E+02	*	*	*
Be-7	18	1.7E+00	1.2E+00 to 3.4E+00	1.4E+00	1/18	1.4E+00 to 1.4E+00	*	*	*

*There is no reference location.

Table 4.29: Bore Hole Water, SRWMF - Phase 2 (Bq·L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	49	1.4E+01	1.3E+01 to 1.6E+01	4.9E+01	47/49	1.5E+01 to 2.1E+02	*	*	*
Ac-228	48	6.6E-1	3.9E-1 to 9.7E-1	1.8E+00	1/48	1.8E+00 to 1.8E+00	*	*	*
K-40	48	2.8E+00	1.6E+00 to 3.5E+00	3.6E+00	1/48	3.6E+00 to 3.6E+00	*	*	*

*There is no reference location.

4.31 Parshall Flume Water (SRWMF)

Of the 103 samples analysed, Be-7 was detected in one, H-3 was detected in 102, and K-40 was detected in one. Only H-3 is attributable to the operation of PLGS.

Rainwater and snow melt at the SRWMF (Phases 1 and 2) are obtained from drainage channels (flumes) constructed to collect surface runoff from these areas. Samples are collected and analysed on a weekly basis.

There is little or no flow into or out of these collection locations during the winter months and values for H-3 tend to vary little from one week to the next except after heavy rain. The average value at Phase 2 is $5.8\text{E}+01 \text{ Bq}\cdot\text{L}^{-1}$, much less than the $9.7\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$ at Phase 1. The Phase 1 results are due to H-3 vapour escaping from the structures and condensing onto surfaces. Tables 4.30 and 4.31 are summaries of the detected radionuclides in the flumes. Figure 4.17 compares the H-3 in the samples from the two facilities. "Less Than" values are plotted for non-detected results.

Cosmogenically produced Be-7 was detected in one sample ($1.5\text{E}+00 \text{ Bq}\cdot\text{L}^{-1}$). Naturally occurring K-40 was detected in another sample ($2.6\text{E}+00 \text{ Bq}\cdot\text{L}^{-1}$).




Figure 4.22: Tritium in Parshall Flume Water

Table 4.30: Parshall Flume Water, SRWMF - Phase 1 ($\text{Bq}\cdot\text{L}^{-1}$)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	51	1.3E+01	1.1E+01 to 1.6E+01	9.7E+02	51/51	3.6E+01 to 5.3E+03	*	*	*
Be-7	51	1.7E+00	1.1E+00 to 2.7E+00	1.5E+00	1/51	1.5E+00 to 1.5E+00	*	*	*

*There is no reference location.

Table 4.31: Parshall Flume Water, SRWMF - Phase 2 (Bq·L⁻¹)

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	52	1.3E+01	1.1E+01 to 1.5E+01	5.8E+01	51/52	1.4E+01 to 5.9E+02	*	*	*
K-40	52	2.9E+00	1.7E+00 to 5.0E+00	2.6E+00	1/52	2.6E+00 to 2.6E+00	*	*	*

*There is no reference location.

4.32 Drop-off TLDs (SRWMF - Phase 2)

The measured radiation decreases as the distance from the SRWMF - Phase 2 increases.

Ambient gamma radiation is measured by TLDs placed at 17 locations in two directions from the boundary fence of Phase 2. These measure decreasing levels of radiation with distance from the filled dry fuel storage canisters, to a distance of about 100 metres. TLDs are changed quarterly

Results are presented in Table 4.32.

There were 106 concrete canisters filled to the end of 2003 with 57 240 used-fuel bundles. Radiation "drop-off" measurements (Figure 4.23) with increasing distance from the fence show distinct differences. The "A" direction consists mostly of swamp after 20 m from the fence and extends to the northeast away from the perimeter fence. The "B" direction consists mostly of rock with some shallow sandy overburden and extends to the northwest away from the perimeter (after 75 m the TLDs are shielded from the facility by high ground). The "B" TLDs are closer to freshly filled canisters than "A" TLDs.

The TLD locations furthest from the facility in the "B" direction (B9 and B10) were discontinued in 2001. They are hazardous for personnel to access. Since they are shielded from the facility by high ground, they provided limited, useful information.

Table 4.32: TLD, Drop-off (μGy)

Location	Dose ($\mu\text{Gy} \pm 10\%$)				
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	Year
A 5m	165 $\pm$ 16	210 $\pm$ 21	307 $\pm$ 31	273 $\pm$ 27	960 $\pm$ 50
A 10m	166 $\pm$ 17	181 $\pm$ 18	286 $\pm$ 29	257 $\pm$ 26	890 $\pm$ 50
A 15m	132 $\pm$ 13	165 $\pm$ 16	240 $\pm$ 24	199 $\pm$ 20	740 $\pm$ 40
A 20m	106 $\pm$ 11	112 $\pm$ 11	186 $\pm$ 19	153 $\pm$ 15	560 $\pm$ 30
A 25m	99 $\pm$ 10	102 $\pm$ 10	160 $\pm$ 16	134 $\pm$ 13	490 $\pm$ 30
A 50m	91 $\pm$ 9	89 $\pm$ 9	126 $\pm$ 13	101 $\pm$ 10	410 $\pm$ 20
A 75m	90 $\pm$ 9	89 $\pm$ 9	132 $\pm$ 13	107 $\pm$ 11	420 $\pm$ 20
A 100m	95 $\pm$ 10	88 $\pm$ 9	125 $\pm$ 12	106 $\pm$ 11	410 $\pm$ 20
A 118m	79 $\pm$ 8	74 $\pm$ 7	108 $\pm$ 11	93 $\pm$ 9	350 $\pm$ 20
B 5m	209 $\pm$ 21	255 $\pm$ 26	342 $\pm$ 34	290 $\pm$ 29	1100 $\pm$ 60
B 10m	234 $\pm$ 23	277 $\pm$ 28	323 $\pm$ 32	300 $\pm$ 30	1130 $\pm$ 60
B 15m	160 $\pm$ 16	217 $\pm$ 22	280 $\pm$ 28	238 $\pm$ 24	890 $\pm$ 50
B 20m	120 $\pm$ 12	168 $\pm$ 17	224 $\pm$ 22	186 $\pm$ 19	700 $\pm$ 40
B 25m	135 $\pm$ 14	190 $\pm$ 19	252 $\pm$ 25	202 $\pm$ 20	780 $\pm$ 40
B 50m	133 $\pm$ 13	144 $\pm$ 14	207 $\pm$ 21	184 $\pm$ 18	670 $\pm$ 30
B 75m	131 $\pm$ 13	144 $\pm$ 14	200 $\pm$ 20	184 $\pm$ 18	660 $\pm$ 30
B 100m	174 $\pm$ 17	168 $\pm$ 17	240 $\pm$ 24	193 $\pm$ 19	780 $\pm$ 40
B 150m	suspended at the end of 2001				
B 200m	suspended at the end of 2001				

4.32 Drop-off TLDs (SRWMF - Phase 2)

The measured radiation decreases as the distance from the SRWMF - Phase 2 increases.

Ambient gamma radiation is measured by TLDs placed at 17 locations in two directions from the boundary fence of Phase 2. These measure decreasing levels of radiation with distance from the filled dry fuel storage canisters, to a distance of about 100 metres. TLDs are changed quarterly

Results are presented in Table 4.32.

There were 106 concrete canisters filled to the end of 2003 with 57 240 used-fuel bundles. Radiation "drop-off" measurements (Figure 4.23) with increasing distance from the fence show distinct differences. The "A" direction consists mostly of swamp after 20 m from the fence and extends to the northeast away from the perimeter fence. The "B" direction consists mostly of rock with some shallow sandy overburden and extends to the northwest away from the perimeter (after 75 m the TLDs are shielded from the facility by high ground). The "B" TLDs are closer to freshly filled canisters than "A" TLDs.

The TLD locations furthest from the facility in the "B" direction (B9 and B10) were discontinued in 2001. They are hazardous for personnel to access. Since they are shielded from the facility by high ground, they provided limited, useful information.

Table 4.32: TLD, Drop-off (μGy)

Location	Dose ($\mu\text{Gy} \pm 10\%$)				Year
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	
A 5m	165 $\pm$ 16	210 $\pm$ 21	307 $\pm$ 31	273 $\pm$ 27	960 $\pm$ 50
A 10m	166 $\pm$ 17	181 $\pm$ 18	286 $\pm$ 29	257 $\pm$ 26	890 $\pm$ 50
A 15m	132 $\pm$ 13	165 $\pm$ 16	240 $\pm$ 24	199 $\pm$ 20	740 $\pm$ 40
A 20m	106 $\pm$ 11	112 $\pm$ 11	186 $\pm$ 19	153 $\pm$ 15	560 $\pm$ 30
A 25m	99 $\pm$ 10	102 $\pm$ 10	160 $\pm$ 16	134 $\pm$ 13	490 $\pm$ 30
A 50m	91 $\pm$ 9	89 $\pm$ 9	126 $\pm$ 13	101 $\pm$ 10	410 $\pm$ 20
A 75m	90 $\pm$ 9	89 $\pm$ 9	132 $\pm$ 13	107 $\pm$ 11	420 $\pm$ 20
A 100m	95 $\pm$ 10	88 $\pm$ 9	125 $\pm$ 12	106 $\pm$ 11	410 $\pm$ 20
A 118m	79 $\pm$ 8	74 $\pm$ 7	108 $\pm$ 11	93 $\pm$ 9	350 $\pm$ 20
B 5m	209 $\pm$ 21	255 $\pm$ 26	342 $\pm$ 34	290 $\pm$ 29	1100 $\pm$ 60
B 10m	234 $\pm$ 23	277 $\pm$ 28	323 $\pm$ 32	300 $\pm$ 30	1130 $\pm$ 60
B 15m	160 $\pm$ 16	217 $\pm$ 22	280 $\pm$ 28	238 $\pm$ 24	890 $\pm$ 50
B 20m	120 $\pm$ 12	168 $\pm$ 17	224 $\pm$ 22	186 $\pm$ 19	700 $\pm$ 40
B 25m	135 $\pm$ 14	190 $\pm$ 19	252 $\pm$ 25	202 $\pm$ 20	780 $\pm$ 40
B 50m	133 $\pm$ 13	144 $\pm$ 14	207 $\pm$ 21	184 $\pm$ 18	670 $\pm$ 30
B 75m	131 $\pm$ 13	144 $\pm$ 14	200 $\pm$ 20	184 $\pm$ 18	660 $\pm$ 30
B 100m	174 $\pm$ 17	168 $\pm$ 17	240 $\pm$ 24	193 $\pm$ 19	780 $\pm$ 40
B 150m	suspended at the end of 2001				
B 200m	suspended at the end of 2001				




Figure 4.23: Drop-off TLDs

4.33 Hemlock Knoll Regional Sanitary Landfill

In December 1999, PLGS began disposing of its non-active waste at the public landfill facility. A monitoring program was established prior to the first shipment. It includes sampling of water from the leachate, monitoring wells and various holding ponds, and dosimeter placement at key locations.

There were 48 water samples and 20 TLD results. Tritium was detected in 12 of the 48 water samples (mean of $1.9\text{E}+02 \text{ Bq}\cdot\text{L}^{-1}$). Table 4.33 summarises the water sample results. There were no radionuclides detected other than naturally occurring isotopes that are not reported here. TLD results appear in Table 4.06 (location codes YTL1 to YTL5).

In 2001, the leachate from Crane Mountain Regional Sanitary Landfill was analysed and found to have H-3 levels similar to those at Hemlock Knoll. PLGS does not ship waste to that facility. The source of H-3 in both of these landfills is suspected to be H-3 in commercial and consumer devices (e.g., H-3 powered "Exit" signs).

Soil and gamma surveys from the disposal cell were discontinued in 2001. Since fresh soil was used to cover the cell, no useful information was obtained.

Table 4.33: Liquid ($\text{Bq}\cdot\text{L}^{-1}$), Hemlock Knoll Regional Sanitary Landfill

Analysis Type	Total Number	Critical Level		Indicator Locations			Reference Locations		
		Mean	Range	Mean	Frequency	Range	Mean	Frequency	Range
H-3	48	6.2E+01	5.8E+01 to 7.0E+01	1.9E+02	12/48	6.0E+01 to 5.0E+02	*	*	*

*There is no reference location.

4.34 Meteorological Data

A problem was discovered in the meteorological data for the years 1992 to 2000: the temperature reading from the 42-metre elevation (at the Point Lepreau Generating Station tower) contained a bias that affected the calculation of the Pasquill Stability factor. This does not effect the program. The meteorological data for 2003, and a compilation of the available 1986 to 2003 data, have this information removed and are presented in Tables 4.34 and 4.35. Data were collected hourly. Wind Rose data for 2003 are presented in Figure 4.24 and a pie-plot of the average percentage frequency of Pasquill stability classes for the years from 1986 to 1991 in the Point Lepreau area is presented in Figure 4.25.

Table 4.34: Meteorological Data for Point Lepreau (2003)

Month	Temperature (Degrees Celsius) 10 Metre Tower Data					Wind Direction* (Relative %) 42 Metre Tower Data							
	Avg	Mean Daily		Extreme		%Observations from							
		Max	Min	Max	Min	N	NE	E	SE	S	SW	W	NW
January	-8.5	-4.8	-12.7	6.5	-22.1	18	7	6	12	14	18	11	13
February	-6.6	-1.9	-10.8	7.0	-24.7	17	18	12	10	7	13	12	11
March	-3.6	0.7	-8.6	5.3	-18.9	15	11	24	14	9	11	4	11
April	3.6	7.0	0.2	17.6	-10.5	8	9	18	9	19	21	9	7
May	7.7	11.0	4.9	20.2	-1.0	7	9	11	17	18	16	14	8
June	12.6	17.4	9.2	24.5	5.8	8	10	20	29	10	12	6	6
July	14.5	18.7	11.7	28.8	10.3	4	4	31	22	6	22	1	10
August	17.0	20.5	14.3	25.1	12.6	2	13	22	37	16	5	0	3
September	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
October	7.6	10.0	4.5	16.2	0.5	13	8	11	14	17	19	12	6
November	4.9	8.2	1.6	14.9	-6.0	24	17	8	10	11	13	10	7
December	-2.8	0.7	-6.7	9.9	-14.3	16	10	6	11	18	19	10	10
Annual	Mean 2.5	Mean 6.4	Mean -1.1	Extreme 28.8	Extreme -24.7	13	11	14	15	13	16	9	9
Years	1	1	1	1	1	1	1	1	1	1	1	1	1

*Each compass direction covers ± 22.5 degrees.

NA: Data was not available.

Table 4.35: Meteorological Data for Point Lepreau (average 1986 to 1991)

Month	Temperature (Degrees Celsius)				Wind Direction* Relative % Observation From								Relative % Pasquill Stability Classes							% UNAV	
	Avg	Mean Daily		Extreme	N	NE	E	SE	S	SW	W	NW	A	B	C	D	E	F	G		
		Max	Min	Max																	Min
January	-4.9	-0.8	-8.9	7.2	-25.3	11	10	4	5	10	19	18	23	19	9	8	26	22	12	5	3
February	-5.4	-1.8	-9.4	7.3	-21.9	16	8	3	4	11	22	15	23	22	11	11	23	19	9	5	1
March	-1.5	1.5	-4.7	13.5	-24.9	19	13	4	5	15	17	9	19	16	8	8	25	25	12	7	2
April	3.3	5.9	1.1	16.4	-4.2	20	25	6	6	17	13	8	5	12	5	7	25	33	12	6	15
May	7.9	11.2	5.5	25.6	-0.7	13	19	6	6	22	22	7	5	8	4	6	21	32	17	13	18
June	11.4	14.6	9.0	26.1	4.1	8	17	7	6	20	23	12	8	4	2	3	16	36	23	16	14
July	14.4	17.3	12.0	25.2	6.9	5	12	5	7	25	31	10	6	2	1	2	11	31	27	27	9
August	14.8	17.5	12.7	25.0	8.3	6	10	5	8	23	27	14	8	2	1	1	9	29	33	26	7
September	12.0	14.4	9.9	26.3	1.1	8	9	4	6	20	24	16	14	5	2	3	18	34	25	13	6
October	8.4	10.7	6.1	18.9	-1.7	13	10	7	9	19	18	14	11	5	4	5	27	30	17	12	3
November	2.8	5.7	-0.2	14.5	-13.7	13	9	4	7	11	13	22	23	9	5	8	34	25	15	4	1
December	-4.0	-0.1	-8.0	11.1	-21.1	13	6	5	3	7	13	25	28	18	11	11	27	21	9	3	5
Period	Mean 4.9	Mean 8.1	Mean 2.2	Mean 26.3	Extreme -25.3	12	12	5	6	17	20	14	15	10	5	6	22	28	18	11	7
Years	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6

42 Metre Tower data

*Each wind direction covers ± 22.5 degrees

Table 4.35: Meteorological Data for Point Lepreau (average 1986 to 1991)

Month	Temperature (Degrees Celsius)				Wind Direction* Relative % Observation From								Relative % Pasquill Stability Classes						% UNAV		
	Mean Daily		Extreme	Avg	N	NE	E	SE	S	SW	W	NW	A	B	C	D	E	F		G	
	Max	Min																			
January	-4.9	-0.8	-8.9	7.2	-25.3	11	10	4	5	10	19	18	23	19	9	8	26	22	12	5	3
February	-5.4	-1.8	-9.4	7.3	-21.9	16	8	3	4	11	22	15	23	22	11	11	23	19	9	5	1
March	-1.5	1.5	-4.7	13.5	-24.9	19	13	4	5	15	17	9	19	16	8	8	25	25	12	7	2
April	3.3	5.9	1.1	16.4	-4.2	20	25	6	6	17	13	8	5	12	5	7	25	33	12	6	15
May	7.9	11.2	5.5	25.6	-0.7	13	19	6	6	22	22	7	5	8	4	6	21	32	17	13	18
June	11.4	14.6	9.0	26.1	4.1	8	17	7	6	20	23	12	8	4	2	3	16	36	23	16	14
July	14.4	17.3	12.0	25.2	6.9	5	12	5	7	25	31	10	6	2	1	2	11	31	27	27	9
August	14.8	17.5	12.7	25.0	8.3	6	10	5	8	23	27	14	8	2	1	1	9	29	33	26	7
September	12.0	14.4	9.9	26.3	1.1	8	9	4	6	20	24	16	14	5	2	3	18	34	25	13	6
October	8.4	10.7	6.1	18.9	-1.7	13	10	7	9	19	18	14	11	5	4	5	27	30	17	12	3
November	2.8	5.7	-0.2	14.5	-13.7	13	9	4	7	11	13	22	23	9	5	8	34	25	15	4	1
December	-4.0	-0.1	-8.0	11.1	-21.1	13	6	5	3	7	13	25	28	18	11	11	27	21	9	3	5
Period	Mean 4.9	Mean 8.1	Mean 2.2	Extreme 26.3	Extreme -25.3	12	12	5	6	17	20	14	15	10	5	6	22	28	18	11	7
Years	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6

42 Metre Tower data

*Each wind direction covers ± 22.5 degrees




Figure 4.24: Wind Rose for Point Lepreau (2003)




Figure 4.25: Pasquill Stability Factors for Point Lepreau (1986 to 1991)

5 Trends

The following trends were observed in the historical data:

- decreasing dose to members of the Critical Groups due to decreasing emissions since 1995 (Figure 5.01 and 5.06).
- decreasing concentration of tritium in water vapour (onsite locations) since 1994 (Figure 5.09).
- decreasing concentration of tritium in monitoring wells (near plant) since 2001 (Figure 5.17).
- increasing concentration of tritium in Parshall Flume water from the Solid Radioactive Waste Management Facility (SRWMF) Phase 1 (Figure 5.29). However, it continues to be below the peak concentrations observed in 1999 and 2000.

As in the figures in Section 4, "Less Than" values are plotted for non-detected values. All location codes are described in Appendix C.

5.01 Dose from Airborne and Liquid Pathways

Radiation dose from PLGS emissions continues to be well below the public dose limit (1000 microsieverts per annum), and also well below the design and operating target for PLGS (50 microsieverts per annum). Since 1995, there has been a decreasing trend in emissions (See Figure 5.01).




Figure 5.01: Dose from Airborne and Liquid Pathways

5.02 Gross Beta in Air

Figures 5.02 and 5.03 show the gross beta data for all air stations since the NB Power program began in 1976. A plot of the gross beta data from Dipper Harbour, about 4 km from the PLGS stack in the predominant downwind direction, is presented in Figure 5.04. The baseline data show the naturally occurring radioactivity in the area. The peaks on the plots correspond to fallout from various atmospheric bomb tests that were most common in the 1950s and 1960s but decreased into the 1970s. Fallout from the Chinese atmospheric bomb test in October of 1980 which impacted N.B. in 1981, and from the Chernobyl accident in April 1986, was detected. Figure 5.05 shows a comparable plot of data from Health and Welfare Canada, but for the whole of Canada from 1959 (when data were first collected) to 1991. The scale is condensed to allow the bomb test fallout levels to be kept on-scale.

In a period of a few days, the Chernobyl accident released about 1% as much radioactivity to the environment as all of the U.S. atmospheric bomb tests combined.




Figure 5.02: Gross Beta in Air (Offsite Air Stations)




Figure 5.03: Gross Beta in Air (Onsite Air Stations)




Figure 5.04: Gross Beta Activity in Air at Dipper Harbour




Figure 5.05: Annual Average Gross Beta Activity in Air for Canada 1959 to 1991 (Health and Welfare Canada Data)

5.03 Tritiated Water in Air

Station airborne tritium emissions have declined since their peak in 1993 (Figure 5.06). The onsite stations show a similar decline (Figures 5.07 and 5.09) in airborne H-3 concentration but still continue to be higher than the offsite locations (Figure 5.08). This is due to increasing dilution with distance from the emissions stack.




Figure 5.06: Gaseous Tritium Emissions




Figure 5.07: Gaseous Tritium Emissions and Water Vapour (Tritium) Results




Figure 5.08: Water Vapour (Tritium) for Offsite Air Stations




Figure 5.09: Water Vapour (Tritium) for Onsite Air Stations

5.04 Atmospheric Dispersion Factors

The annual average dispersion factor for stack emissions since 1984 is between $1\text{E-}07$ and $2\text{E-}07 \text{ s}\cdot\text{m}^{-3}$. This factor is based upon the data for H-3. A value of $2\text{E-}07$, based on such empirical data, is used in the DEL calculations. Results since 1984 are presented in Table 5.02.

The average recorded mean dispersion factor at each location, is now the average of the detected values and the "Less Than" values. This calculation will give a conservative estimate of the true value (i.e., less dispersion of the radionuclides).

Each dispersion factor value is corrected to one kilometre to derive a normalised mean dispersion factor at one kilometre from the stack for all locations. This is accomplished by tracing back between dispersion curves on the graph of "Weighted Mean Dilution Factor versus Distance from the Point of Continuous Emission"⁽¹⁵⁾. The average of these normalised values is presented in Table 5.01.

Table 5.01: Normalised Mean Dispersion Factor at 1 km for All Indicator Locations

<i>Year</i>	<i>Dispersion Factor (s·m⁻³)</i>
1984	2E-07
1985	1E-07
1986	1E-07
1987	1E-07
1988	2E-07
1989	2E-07
1990	1E-07
1991	1E-07
1992	1E-07
1993	1E-07
1994	1E-07
1995	2E-07
1996	2E-07
1997	2E-07
1998	2E-07
1999	2E-07
2000	2E-07
2001	2E-07
2002	2E-07
2003	2E-07
Average over 20 years	<2E-07

Table 5.02: Average Atmospheric Dispersion Factor for Each Air Monitoring Location

Location Code	E01	F01	G02	H04	I01	K02	L04	N01
Location	Maces	Welch	Lepreau	Old Site of	SRWMF	CCW	Construction	Dipper
Distance from PLGS	4.5 km	1.6 km	1.0 km	0.75 km	1.2 km		0.55 km	3.7 km
Year	Emission(Bq)	Dispersion Factor ($s \cdot m^{-3}$)						
1984	6.80E+13	8E-08	8E-08	2E-07	5E-07	7E-7**	5E-07	8E-08
1985	1.10E+14	2E-08	4E-08	9E-08	3E-07	2E-07	3E-07	5E-08
1986	2.00E+14	3E-08	5E-08	1E-07	3E-07	2E-07	5E-07	6E-08
1987	2.20E+14	2E-08	2E-08	1E-07	2E-07	2E-07	3E-07	7E-08
1988	2.20E+14	3E-08	7E-08	1E-07	4E-07	3E-07	#	9E-08
1989	2.10E+14	2E-08	4E-08	8E-08	4E-07	3E-07	#	8E-08
1990	2.50E+14	2E-08	3E-08	8E-08	3E-07	2E-07	#	8E-08
1991	1.70E+14	2E-08	3E-08	5E-08	3E-07	3E-07	#	7E-08
1992	3.60E+14	2E-08	5E-08	5E-08	2E-07	2E-07	#	4E-08
1993	6.40E+14	2E-08	5E-08	6E-08	4E-07	2E-07	#	5E-08
1994	5.60E+14	2E-08	3E-08	5E-08	5E-07	2E-07	#	1E-07
1995	3.10E+14	2E-08	5E-08	2E-07	3E-07	3E-07	#	4E-08
1996	2.40E+14	2E-08	5E-08	9E-08	5E-07	3E-07	#	8E-08
1997	2.10E+14	3E-08	5E-08	1E-07	4E-07	4E-07	#	9E-08
1998	1.30E+14	2E-08	3E-08	1E-07	3E-07	4E-07	#	5E-08
1999	9.50E+13	7E-08	5E-08	1E-07	5E-07	5E-07	#	1E-07
2000	1.30E+14	2E-08	3E-08	2E-07	5E-07	5E-07	#	8E-08
2001	1.30E+14	9E-08	5E-08	1E-07	4E-07	4E-07	#	2E-07
2002	1.30E+14	2E-08	7E-08	1E-07	3E-07	4E-07	#	5E-08
2003	1.00E+14	7E-08	2E-07	2E-07	2E-07	2E-07	#	8E-08

**This value includes a second source term: H-3 from containers temporarily located in this facility in 1984 and picked up by the air sampler (ignored in the calculation of the normalised mean dispersion factor).

No longer in use. This monitoring station was relocated to L04 - the Construction Stores Compound - in the spring of 1988.

5.05 Carbon-14 in Air

Station airborne C-14 emissions have declined since their peak in 1992 (Figure 5.10). Based on current stack emissions, the calculated average annual concentration of C-14 in air at the boundary fence is less than $2\text{E-}03\text{ Bq}\cdot\text{m}^{-3}$ (well below the natural level of $4\text{E-}02\text{ Bq}\cdot\text{m}^{-3}$). Only natural levels are detected at the air stations.




Figure 5.10: Gaseous Carbon-14 Emissions




Figure 5.11: Gaseous C-14 Emissions and C-14 for Onsite Air Stations

5.06 TLD Measurements

A plot of summary TLD data since 1977 is presented in Figure 5.12. There is only one reference location (A01R in Bocabec) while the other groups are the average of many locations. *Boundary* refers to locations at the edge of NB Power property.

The variation in natural background radiation at any individual location covers a range of about 300 microgray from year to year. A few locations (close to the reactor building and the air emissions stack) show significant, but small, increases in gamma radiation due to chronic emissions of low levels of noble gases. In 1995, the extended outage resulted in fewer noble gas emissions and thus lower dose measured by these TLDs. Small increases at the SRWMF are due to low-level waste and used fuel emplacement and not to station emissions.

Background radiation in any of the monitored residential areas has not increased from the levels measured before the Point Lepreau Generating Station was placed into operation.




Figure 5.12: TLD Measurements

5.07 Strontium-90 in Air (GEM)

There have only been a few years when Sr-90 was detected in station effluents. The maximum values for Sr-90 still represent only a small fraction of the DEL and are due to activity detected just above the detection limit.




Figure 5.13: Sr-90 in Air (GEM)

5.08 Gross Beta in Well Water

The beta activity in well water is due to the presence of naturally occurring radionuclides, especially radon progeny. As expected, there has been no significant change in this parameter over the years.

The value plotted for each year in Figure 5.14 is the mean of all values for that year. "Less Than" values are plotted for non-detected values.




Figure 5.14: Gross Beta in Well Water

5.09 Tritium in Well Water

Precipitation and surface water contain H-3 from PLGS emissions. Even though there is surface runoff into some shallow wells, there has been no significant change in this parameter over the years.

The value plotted for each year in Figure 5.15 is the mean of all values for that year. "Less Than" values are plotted for non-detected values.




Figure 5.15: Tritium in Well Water

5.10 Cs-137 in Soil

Cesium-137 from the fallout of past atmospheric bomb tests tends to accumulate in the organic layer of soil. Any fluctuation in Cs-137 levels seems to be due to this organic load in the sample. There were no soil samples collected from 1986 to 1992 because, at the time, this fluctuation caused soil to be viewed as an unimportant sample type.

The value plotted for each year in Figure 5.16 is the mean of all values for that year. "Less Than" values are plotted for non-detected values.




Figure 5.16: Cs-137 in Soil

5.11 Tritium in Monitoring Well Water (Near Plant)

The concentration of H-3 in monitoring wells (near plant) has been decreasing since 2001 (Figure 5.17).




Figure 5.17: H-3 in Monitoring Well Water (near plant)




Figure 5.18: H-3 in Monitoring Well Water (near plant)

5.12 Tritium and C-14 in Seawater

Tritium and C-14 emissions to seawater have been lower in recent years than they were at their peak in 1996 and 1997 (Figures 5.19 and 5.20).

Tritium concentrations in seawater increased in 1996 and 1997 due to samples being taken directly over the out-fall. In other years, these samples are usually taken at the shore, where the effects of tidal mixing are evident. The value plotted for each year in Figure 5.15 is the mean of all values for that year. "Less Than" values are plotted for non-detected values.

Since C-14 emissions are low, the expected concentration in seawater is below the detection limit. If the emission rate is more than 1% DEL, a C-14 analysis is performed on seawater. Since this has never happened, no further analyses were required.




Figure 5.19: Liquid Tritium Emissions




Figure 5.20: Liquid C-14 Emissions




Figure 5.21: Tritium in Seawater

5.13 Cs-137 in Sediment

The effects of the atmospheric bomb tests and the accident at Chernobyl continue to be seen in the Cs-137 load in the soil. There has been no significant change in this level over the years.

The value plotted for each year in Figure 5.22 is the mean of all values for that year. "Less Than" values are plotted for non-detected values.




Figure 5.22: Cs-137 in Sediment

5.14 Strontium-90 in LEM

The maximum values for Sr-90 still represent only a small fraction of the DEL and are due to activity detected just above the detection limit.




Figure 5.23: Sr-90 in LEM

5.15 Tritium in Bore Hole Water

In the summer of 2000, a geotechnical firm evaluated the onsite groundwater movement and made recommendations for an improved monitoring program. Based on their advice, nine new bore holes in and around the SRWMF (two older ones were retired) were drilled, bringing the total number of bore holes to 24. There has been a general upward trend in the Phase 1 H-3 results since the late 1980s. That trend was reversed in 2001 (Figures 5.24 to 5.28)




Figure 5.24: H-3 in Bore Hole Water




Figure 5.25: H-3 in Bore Hole Water




Figure 5.26: H-3 in Bore Hole Water




Figure 5.27: H-3 in Bore Hole Water




Figure 5.28: H-3 in Bore Hole Water

5.16 Tritium in Parshall Flume Water

The H-3 values at Phase 2 are typically less than those at Phase 1. The Phase 1 results are due to H-3 vapour escaping from the structures and condensing onto surfaces. There has been a general upward trend in the Phase 1 Parshall Flume H-3 results since the late 1980s. This trend was reversed in 2001 and concentrations continue to be below those observed in 1999 and 2000.




Figure 5.29: H-3 in Parshall Flume Water

5.17 Drop-off TLDs

Dosimeters are situated northeast ("A") and northwest ("B") from the boundary fence of the SRWMF - Phase 2 facility to a distance of about 100 m. These measure the decrease in radiation levels from the filled dry fuel storage canisters with distance. Results are presented in Figure 5.30. Each point on the graph is the average of all of the results collected since the facility has operated. The "B" direction shows higher radiation levels than the "A" direction because the mostly rocky terrain found in this direction has a higher natural background. The pattern of filling the canisters with spent fuel affects the reading on the first few TLDs in the "B" direction. In recent years, these TLDs have shown higher levels of radiation than the "A" TLDs because they are closer to full canisters. This trend has started to change as a new row of canisters, closer to the "A" TLDs, is currently being filled.

The bar charts in Figure 5.31 and Figure 5.32 present the annual dose for each location (since 1991).




Figure 5.30: Drop-off TLDs




Figure 5.31: Drop-off TLDs




Figure 5.32: Drop-off TLDs

6 Dose Estimation

Based upon the total percent DEL for all monitored radionuclides in each pathway for 2003, the calculated annual whole body radiation dose to members of the Critical Groups was about $0.06 \mu\text{Sv}$ from liquid emissions and about $0.27 \mu\text{Sv}$ from airborne emissions. This latter calculation allows for the actual location of an existing dairy herd in 2003 at about 40 km, rather than assuming the existence of a hypothetical herd at 1.5 km. The result is a reduction in dose factor of about 12 for C-14 in the milk pathway because of the differences in dispersion factors between 1.5 km and 40 km ($6\text{E-}08 \text{ s}\cdot\text{m}^{-3}$, and $5\text{E-}09 \text{ s}\cdot\text{m}^{-3}$, respectively).

Because of the protective assumptions used in the DEL calculations, and the relatively low level of emissions, the most exposed member of the general public received far less than the calculated dose of $0.33 \mu\text{Sv}$. This radiation dose may be compared with the individual natural radiation dose in the Point Lepreau area of approximately 2000 to 3000 μSv per annum. (TLDs show only the external, penetrating component, amounting to about 500 to 1000 μSv .) This includes natural dose contributions from ground, air, food and from an assumed low concentration of radon in homes. A significant fraction of Canadian homes contain radon levels that give a much larger radiation dose than the 2000 μSv quoted in the table. In addition, the average annual medical radiation dose is about 350 μSv per person.

Table 6.01: Annual Dose

<i>Source of Dose to Critical Group</i>	<i>Dose to Critical Group ($\mu\text{Sv/a}$)</i>
PLGS airborne emissions	0.27
PLGS liquid emissions	0.06
natural background (estimate)	2 000
average medical dose (estimate)	350

The only assessable radiation dose from PLGS to the local population is that from tritiated water vapour in air. This continues to be detected offsite in air and water samples.

7 Quality Assurance Results

The purpose of Quality Assurance is to provide confidence in the program and demonstrate that the program is able to meet its objectives. QA is a system whereby the laboratory can assure the regulator, NB Power, and the public that the laboratory is generating data of proven and known quality. It encompasses:

- personnel
- procedures
- measurements
- contamination
- records
- annual review
- program audits
- program improvement

This section describes how QA was achieved for the year 2003. The specific procedures can be found in the *Quality Assurance* section of *Environmental Radiation Monitoring Program Procedures*⁽¹⁶⁾.

7.01 Quality Control Checks

The four main pieces of analytical equipment used in the OERMP have a quality control (QC) check performed daily. Key instrument parameters are checked and the results are compared against tolerance limits, and are also compared with previous results to detect trends in performance. To perform the quality control checks, radiation sources traceable to US or Canadian standards (National Institute of Standards and Technology and National Research Council) are used. Failures are investigated immediately.

The QC evaluations in the laboratory cover the following instruments:

1. Canberra Intrinsic Ge Gamma Spectrometer
2. Beckman Liquid Scintillation Counter
3. Tennelec LB-5100 Gross Alpha/Beta Detector
4. Panasonic UD-710A TLD Reader

The operating parameters of each of the major instruments are evaluated at the start of each working day. (A background count is made each weekend to ensure the absence of contamination in the gamma spectrometer sample chamber.) This ensures that the parameters are consistent and remain free from significant drift or random variation that could influence the analyses. A compilation of the results and statistical fluctuations is maintained, and from these data the upper and lower flag

limits are determined. If any equipment exceeds these limits, it is not used for analytical work until the problem has been resolved.

Throughout the year there were failures for each of the instruments. These failures involved only one of the seven to ten parameters monitored for each system. All of these failures were minor and were resolved on the same day they occurred.

Table 7.01: QC Passes & Failures

<i>Instrument</i>	<i>Number of Parameters Monitored Per Check</i>	<i>Number of Checks</i>	<i>Number of Individual Parameters Tested</i>	<i>Number of Individual Parameters Failed</i>	<i>Unresolved Failures</i>
Canberra Intrinsic Ge Gamma Spectrometer	6	244	1464	5	0
Canberra Intrinsic Ge Gamma Spectrometer (Weekend Long Background)	8	50	400	2	0
Beckman Liquid Scintillation Counter	10	259	2590	11	0
Tennelec LB-5100 Gross Alpha/Beta Detector	8	254	2032	23	0
Panasonic UD-710A TLD Reader	8	284	2272	16	0

7.01.01 Intrinsic Ge Gamma Spectrometer

A daily check of seven system parameters is performed for the germanium gamma spectroscopy system. Measurements are made of the energy centroids, full width half maxima (FWHM) and efficiencies of two widely separated photon energies of Eu-152. These show the accuracy and precision of the system relative to the defined limits of acceptance. The rate of liquid nitrogen consumption is monitored to verify the physical integrity of the cryostat (this parameter is not reflected in the numbers in Table 7.01). A computer program that generates QC plots and performs statistical tests to detect out-of-range values, processes the results. A 200 000 s background count is made each weekend to ensure the absence of contamination in the sample chamber. The QC program evaluates the total counts in eight separate regions of the background spectrum, and out-of-range values are flagged for assessment.

The efficiency calibration of the gamma spectroscopy system is checked annually for each of the counting geometries. This is accomplished using a mixed nuclide standard traceable to the U.S. National Institute of Standards and Technology (NIST).

7.01.02 Beckman Liquid Scintillation Counter (model LS 6000TA)

A set of sealed tritium, C-14 and background standards traceable to NIST is analysed daily. Statistical parameters must lie within defined limits or the equipment will not be used. These same standards are used to calibrate the instrument for each analysis run.

7.01.03 Tennelec LB-5100 Gross Alpha/Beta Detector

Planchet standards of Am-241 and Sr-Y-90 are analysed daily. Alpha and Beta discrimination allows the simultaneous analysis of alpha and beta emissions on all samples analysed. Planchet and filter backgrounds are included in the QC checks. These same standards are used to calibrate the instrument for each analysis run.

7.01.04 Panasonic UD-710A TLD Reader

A set of 16 TLDs is exposed in the Panarad Irradiator and read out in the TLD reader. The mean of each of the four elements, dark current, reference light, reference element, and lamp flashes must all be within specified limits. The QA aspect of this system is covered in detail in *External Beta/Gamma Dosimetry Program*⁽¹⁷⁾.

7.01.05 Other Instruments

Other instruments (balances, pipettes) are checked or calibrated at least annually. See the *Calibration, Maintenance and Repair* section of *Environmental Radiation Monitoring Program Procedures*⁽¹⁶⁾. Frequencies of calibration are based on reproducibility of measurements and on time stability tests to ensure that the measurements are within the specified tolerances for accuracy.

The gamma survey meters and contamination monitor are calibrated at PLGS on an annual basis.

7.02 External QA

The external quality assurance program consists of inter-comparisons with other laboratories to give independent verification of analytical performance. The frequency of each program may vary at the discretion of the sponsoring agency (see Table 7.02). Five such groups – United States Department of Energy (USDOE), CANDU Owners Group (COG), Analytics, Radiation Protection Bureau of Health Canada (RPB) and the National Research Council (NRC) provide up to 10% of the sample load in the laboratory with blind or semi-blind samples. Results of our performance with these samples give an indication of the quality of measurements the laboratory is capable of producing.

The number of External QA samples analysed was reduced from the previous year (151 samples in 2002 to 112 samples in 2003). Lab resources could not sustain the higher numbers.

The results are tabulated by radionuclide in Tables 7.03 and presented graphically in Figures 7.01 to 7.19. The same results are tabulated by medium in Tables 7.04 to 7.11. The tables show the sample date, while the figures show the analysis date.

The QA agent defines acceptable performance, generally in terms of an expected range. A failure signals the need to assess the procedures, analytical methods, or equipment calibrations.

There were 3 failures out of 202 tests on 112 samples in the external QA program:

- Sr-90 on Air Filter (Analytics) – There was one random failure.
- C-14 in Water (COG) – There was one random failure.
- Co-60 in Vegetation/Food (USDOE) – There was one failure due to a geometry difference between the calibration standard and QA sample.

Table 7.02: External Quality Assurance Frequency

<i>Media</i>	<i>Analyses</i>	<i>Number of QA Samples</i>	<i>External Agencies</i>
Filters	Gross Alpha/Beta	2	USDOE
		2	Analytics
	Gamma	2	USDOE
		2	Analytics
	Sr-89,90	2	USDOE
		2	Analytics
Charcoal Cartridges	Gamma	4	Analytics
Environmental Gamma	TLD	10	NRC
		no test in 2003	USDOE
Milk	Gamma	4	Analytics
Water	Gross Alpha/Beta	2	USDOE
		1	COG
		1	Analytics
	H-3	4	COG
	C-14	4	COG
	Gamma	2	USDOE
		2	COG
	Sr-89,90	2	USDOE
		2	Analytics
Food/Vegetation	Gamma	2	USDOE
		2	Analytics
Soil/Sediment	Gamma	2	USDOE
		2	Analytics
Urine	H-3	30	RPB
	C-14	20	RPB
	Gamma	4	RPB

Table 7.03: Radionuclide Performance (External QA)

<i>Analysis</i>	<i>Table No.</i>	<i>Sample Date</i>	<i>NB Power/Agent</i>	<i>All Participants</i>
ALPHA (Figure 7.01)	7.04	2003-06-12	0.96	
	7.04	2003-12-11	0.91	
	7.04	2003-03-01	0.99	0.67 - 1.38
	7.04	2003-09-01	1.03	0.86 - 1.13
	7.08	2003-12-11	0.95	
	7.08	2003-03-01	0.90	0.63 - 1.26
	7.08	2003-09-01	1.17	0.77 - 1.04
BETA (Figure 7.02)	7.04	2003-06-12	0.88	
	7.04	2003-12-11	0.99	
	7.04	2003-03-01	0.99	0.94 - 1.01
	7.04	2003-09-01	1.00	0.92 - 1.19
	7.04	2003-03-01	1.07	0.87 - 1.25
	7.04	2003-09-01	1.07	0.88 - 1.09
	7.08	2003-12-11	1.25	
	7.08	2003-03-01	1.02	0.77 - 1.35
	7.08	2003-09-01	0.92	0.85 - 1.05
Ba-133 (Figure 7.16)	7.11	2003-09-04	0.98	0.86 - 1.03
C-14 (Figure 7.03)	7.08	2003-03-01	1.15	1.00 - 1.15
	7.08	2003-03-01	1.00	0.92 - 1.00
	7.08	2003-09-01	0.78	0.69 - 1.09
	7.08	2003-09-01	0.80 Fail	0.79 - 1.05
	7.11	2003-10-08	0.96	0.95 - 1.08
	7.11	2003-10-08	0.95	0.94 - 1.08
	7.11	2003-10-08	0.87	0.88 - 1.06
Cd-109 (Figure 7.16)	7.08	2003-03-01	0.96	0.93 - 1.08
	7.08	2003-09-01	1.01	0.92 - 1.06
Ce-139 (Figure 7.16)	7.08	2003-03-01	1.02	0.98 - 1.03
	7.08	2003-09-01	1.00	0.95 - 1.09

Table 7.03 (continued): Radionuclide Performance (External QA)

Analysis	Table No.	Sample Date	NB Power/Agent	All Participants
Ce-141 (Figure 7.04)	7.04	2003-06-12	1.03	
	7.04	2003-12-11	0.94	
	7.07	2003-03-20	0.99	
	7.07	2003-06-12	0.98	
	7.07	2003-09-18	1.03	
	7.07	2003-12-11	0.93	
	7.08	2003-06-12	1.02	
	7.08	2003-12-11	1.05	
	7.09	2003-06-12	1.11	
	7.09	2003-12-11	1.16	
	7.10	2003-06-12	0.82	
	7.10	2003-12-11	0.91	
Co-57 (Figure 7.17)	7.08	2003-03-01	0.98	0.96 - 1.04
	7.08	2003-09-01	1.03	0.95 - 1.09
Co-58 (Figure 7.05)	7.04	2003-06-12	1.12	
	7.04	2003-12-11	1.08	
	7.07	2003-03-20	1.07	
	7.07	2003-06-12	0.99	
	7.07	2003-09-18	1.05	
	7.07	2003-12-11	1.02	
	7.08	2003-06-12	1.05	
	7.08	2003-12-11	1.00	
	7.09	2003-06-12	1.04	
	7.09	2003-12-11	1.11	
	7.10	2003-06-12	0.91	
	7.10	2003-12-11	0.88	

Table 7.03 (continued): Radionuclide Performance (External QA)

Analysis	Table No.	Sample Date	NB Power/Agent	All Participants
Co-60 (Figure 7.06)	7.04	2003-06-12	1.06	
	7.04	2003-12-11	1.05	
	7.04	2003-03-01	0.96	0.89 - 1.16
	7.04	2003-09-01	0.95	0.95 - 1.10
	7.07	2003-03-20	1.00	
	7.07	2003-06-12	1.03	
	7.07	2003-09-18	1.10	
	7.07	2003-12-11	0.97	
	7.08	2003-06-12	1.02	
	7.08	2003-12-11	0.94	
	7.08	2003-03-01	0.98	0.95 - 1.02
	7.08	2003-09-01	1.00	0.94 - 1.06
	7.08	2003-03-01	0.92	0.91 - 1.08
	7.08	2003-09-01	0.91	0.93 - 1.02
	7.09	2003-06-12	1.16	
	7.09	2003-12-11	1.09	
	7.09	2003-03-01	1.45 Fail	0.85 - 1.35
	7.10	2003-06-12	0.77	
	7.10	2003-12-11	0.83	
Cr-51 (Figure 7.07)	7.04	2003-06-12	1.16	
	7.04	2003-12-11	1.12	
	7.07	2003-03-20	1.13	
	7.07	2003-06-12	1.09	
	7.07	2003-09-18	1.07	
	7.07	2003-12-11	1.06	
	7.08	2003-06-12	1.17	
	7.08	2003-12-11	1.05	
	7.09	2003-06-12	1.11	
	7.09	2003-12-11	1.19	
	7.10	2003-06-12	1.09	
	7.10	2003-12-11	0.92	

Table 7.03 (continued): Radionuclide Performance (External QA)

<i>Analysis</i>	<i>Table No.</i>	<i>Sample Date</i>	<i>NB Power/Agent</i>	<i>All Participants</i>
Cs-134 (Figure 7.08)	7.04	2003-06-12	1.10	
	7.04	2003-12-11	0.96	
	7.07	2003-03-20	0.95	
	7.07	2003-06-12	1.13	
	7.07	2003-09-18	0.98	
	7.07	2003-12-11	0.97	
	7.08	2003-06-12	0.87	
	7.08	2003-12-11	1.06	
	7.08	2003-03-01	0.96	0.82 - 1.06
	7.08	2003-09-01	1.02	0.88 - 0.99
	7.09	2003-06-12	1.14	
	7.09	2003-12-11	1.02	
	7.10	2003-06-12	0.94	
	7.10	2003-12-11	0.82	
Cs-137 (Figure 7.09)	7.04	2003-06-12	1.05	
	7.04	2003-12-11	1.05	
	7.04	2003-03-01	1.00	0.89 - 1.22
	7.04	2003-09-01	1.02	0.98 - 1.14
	7.07	2003-03-20	0.94	
	7.07	2003-06-12	0.96	
	7.07	2003-09-18	1.03	
	7.07	2003-12-11	0.95	
	7.08	2003-06-12	1.02	
	7.08	2003-12-11	0.98	
	7.08	2003-03-01	0.94	0.95 - 1.02
	7.08	2003-09-01	0.97	0.95 - 1.05
	7.08	2003-03-01	0.94	0.89 - 1.09
	7.08	2003-09-01	0.97	0.95 - 1.06
	7.09	2003-06-12	1.13	
	7.09	2003-12-11	1.10	
	7.09	2003-03-01	1.21	0.89 - 1.28
	7.10	2003-06-12	0.86	
	7.10	2003-12-11	0.87	
	7.10	2003-03-01	0.93	0.88 - 1.16
	7.10	2003-09-01	0.80	0.91 - 1.08
	7.11	2003-09-04	0.88	0.87 - 1.08

Table 7.03 (continued): Radionuclide Performance (External QA)

<i>Analysis</i>	<i>Table No.</i>	<i>Sample Date</i>	<i>NB Power/Agent</i>	<i>All Participants</i>
Fe-59 (Figure 7.10)	7.04	2003-06-12	1.09	
	7.04	2003-12-11	1.19	
	7.07	2003-03-20	1.06	
	7.07	2003-06-12	1.05	
	7.07	2003-09-18	1.06	
	7.07	2003-12-11	1.09	
	7.08	2003-06-12	1.06	
	7.08	2003-12-11	1.04	
	7.09	2003-06-12	1.01	
	7.09	2003-12-11	1.19	
	7.10	2003-06-12	0.84	
	7.10	2003-12-11	0.91	
Gamma (Figure 7.17)	7.06	2003-05-23	0.95	
	7.06	2003-11-04	0.88	
H-3 (Figure 7.11)	7.08	2003-03-01	0.97	0.98 - 1.05
	7.08	2003-03-01	0.96	0.93 - 1.05
	7.08	2003-09-01	0.92	0.84 - 1.20
	7.08	2003-09-01	0.95	0.93 - 1.06
	7.08	2003-03-01	0.92	0.86 - 1.21
	7.08	2003-09-01	0.99	0.90 - 1.28
	7.11	2003-04-15	0.90	0.87 - 1.11
	7.11	2003-04-15	0.91	0.84 - 1.13
Hg-203 (Figure 7.17)	7.08	2003-03-01	0.98	0.96 - 1.01
	7.08	2003-09-01	1.01	0.97 - 1.09
I-131 (Figure 7.12)	7.05	2003-03-20	0.89	
	7.05	2003-06-12	1.04	
	7.05	2003-09-18	0.90	
	7.05	2003-12-11	0.94	
	7.07	2003-03-20	1.08	
	7.07	2003-06-12	1.15	
	7.07	2003-09-18	1.08	
	7.07	2003-12-11	1.14	
	7.08	2003-06-12	1.33	
	7.08	2003-12-11	1.14	

Table 7.03 (continued): Radionuclide Performance (External QA)

Analysis	Table No.	Sample Date	NB Power/Agent	All Participants
K-40 (Figure 7.18)	7.09	2003-03-01	1.31	0.88 - 1.28
	7.10	2003-03-01	1.01	0.86 - 1.20
	7.10	2003-09-01	0.86	0.91 - 1.12
Mn-54 (Figure 7.13)	7.04	2003-06-12	1.20	
	7.04	2003-12-11	1.18	
	7.04	2003-03-01	1.08	0.87 - 1.23
	7.04	2003-09-01	1.09	0.98 - 1.15
	7.07	2003-03-20	1.05	
	7.07	2003-06-12	1.05	
	7.07	2003-09-18	1.12	
	7.07	2003-12-11	1.00	
	7.08	2003-06-12	1.01	
	7.08	2003-12-11	1.01	
	7.09	2003-06-12	1.09	
	7.09	2003-12-11	1.07	
	7.10	2003-06-12	0.94	
	7.10	2003-12-11	0.94	
Sn-113 (Figure 7.18)	7.08	2003-03-01	1.04	0.93 - 1.01
	7.08	2003-09-01	1.07	0.93 - 1.11
Sr-85 (Figure 7.18)	7.08	2003-03-01	1.01	0.95 - 1.03
	7.08	2003-09-01	1.04	0.94 - 1.06
Sr-89 (Figure 7.19)	7.04	2003-06-12	0.86	
	7.04	2003-12-11	0.85	
	7.08	2003-06-12	0.91	
	7.08	2003-12-11	0.88	

Table 7.03 (continued): Radionuclide Performance (External QA)

<i>Analysis</i>	<i>Table No.</i>	<i>Sample Date</i>	<i>NB Power/Agent</i>	<i>All Participants</i>
Sr-90 (Figure 7.14)	7.04	2003-06-12	0.65 Fail	
	7.04	2003-12-11	0.93	
	7.04	2003-03-01	0.81	0.73 - 1.15
	7.04	2003-09-01	0.86	0.77 - 1.04
	7.08	2003-06-12	0.88	
	7.08	2003-12-11	0.89	
	7.08	2003-09-01	0.89	0.82 - 0.99
Y-88 (Figure 7.19)	7.08	2003-03-01	0.98	0.94 - 1.02
	7.08	2003-09-01	1.01	0.94 - 1.05
Zn-65 (Figure 7.15)	7.04	2003-06-12	1.24	
	7.04	2003-12-11	1.13	
	7.07	2003-03-20	1.02	
	7.07	2003-06-12	1.10	
	7.07	2003-09-18	1.09	
	7.07	2003-12-11	0.98	
	7.08	2003-06-12	1.00	
	7.08	2003-12-11	0.90	
	7.09	2003-06-12	1.06	
	7.09	2003-12-11	1.21	
	7.10	2003-06-12	0.86	
	7.10	2003-12-11	1.02	

Table 7.04: Filter Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·filter ⁻¹ ± 2 sigma)	NB Power (Bq·filter ⁻¹ ± 2 sigma)	NB Power/ QA Agent (ratio)
ALPHA	2003-06-12	1.04 ± 0.04	0.995 ± 0.065	0.96
	2003-12-11	0.629 ± 0.037	0.570 ± 0.031	0.91
	2003-03-01	1.17 ± 0.12	1.16 ± 0.05	0.99
	2003-09-01	3.11 ± 0.61	3.19 ± 0.11	1.03
BETA	2003-06-12	5.81 ± 0.19	5.11 ± 0.19	0.88
	2003-12-11	1.74 ± 0.07	1.71 ± 0.06	0.99
	2003-03-01	7.10 ± 1.77	7.06 ± 0.20	0.99
	2003-09-01	7.40 ± 1.79	7.40 ± 0.21	1.00
	2003-03-01	1.50 ± 0.15	1.61 ± 0.06	1.07
	2003-09-01	3.89 ± 0.76	4.17 ± 0.13	1.07
Ce-141	2003-06-12	7.44 ± 0.26	7.70 ± 0.48	1.03
	2003-12-11	4.26 ± 0.15	4.00 ± 0.27	0.94
Co-58	2003-06-12	2.44 ± 0.07	2.73 ± 0.24	1.12
	2003-12-11	2.33 ± 0.07	2.52 ± 0.22	1.08
Co-60	2003-06-12	3.48 ± 0.11	3.69 ± 0.23	1.06
	2003-12-11	3.26 ± 0.11	3.41 ± 0.21	1.05
	2003-03-01	33.5 ± 0.9	32.3 ± 1.4	0.96
	2003-09-01	55.1 ± 2.2	52.3 ± 2.2	0.95
Cr-51	2003-06-12	6.29 ± 0.22	7.33 ± 0.84	1.16
	2003-12-11	5.88 ± 0.19	6.59 ± 0.70	1.12
Cs-134	2003-06-12	2.70 ± 0.07	2.98 ± 0.40	1.10
	2003-12-11	2.85 ± 0.11	2.75 ± 0.32	0.96
Cs-137	2003-06-12	6.07 ± 0.19	6.36 ± 0.43	1.05
	2003-12-11	2.70 ± 0.07	2.85 ± 0.23	1.05
	2003-03-01	99.7 ± 2.3	100 ± 6	1.00
	2003-09-01	54.8 ± 2.2	56.1 ± 3.3	1.02
Fe-59	2003-06-12	2.59 ± 0.07	2.83 ± 0.40	1.09
	2003-12-11	2.15 ± 0.07	2.55 ± 0.36	1.19
Mn-54	2003-06-12	4.88 ± 0.15	5.85 ± 0.41	1.20
	2003-12-11	3.63 ± 0.11	4.29 ± 0.32	1.18
	2003-03-01	43.8 ± 1.1	47.2 ± 2.8	1.08
	2003-09-01	58.0 ± 2.6	63.3 ± 3.7	1.09
Sr-89	2003-06-12	3.44 ± 0.11	2.97 ± 0.15	0.86
	2003-12-11	3.18 ± 0.11	2.71 ± 0.14	0.85
Sr-90	2003-06-12	0.962 ± 0.037	0.625 ± 0.048	0.65 Fail
	2003-12-11	0.333 ± 0.000	0.309 ± 0.031	0.93
	2003-03-01	2.80 ± 0.14	2.28 ± 0.06	0.81
	2003-09-01	2.06 ± 0.14	1.77 ± 0.05	0.86
Zn-65	2003-06-12	4.77 ± 0.15	5.92 ± 0.54	1.24
	2003-12-11	4.14 ± 0.15	4.70 ± 0.46	1.13

Table 7.05: Charcoal Cartridge Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·cartridge ⁻¹ ± 2 sigma)	NB Power (Bq·cartridge ⁻¹ ± 2 sigma)	NB Power/QA Agent (ratio)
I-131	2003-03-20	2.74 ± 0.89	2.42 ± 0.31	0.89
	2003-06-12	2.26 ± 0.07	2.35 ± 0.30	1.04
	2003-09-18	3.15 ± 0.11	2.85 ± 0.33	0.90
	2003-12-11	2.81 ± 0.11	2.65 ± 0.32	0.94

Table 7.06: Environmental TLD Performance (External QA)

Analysis	Sample Date	QA Agent (mR ± 2 sigma)	NB Power (mR ± 2 sigma)	NB Power/QA Agent (ratio)
GAMMA	2003-05-23	159 ± 2	151 ± 13	0.95
	2003-11-04	151 ± 2	133 ± 10	0.88

Table 7.07: Milk Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·L ⁻¹ ± 2 sigma)	NB Power (Bq·L ⁻¹ ± 2 sigma)	NB Power/ QA Agent (ratio)
Ce-141	2003-03-20	6.40 ± 2.09	6.36 ± 0.43	0.99
	2003-06-12	10.5 ± 0.3	10.2 ± 0.7	0.98
	2003-09-18	3.18 ± 0.11	3.29 ± 0.24	1.03
	2003-12-11	7.47 ± 0.26	6.96 ± 0.46	0.93
Co-58	2003-03-20	1.74 ± 0.57	1.86 ± 0.16	1.07
	2003-06-12	3.44 ± 0.11	3.39 ± 0.26	0.99
	2003-09-18	3.66 ± 0.11	3.85 ± 0.28	1.05
	2003-12-11	4.11 ± 0.15	4.18 ± 0.30	1.02
Co-60	2003-03-20	5.99 ± 1.96	5.99 ± 0.31	1.00
	2003-06-12	4.88 ± 0.15	5.03 ± 0.26	1.03
	2003-09-18	4.55 ± 0.15	5.00 ± 0.26	1.10
	2003-12-11	5.74 ± 0.19	5.55 ± 0.28	0.97
Cr-51	2003-03-20	9.10 ± 2.97	10.3 ± 0.9	1.13
	2003-06-12	8.84 ± 0.30	9.66 ± 0.99	1.09
	2003-09-18	8.62 ± 0.30	9.21 ± 0.87	1.07
	2003-12-11	10.4 ± 0.3	11.0 ± 1.0	1.06
Cs-134	2003-03-20	3.33 ± 1.09	3.16 ± 0.38	0.95
	2003-06-12	3.81 ± 0.11	4.29 ± 0.50	1.13
	2003-09-18	4.40 ± 0.15	4.33 ± 0.37	0.98
	2003-12-11	5.00 ± 0.19	4.85 ± 0.48	0.97
Cs-137	2003-03-20	7.40 ± 2.42	6.96 ± 0.47	0.94
	2003-06-12	8.51 ± 0.30	8.14 ± 0.54	0.96
	2003-09-18	3.26 ± 0.11	3.37 ± 0.25	1.03
	2003-12-11	4.77 ± 0.15	4.55 ± 0.32	0.95
Fe-59	2003-03-20	1.74 ± 0.57	1.84 ± 0.25	1.06
	2003-06-12	3.66 ± 0.11	3.85 ± 0.39	1.05
	2003-09-18	2.92 ± 0.11	3.09 ± 0.32	1.06
	2003-12-11	3.77 ± 0.11	4.11 ± 0.38	1.09
I-131	2003-03-20	2.74 ± 0.89	2.95 ± 0.29	1.08
	2003-06-12	3.81 ± 0.11	4.37 ± 0.43	1.15
	2003-09-18	2.74 ± 0.07	2.96 ± 0.25	1.08
	2003-12-11	3.33 ± 0.11	3.81 ± 0.64	1.14
Mn-54	2003-03-20	2.37 ± 0.77	2.49 ± 0.20	1.05
	2003-06-12	6.88 ± 0.22	7.25 ± 0.49	1.05
	2003-09-18	3.44 ± 0.11	3.85 ± 0.28	1.12
	2003-12-11	6.40 ± 0.22	6.40 ± 0.44	1.00
Zn-65	2003-03-20	3.44 ± 1.12	3.50 ± 0.33	1.02
	2003-06-12	6.70 ± 0.22	7.40 ± 0.56	1.10
	2003-09-18	6.51 ± 0.22	7.07 ± 0.54	1.09
	2003-12-11	7.29 ± 0.26	7.14 ± 0.54	0.98

Table 7.08: Water Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·L ⁻¹ ± 2 sigma) or (Bq·kg ⁻¹ ± 2 sigma)	NB Power (Bq·L ⁻¹ ± 2 sigma) or (Bq·kg ⁻¹ ± 2 sigma)	NB Power/ QA Agent (ratio)
ALPHA	2003-12-11	1.89 ± 0.07	1.79 ± 0.12	0.95
	2003-03-01	378 ± 10	338 ± 28	0.90
	2003-09-01	622 ± 122	727 ± 51	1.17
BETA	2003-12-11	5.22 ± 0.19	6.51 ± 0.29	1.25
	2003-03-01	628 ± 10	641 ± 39	1.02
	2003-09-01	1950 ± 380	1800 ± 90	0.92
C-14	2003-03-01	118000 ± 18000	136000 ± 3000	1.15
	2003-03-01	7.5E+6 ± 1.1E+6	7.6E+6 ± 1.9E+5	1.00
	2003-09-01	57400 ± 12800	44800 ± 1200	0.78
	2003-09-01	8.1E+6 ± 1.6E+6	6.5E+6 ± 1.6E+5	0.80 Fail
Cd-109	2003-03-01	1.7E+6 ± 2.6E+5	1.7E+6 ± 9.8E+4	0.96
	2003-09-01	1.7E+6 ± 2.0E+5	1.7E+6 ± 1.1E+5	1.01
Ce-139	2003-03-01	89500 ± 13300	91300 ± 5400	1.02
	2003-09-01	86600 ± 7500	86600 ± 5100	1.00
Ce-141	2003-06-12	9.36 ± 0.30	9.58 ± 0.85	1.02
	2003-12-11	6.99 ± 0.22	7.36 ± 0.69	1.05
Co-57	2003-03-01	69600 ± 10400	68200 ± 4000	0.98
	2003-09-01	69200 ± 6500	71400 ± 4200	1.03
Co-58	2003-06-12	3.07 ± 0.11	3.21 ± 0.48	1.05
	2003-12-11	3.85 ± 0.11	3.85 ± 0.51	1.00
Co-60	2003-06-12	4.37 ± 0.15	4.44 ± 0.44	1.02
	2003-12-11	5.37 ± 0.19	5.03 ± 0.48	0.94
	2003-03-01	343000 ± 51000	335000 ± 14000	0.98
	2003-09-01	340000 ± 25000	340000 ± 14000	1.00
	2003-03-01	234 ± 8	216 ± 11	0.92
	2003-09-01	513 ± 35	468 ± 22	0.91
Cr-51	2003-06-12	7.88 ± 0.26	9.25 ± 2.15	1.17
	2003-12-11	9.69 ± 0.33	10.2 ± 2.1	1.05
Cs-134	2003-06-12	3.40 ± 0.11	2.95 ± 0.46	0.87
	2003-12-11	4.70 ± 0.15	5.00 ± 0.58	1.06
	2003-03-01	30.5 ± 1.1	29.2 ± 2.5	0.96
	2003-09-01	63.0 ± 3.9	64.3 ± 7.3	1.02
Cs-137	2003-06-12	7.62 ± 0.26	7.77 ± 0.75	1.02
	2003-12-11	4.48 ± 0.15	4.37 ± 0.53	0.98
	2003-03-01	286000 ± 43000	269000 ± 16000	0.94
	2003-09-01	286000 ± 20000	278000 ± 16000	0.97
	2003-03-01	63.8 ± 3.4	60.0 ± 4.5	0.94
	2003-09-01	80.3 ± 8.0	77.6 ± 5.7	0.97

Table 7.08 (continued): Water Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·L ⁻¹ ± 2 sigma) or (Bq·kg ⁻¹ ± 2 sigma)	NB Power (Bq·L ⁻¹ ± 2 sigma) or (Bq·kg ⁻¹ ± 2 sigma)	NB Power/ QA Agent (ratio)
Fe-59	2003-06-12	3.26 ± 0.11	3.46 ± 0.77	1.06
	2003-12-11	3.55 ± 0.11	3.69 ± 0.91	1.04
H-3	2003-03-01	104000 ± 16000	101000 ± 3000	0.97
	2003-03-01	7.3E+6 ± 1.1E+6	7.1E+6 ± 1.7E+5	0.96
	2003-09-01	116000 ± 34000	107000 ± 3000	0.92
	2003-09-01	7.1E+6 ± 6.1E+5	6.8E+6 ± 1.7E+5	0.95
	2003-03-01	390 ± 3	360 ± 13	0.92
	2003-09-01	446 ± 4	441 ± 15	0.99
	2003-09-01	446 ± 4	441 ± 15	0.99
Hg-203	2003-03-01	229000 ± 34000	224000 ± 13000	0.98
	2003-09-01	236000 ± 26000	239000 ± 14000	1.01
I-131	2003-06-12	3.00 ± 0.11	4.00 ± 0.69	1.33
	2003-12-11	2.26 ± 0.07	2.57 ± 0.43	1.14
Mn-54	2003-06-12	6.14 ± 0.22	6.22 ± 0.67	1.01
	2003-12-11	5.99 ± 0.19	6.07 ± 0.65	1.01
Sn-113	2003-03-01	335000 ± 50000	348000 ± 18000	1.04
	2003-09-01	323000 ± 34000	344000 ± 18000	1.07
Sr-85	2003-03-01	392000 ± 59000	397000 ± 23000	1.01
	2003-09-01	403000 ± 27000	418000 ± 25000	1.04
Sr-89	2003-06-12	2.70 ± 0.07	2.47 ± 0.13	0.91
	2003-12-11	3.70 ± 0.11	3.24 ± 0.16	0.88
Sr-90	2003-06-12	0.740 ± 0.037	0.651 ± 0.057	0.88
	2003-12-11	0.370 ± 0.000	0.330 ± 0.041	0.89
	2003-09-01	7.04 ± 0.65	6.27 ± 0.39	0.89
Y-88	2003-03-01	670000 ± 100000	657000 ± 28000	0.98
	2003-09-01	670000 ± 51000	677000 ± 28000	1.01
Zn-65	2003-06-12	5.99 ± 0.19	5.99 ± 0.96	1.00
	2003-12-11	6.81 ± 0.22	6.14 ± 0.99	0.90

Table 7.09: Food/Vegetation Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·kg ⁻¹ ± 2 sigma)	NB Power (Bq·kg ⁻¹ ± 2 sigma)	NB Power/QA Agent (ratio)
Ce-141	2003-06-12	15.6 ± 0.5	17.3 ± 1.5	1.11
	2003-12-11	6.96 ± 0.22	8.07 ± 0.87	1.16
Co-58	2003-06-12	5.11 ± 0.19	5.33 ± 0.78	1.04
	2003-12-11	3.81 ± 0.11	4.22 ± 0.70	1.11
Co-60	2003-06-12	7.29 ± 0.26	8.44 ± 0.78	1.16
	2003-12-11	5.33 ± 0.19	5.81 ± 0.65	1.09
	2003-03-01	12.1 ± 0.7	17.5 ± 2.7	1.45 Fail
Cr-51	2003-06-12	13.2 ± 0.4	14.7 ± 3.7	1.11
	2003-12-11	9.66 ± 0.33	11.5 ± 3.0	1.19
Cs-134	2003-06-12	5.70 ± 0.19	6.51 ± 0.88	1.14
	2003-12-11	4.66 ± 0.15	4.74 ± 0.73	1.02
Cs-137	2003-06-12	12.7 ± 0.4	14.4 ± 1.3	1.13
	2003-12-11	4.48 ± 0.15	4.92 ± 0.70	1.10
	2003-03-01	444 ± 22	539 ± 34	1.21
Fe-59	2003-06-12	5.48 ± 0.19	5.51 ± 1.42	1.01
	2003-12-11	3.52 ± 0.11	4.18 ± 1.23	1.19
K-40	2003-03-01	1120 ± 60	1470 ± 130	1.31
Mn-54	2003-06-12	10.2 ± 0.3	11.1 ± 1.2	1.09
	2003-12-11	5.96 ± 0.19	6.36 ± 0.84	1.07
Zn-65	2003-06-12	9.99 ± 0.33	10.6 ± 1.7	1.06
	2003-12-11	6.81 ± 0.22	8.25 ± 1.57	1.21

Table 7.10: Soil Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·kg ⁻¹ ± 2 sigma)	NB Power (Bq·kg ⁻¹ ± 2 sigma)	NB Power/ QA Agent (ratio)
Ce-141	2003-06-12	11.5 ± 0.4	9.44 ± 0.96	0.82
	2003-12-11	12.0 ± 0.4	10.9 ± 1.0	0.91
Co-58	2003-06-12	3.77 ± 0.11	3.44 ± 0.63	0.91
	2003-12-11	6.55 ± 0.22	5.77 ± 0.76	0.88
Co-60	2003-06-12	5.37 ± 0.19	4.11 ± 0.51	0.77
	2003-12-11	9.18 ± 0.30	7.62 ± 0.71	0.83
Cr-51	2003-06-12	9.69 ± 0.33	10.5 ± 3.2	1.09
	2003-12-11	16.6 ± 0.6	15.3 ± 3.3	0.92
Cs-134	2003-06-12	4.18 ± 0.15	3.92 ± 0.71	0.94
	2003-12-11	8.03 ± 0.26	6.62 ± 0.87	0.82
Cs-137	2003-06-12	13.3 ± 0.1	11.5 ± 1.1	0.86
	2003-12-11	11.8 ± 0.4	10.3 ± 1.0	0.87
	2003-03-01	1450 ± 70	1350 ± 80	0.93
	2003-09-01	1970 ± 190	1580 ± 90	0.80
Fe-59	2003-06-12	4.00 ± 0.15	3.37 ± 1.19	0.84
	2003-12-11	6.07 ± 0.19	5.51 ± 1.34	0.91
K-40	2003-03-01	636 ± 33	640 ± 53	1.01
	2003-09-01	488 ± 51	419 ± 39	0.86
Mn-54	2003-06-12	7.55 ± 0.26	7.07 ± 0.83	0.94
	2003-12-11	10.2 ± 0.3	9.62 ± 1.02	0.94
Zn-65	2003-06-12	7.36 ± 0.26	6.36 ± 0.82	0.86
	2003-12-11	11.7 ± 0.4	11.9 ± 1.6	1.02

Table 7.11: Urine Performance (External QA)

Analysis	Sample Date	QA Agent (Bq·L ⁻¹ ± 2 sigma)	NB Power (Bq·L ⁻¹ ± 2 sigma)	NB Power/QA Agent (ratio)
Ba-133	2003-09-04	212 ± 11	208 ± 12	0.98
C-14	2003-10-08	2120 ± 110	2040 ± 50	0.96
	2003-10-08	25300 ± 1300	24000 ± 400	0.95
	2003-10-08	177000 ± 9000	154000 ± 11000	0.87
Cs-137	2003-09-04	259 ± 13	227 ± 15	0.88
H-3	2003-04-15	67900 ± 3400	61100 ± 1800	0.90
	2003-04-15	293000 ± 15000	266000 ± 8000	0.91
	2003-04-15	9.1E+6 ± 4.6E+5	7.5E+6 ± 2.1E+5	0.83




Figure 7.01: Alpha Performance (External QA)




Figure 7.02: Beta Performance (External QA)




Figure 7.03: C-14 Performance (External QA)




Figure 7.04: Ce-141 Performance (External QA)




Figure 7.05: Co-58 Performance (External QA)




Figure 7.06: Co-60 Performance (External QA)




Figure 7.07: Cr-51 Performance (External QA)




Figure 7.08: Cs-134 Performance (External QA)




Figure 7.09: Cs-137 Performance (External QA)




Figure 7.10: Fe-59 Performance (External QA)




Figure 7.11: H-3 Performance (External QA)




Figure 7.12: I-131 Performance (External QA)




Figure 7.13: Mn-54 Performance (External QA)




Figure 7.14: Sr-90 Performance (External QA)




Figure 7.15: Zn-65 Performance (External QA)




Figure 7.16: Ba-133, Cd-109 and Ce-139 Performance (External QA)




Figure 7.17: Co-57, Gamma and Hg-203 Performance (External QA)




Figure 7.18: K-40, Sn-113 and Sr-85 Performance (External QA)




Figure 7.19: Sr-89 and Y-88 Performance (External QA)

7.03 Internal QA

There are four parts to Internal QA:

- 1) duplicate samples – two samples collected at the same time and analysed separately
- 2) replicate analyses – two analyses done on the same sample
- 3) spiked samples – one person spikes a sample and a different person performs the analysis
- 4) repeated analyses of calibration standards or stock solutions

Duplicate samples and replicate counts are employed as part of the overall quality assurance program. For those media where two samples can be obtained from the same location at the same time, similar analytical results are expected. This approach demonstrates that the samples are representative of the medium in that area. Where duplicate samples are not possible, e.g., air filters, a sample is counted twice to demonstrate reproducibility in the counting system. Results of performance with these samples gives an indication of the reproducibility of the measurements.

Tracking of results is done in a spreadsheet and performance is charted. If the range of the ratio (of the two detected measurements) plus or minus the combined uncertainty (95% confidence interval) includes 1.00, then performance is acceptable. See Table 7.12 for the frequency.

There were 206 radionuclide comparisons performed on 94 samples analysed. Twelve of these had failures in one of the comparisons:

- Beta in LEM Composite – one failure due to tight statistics around each result (results differed by only eight percent) and two failures due to inconsistent amounts of small particles in the samples.
- Be-7 in Charcoal Cartridge – three random failures.
- Be-7 on Air Filter – one failure due to low activity.
- Cs-137 in Soil – one failure due to an inconsistency between the two samples.
- Nb-95 in LEM Composite – one failure due to low activity.
- Co-60 in LEM Composite – one failure due to inconsistent amounts of small particles in the samples.
- H-3 in Parshall Flume Water – two failures due to tight statistics around each of the results (results differed by only six and eight percent)

The results are presented graphically in Figures 7.20 to 7.33 (plotted against the analysis date).

Table 7.12: Internal Quality Assurance Frequency

<i>Medium</i>	<i>Duplicate/Replicate</i>	<i>Number of Radionuclide Comparisons</i>	<i>Analyses</i>
Airborne Carbon Dioxide	Replicate analysis (single location)	12	LSC C-14
Airborne Iodines	Replicate count (1 composite set)	36	Gamma
Airborne Particulates	Replicate count	12	Gamma
		24	Alpha/Beta
Garden Vegetables and Berries	Replicate count	7	Gamma
Milk	Duplicate sample	12	Gamma
Parshall Flume	Replicate count	12	LSC H-3
LEM Composite	Replicate count Replicate analysis	30	Gamma
		25	Alpha/Beta
		14	Sr-89,90
Sea Food	Replicate count	4	Gamma
Sediment / Soil	Duplicate sample	14	Gamma
Environmental Gamma	Duplicate sample	4	TLD

There were 206 radionuclide comparisons performed on 94 samples analysed. Twelve of these had failures in one of the comparisons:

- Beta in LEM Composite – one failure due to tight statistics around each result (results differed by only eight percent) and two failures due to inconsistent amounts of small particles in the samples.
- Be-7 in Charcoal Cartridge – three random failures.
- Be-7 on Air Filter – one failure due to low activity.
- Cs-137 in Soil – one failure due to an inconsistency between the two samples.
- Nb-95 in LEM Composite – one failure due to low activity.
- Co-60 in LEM Composite – one failure due to inconsistent amounts of small particles in the samples.
- H-3 in Parshall Flume Water – two failures due to tight statistics around each of the results (results differed by only six and eight percent)

The results are presented graphically in Figures 7.20 to 7.33 (plotted against the analysis date).

Table 7.12: Internal Quality Assurance Frequency

<i>Medium</i>	<i>Duplicate/Replicate</i>	<i>Number of Radionuclide Comparisons</i>	<i>Analyses</i>
Airborne Carbon Dioxide	Replicate analysis (single location)	12	LSC C-14
Airborne Iodines	Replicate count (1 composite set)	36	Gamma
Airborne Particulates	Replicate count	12	Gamma
		24	Alpha/Beta
Garden Vegetables and Berries	Replicate count	7	Gamma
Milk	Duplicate sample	12	Gamma
Parshall Flume	Replicate count	12	LSC H-3
LEM Composite	Replicate count Replicate analysis	30	Gamma
		25	Alpha/Beta
		14	Sr-89,90
Sea Food	Replicate count	4	Gamma
Sediment / Soil	Duplicate sample	14	Gamma
Environmental Gamma	Duplicate sample	4	TLD




Figure 7.20: Alpha Performance (Internal QA)




Figure 7.21: Beta Performance (Internal QA)




Figure 7.22: Ac-228 Performance (Internal QA)




Figure 7.23: Be-7 Performance (Internal QA)




Figure 7.24: C-14 Performance (Internal QA)




Figure 7.25: Co-60 Performance (Internal QA)




Figure 7.26: Cs-137 Performance (Internal QA)




Figure 7.27: Gamma Performance (Internal QA)




Figure 7.28: H-3 Performance (Internal QA)




Figure 7.29: K-40 Performance (Internal QA)




Figure 7.30: Nb-95 Performance (Internal QA)




Figure 7.31: Sb-124 Performance (Internal QA)




Figure 7.32: Sr-90 Performance (Internal QA)




Figure 7.33: Gd-153, Sb-125, Sr-89 and Zr-95 Performance (Internal QA)

Samples that are spiked by laboratory personnel play a minor role in the QA program. It is more desirable to purchase QA samples from an accredited QA laboratory. The only exception is the irradiation of environmental TLDs. Similar to External QA, one member of the lab staff irradiates the TLDs and a different person analyses the sample. Results of performance with these samples give an indication of the quality of measurements. Acceptable performance is defined as results within $\pm 10\%$ of the expected value.

There were no failures in the three separate tests (five TLDs for each test). The results are presented in Figure 7.34




Figure 7.34: Gamma Performance (Internal QA)

As well, stock solutions of C-14 and H-3 and were repeatedly analysed throughout the year. The results are shown in Figures 7.35 and 7.36. These practices provide an extra degree of confidence in the Environmental Program. Acceptable performance is defined as results within $\pm 10\%$ of the expected value. There were 18 individual radionuclide failures (15 for C-14 and three for H-3) out of 85 tests.

The poor performance of the C-14 is due to the age of the stock solution. A positive bias is observed in the C-14 stock solution due to evaporation over many years. This standard has been replaced.

A slightly negative bias is observed in the H-3 stock solution. This is due to the two to three percent difference between chemical quench and opacity quench.




Figure 7.35: C-14 Performance (Internal QA)




Figure 7.36: H-3 Performance (Internal QA)

The laboratory also analysed samples for several commercial clients. A calibration standard was run with each set of samples to indicate the reliability of the results to the customer. There were six individual radionuclide failures out of 84 tests. These were marginal failures and were due to the low activity of two of the radionuclides. The results and analysis dates, are presented in Figures 7.37 to 7.38.




Figure 7.37: Am-241, Cd-109 and Co-57 Performance (Internal QA)




Figure 7.38: Co-60, Cs-137 and Y-88 Performance (Internal QA)

7.04 Program Audit

The OERMP audit frequency was changed to once every five years to align with the Canadian Standards Association (CSA) standard. The Independent Assessment Group at PLGS is the principal auditor, although other groups from within NB Power, the CNSC, or other utilities may be used. The last audit was in 2000 and is due again in 2005.

In 2001, the Radiation and Environmental Protection Division (REPD) and Power Reactor Operation Division (PROD) of the CNSC, conducted its first evaluation of the OERMP.

As part of its overall Management System, Point Lepreau has an Environmental Management System (EMS) in place that is registered to ISO 14001. Radiological releases to water and air are part of this system. There were environmental audits relating to the EMS during the year, although the OERMP was not specifically examined.

7.05 Annual Review

A major review of the Operational Environmental Radiation Monitoring Program (OERMP) takes place in February of each year. The requirement for this review is stated in the Reference Document (Operational Environmental Radiation Monitoring Program⁽¹²⁾) and described in the Procedure Document (Environmental Radiation Monitoring Program Procedures⁽¹⁶⁾). All members of the lab take part in this formal review. Generally, all aspects of the program are examined to make sure that the objectives, as stated in the Reference Document, are being met.

The following are the major items from the review:

- 1) The objectives of the program were met.
- 2) PLGS emissions have decreased since 1995.
- 3) Noteworthy trends in results include:
 - increasing concentration of H-3 in Parshall Flume, but lower than the peak concentrations observed in 1999 and 2000.
 - H-3 in Bore Hole and Monitoring Well water continues a downward trend.
- 4) Procedures will be revised and issued by March 1, 2004.
- 5) A report, based on 2002 data, was issued early in 2003 which confirms previously expected groundwater movement on the peninsula and supports a reduced groundwater monitoring effort.
- 6) Work on new DELs was started.
- 7) Audit frequency was changed to once every five years.

7.05.01 Routine Monitoring Results

The analyses results are examined for consistency and trends using graphs and tables created for the Annual Report and using the performance indicators described in the Procedures. Any unusual results and problems are also examined.

This aspect of the review is discussed in sections 4 and 5 of this report.

7.05.02 Procedures

The adequacy and accuracy of field and laboratory procedures are evaluated. New or replacement methods are examined and obsolete ones are deleted. Procedures are completely revised every five years and their execution by staff is regularly checked. Any deviations from these procedures are to be documented in the Annual Report.

Procedures issued early in 2001 had an expiry date of three years. They are currently under revision and will be re-issued in 2004 with an expiry date of five years.

The only deviation from the written procedures was the increase in count time for the gamma QC from 1000 s to 1500 s.

7.05.03 Analytical QA Results

Failures and biases associated with the Analytical QA Program and the Daily QC Checks are addressed. Graphs and tables produced for the Annual Report as well as the QC Failure Log Book are used. Schedules, number of samples and problems are addressed. The degree of satisfaction with external agencies and options for different suppliers of these samples are explored.

This aspect of the review is discussed in Sections 7.01 to 7.03 of this report. Fewer samples were analysed in 2003. In 2002, the large number of QA samples overburdened the resources of the laboratory and resulted in long decay periods before some QA samples were analysed.

The C-14 stock solution will be replaced to improve C-14 QA performance.

7.05.04 Equipment

The status of laboratory and field equipment, software and facilities are considered.

Laboratory – All equipment is in good shape. Plans for the purchase of DSA boxes (gamma spectroscopy system) are being made by the department.

Software – Plans for an upgrade to the Genie 2000 gamma spectroscopy system are progressing, as is the changeover from the current Alpha based computer system to an NT box. Spreadsheet versions of the analytical software are being developed as an emergency backup and as a tool to verify software changes

Field

- A method for tracking power outage duration at the EMBs was implemented.
- The condition of two EMBs (at E01 and G02) continue to deteriorate but will not need to be replaced in 2004.

7.05.05 Personnel

Training during the previous year is reviewed and plans for the coming year are made from the point of view of program requirements and employee development. Human resources available to accomplish program objectives are evaluated.

The following training (relevant to the program) was received by laboratory personnel:

- WHMIS
- Transportation of Dangerous Goods
- First Aid/CPR
- TLD Symposium
- Radiation Protection Training Refresher
- Health Physics in Radiation Accidents
- CNSC Emergency Preparedness Workshop
- CNSC Radioisotope Licence Workshop
- Radiation Protection Training Skills Assessment
- Radiological Health Physics Workshop
- Human Performance Fundamentals

7.05.06 Safety

Laboratory and field work safety is reviewed.

There were no outstanding safety issues.

7.05.07 Emissions

The final gaseous and liquid effluent reports are studied. Their impact on routine monitoring results and their implications to the OERMP are assessed.

There were no unusual emissions that warranted any change to the program. Work on a major revision to the DELs continued as a co-operative undertaking with all COG members.

7.05.08 Meteorological Data

The impact of meteorological data on routine monitoring results and the implications to the OERMP are assessed. The results of the Meteorological Monitoring QA analysis are discussed.

The temperature bias in the 42 metre tower data may still exist. However, this information will no longer be used to calculate Pasquill stability factors starting in 2004. Changes have been made to take advantage of the two different sources of meteorological data

7.05.09 Emergency Measures Organisation Demographic Data

When available, these data are studied for implications to the program.

The survey took place in 2001. The results were still not available from New Brunswick Emergency Measures Organization (NBEMO) for analysis at year end. A new survey, planned for 2004, will be incorporated in the major revision to the DELs, which will continue in 2004.

7.05.10 Appropriateness of Media, Locations and Frequency

The choice of media, and location and frequency of sampling are examined in the broader context of the past year. Possible adjustments are examined to reflect changing conditions in the Lepreau area and future plans and expectations for PLGS from the public and CNSC.

Four environmental Guidance Documents (CNSC) are expected to be released in 2004. Action plans will be developed when these reports are received.

In the summer of 2000, a geotechnical firm evaluated the onsite groundwater movement and made recommendations for an improved monitoring program. Based on their advice, nine new bore holes in and around the SRWMF and eleven new monitoring wells near the plant were drilled, bringing the total to 35. In the fall of 2001, the CNSC inspected these new wells and met with NB Power's hydrogeologists. An enhanced monitoring program was established to give a better understanding of groundwater movement. Each well was sampled three times in 2002. Physical data were recorded at the same time that the samples were taken. At the end of 2002, these data were given to the hydrogeologists for evaluation. A report was issued by the geotechnical firm early in 2003 which confirmed previously expected groundwater movement on the peninsula.

Tritium levels in the groundwater are decreasing, or are currently at a level below regulatory concern. The impact from current levels on humans and the environment is negligible. These results along with the report supports a reduced groundwater monitoring effort for 2003.

Changes:

- new monitoring well sampling equipment was commissioned.
- the clam location at Dipper Harbour (N04) was deleted due to Department of Fisheries restrictions (clams are too small)

- the frequency of sampling monitoring wells was reduced from three times per year to once per year.

7.05.11 High LLDs

The summary report of dose to the Critical Group at the LLD is studied.

The major radionuclides that exceed the 5 μSv level (annual average) continue to be noble gases. These are detected with a TLD which measures 20 μSv dose. However the noble gas spectrometer on the GEM allows for a much smaller LLD calculation. Other exceptions are:

- Ba-140 in soil (7.9 μSv); sediment (8.1 μSv)
- Ce-144 in pond/puddle/surface water (8.0 μSv); rain water (12.4 μSv); well water (10.8 μSv); garden vegetables (8.5 μSv)
- Co-60 in garden vegetables (6.4 μSv)
- Ru-106 in pond/puddle/surface water (10.1 μSv); rain water (15.5 μSv); well water (11.1 μSv); garden vegetables (23.4 μSv); berries (8.5 μSv); clams (7.9 μSv); fish (8.4 μSv)
- Cs-134 in garden vegetables (6.3 μSv)
- I-131 in garden vegetables (6.5 μSv)

Effluent analyses show these are not a major component of emissions and no changes to counting protocols are warranted.

7.05.12 Records

The completeness and consistency of data in the environmental records database are verified at the end of each monitoring year. A QA audit is also performed on the paper copies of analysis reports filed in the laboratory office. The changes to the database are documented.

There were only two changes made to the database:

- Correction of the sample type for a raspberry sample. The wrong sample type was used when the sample was logged into the database.
- Switched location codes for a set of Parshall Flume result. The samples were incorrectly labelled when collected.

7.05.13 Contamination

Results from routine contamination monitoring as well as equipment background checks are examined.

There were no contamination issues in 2003.

7.05.14 Problem Resolution

The PICA system at PLGS was implemented to identify, track and trend conditions, concerns, and problems and solutions.

The few entries made were for External QA failures and air monitoring equipment failures (both described in preceding sections).

7.05.15 Changes to Reference Document

Major changes since the last review are documented for the annual report.

The latest revision of the OERMP Reference Document was issued in January, 2000. A new revision is planned for one year after the four CNSC Guidance Documents are issued. Major changes to the current revision are:

Changes During 2000

- gross alpha/beta counting is never done on seawater or milk samples
- Sr-89,90 analysis is performed on air filters if more than 1% DEL (GEM) is released from PLGS
- Sr-89,90 analysis is performed on seawater if more than 1% DEL (LEM) is released from PLGS
- soil is not sieved or not always heated before counting
- procedures are checked at least every three years as are their execution by staff
- I-131 is not included in any QA samples
- Sr-89,90 and Cs-137 are not included in Duplicate/Replicate filter samples
- Sr-89 is not included in most QA samples
- the major review of the program takes place in February and is approved in March
- I00G (now I11G) is on the north fence (west side)
- I00I (now I11I) is on the north fence (east side)
- gross alpha/beta counting is done routinely on well water samples, but only on other water samples if they contain significant gamma activity
- three DELs were changed to match CNSC limits (Kr-85, I-131 and I-133)

Changes During 2001

- TLDs are no longer placed at B9, B10, I90-I95, I98 & I99
- well water is no longer collected at N03
- a new aquaculture salmon site has been added close to PLGS
- soil and gamma surveys were suspended at Hemlock Knoll
- 18 new bore holes and monitoring wells were added

Changes During 2002:

- an increase in the number of external QA samples replaced a decrease in the number of internal spikes

- a new groundwater sampling procedure was implemented
- All activities that support PLGS will be controlled by the PLGS Management System that is under development. The environmental monitoring program falls under the primary process *SU-2 Provide Environmental Services*. This process was mapped, and all sub-processes related to routine environmental monitoring come under it.
- clam location at Dipper Harbour (N04) deleted

Changes During 2003:

- reduced the frequency of monitoring well sampling from three times per year to once per year (obtained CNSC approval)
- C-14 analysis is performed on milk, water, berries, and garden vegetables if more than 1% DEL (GEM) is released from PLGS
- C-14 analysis is performed on seawater and seafood if more than 1% DEL (LEM) is released from PLGS
- H-3 analysis is performed on berries and garden vegetables if more than 1% DEL (GEM) is released from PLGS
- H-3 analysis is performed on seafood if more than 1% DEL (LEM) is released from PLGS
- reduced the number of QA samples (a new schedule)
- changed the audit frequency to once every five years to align with the CSA standard

Planned Changes for 2004:

- implementation of recommendations from four new CNSC guidance documents
- reduce the frequency of bore hole sampling from three times per year to two times per year (pending CNSC approval)

7.05.16 Program Audit

The results of any audits are reviewed.

This aspect of the review is discussed in Sections 7.04 of this report.

The audit frequency was changed to once every five years to align with the CSA standard.

7.05.17 Program Improvement

Areas for improvement are identified:

- *from relevant operating experience (internal & external) (EN-418)*
- *during the annual review (EN-414)*
- *during audits*
- *by laboratory staff*
- *by other HP staff*
- *by the Manager, Personnel Safety and Environment*

- *by the self assessment process*

Deficiencies in any of the listed areas are dealt with promptly. The results of the Annual Review are used to improve the program, and are included in the Annual Report.

The preceding sections describe ways that the program will be improved in 2004.

8 Reports and Studies

Several reports were issued, including a study of groundwater movement⁽¹⁾, an ecological effects review⁽²⁾, an environmental assessment of the proposed SRWMP modifications (supporting PLGS refurbishment)⁽³⁾ and the process map for environmental services. Each of these was studied for identifying changes to be made to the OERMP.

Work that began in 2002, and that will continue into 2004, includes the next revision of the DELs and the setting up of a Nal monitoring network by Health Canada.

The CNSC released the reporting requirements document S-99 in 2003, and may release four Regulatory Guidance Documents on the environment in 2004. Changes will have to be made to the OERMP to comply with these.

COG released several Reports and Technical Notes that contained interim data from current research projects, guidance for future program development and plans for future projects near PLGS.

Appendices

Appendix A: Statistics, Detection Limits, and Dose at Detection Limits

A1 Statistics

The following statistical conventions are applied in the analysis of each sample:

- Detection limits are defined following the method described by Lochamy⁽¹⁸⁾. The lower limit of detection (LLD) at the 99% confidence level is defined as $6.58 S_b$, where S_b is the standard deviation of the appropriate radiation background measurement. This LLD corresponds to that amount of activity in a sample that will yield a net count greater than $3.29 S_b$, or the so-called critical level (CL), with 99% probability. Thus, the LLD specifies the theoretical capability of the system to detect a given amount of radioactivity, whereas CL is used to determine whether an actual activity measurement should be considered detected. Any net measurement greater than $3.29 S_b$ is considered detected at the 99% confidence level. This also implies a 1% probability of stating that activity is present when it is not (false positive). If activity is present at the LLD level ($6.58 S_b$), there is a 1% probability of stating that activity is not present when it is (false negative).
- The CL of $3.29 S_b$ and LLD of $6.58 S_b$ apply in those analytical systems where the background levels are either not well defined, or where there is a relationship between the background levels and the detected signal above background, as in Ge gamma spectroscopy. Where the background readings are well defined and are independent of sample readings, as in the TLD data, the CL is $2.33 S_b$ and the LLD is $4.66 S_b$.
- In most of the tables of data (Section 4.0), it is this Critical Level that appears in column 2.
- Unless otherwise indicated, the precision of the measurements reported here is given as $\pm 1.96 S_a$ (95% confidence level), where S_a is the standard deviation of the activity measurement.
- The value and standard deviation are reported with two significant figures using modified scientific notation, for example 0.032 is expressed as 3.2E-02.

The lower limits of detection (LLD) of all radionuclides in the various sample media are shown in Tables A.01 to A.11. The Annual Dose is to a member of the Critical Group. The LLDs are based on typical data. Decay of radionuclides is accounted for in the LLD calculations except for H-3 and C-14 (long half-lives). The major assumptions are that the sample is taken at one kilometre from the point of emissions and that the level is maintained for the year. Milk is assumed to be from a cow pastured at 1.5 km, fish and lobster are caught at the Condenser Cooling Water (CCW) outlet and sediment, dulse, seawater and clams are collected at Dipper Harbour.

The CSA recommends, where technically feasible, that all measurements achieve LLDs less than that which would result in a dose of $5 \mu\text{Sv}$ to the Critical Group. Most radionuclides pass this

criterion. The major exceptions are noble gases. Detection of this group is through TLD measurements ($20 \mu\text{Sv}$ dose to the Critical Group at the LLD). However, the noble gas spectrometer on the GEM allows for a much smaller LLD calculation. Other exceptions are Ba-140 in soil and sediment (10 to $12 \mu\text{Sv}$); Ru-106 in water and clams (7 to $17 \mu\text{Sv}$); Ce-144 in water ($11 \mu\text{Sv}$); and I-131 in food ($8 \mu\text{Sv}$). Effluent analyses show these are not major components of emissions. Part of the QA process identifies those LLDs or activities that do not meet this target.

A1.01 Air

A1.01.01 Airborne Particulates

Typical LLDs are given for a 2400 m^3 sample, counted for 5000 s. The LLDs are decay corrected to the midpoint between the start and end of sampling, except for the gross alpha/beta results which represent the long-lived activity present a few days after sample collection. Gross alpha/beta is for trending only.

A1.01.02 Airborne Radioiodines

A typical LLD for I-131 is approximately $9\text{E-}05 \text{ Bq}\cdot\text{m}^{-3}$ (for a 2400 m^3 sample, counted for 50 000 s), which is decay corrected to the midpoint between the start and end of sampling.

A1.01.03 Airborne Tritium

The LLD is approximately $1\text{E-}01 \text{ Bq}\cdot\text{m}^{-3}$ of air for a typical sample of 10 to 70 m^3 (counted for 100 min). Due to the long half-life and relatively short period of time between sampling and analysis, decay correction is not applied.

A1.01.04 Airborne Carbon-14

A typical LLD is approximately $4\text{E-}02 \text{ Bq}\cdot\text{m}^{-3}$ of air for a 30 m^3 sample (counted for 100 min). Due to the long half-life and relatively short period of time between sampling and analysis, decay correction is not applied.

A1.01.05 TLD

The LLD is about $20 \mu\text{Sv}$. For typical quarterly measurements in the region of 150-200 μSv , measurements can be made to $\pm 10\%$ at the 95% confidence level.

Table A.01 Annual Dose at the LLD for Air

Nuclide	LLD (Bq·m ⁻³)	Dose at LLD (μSv)	Activity That Gives 5 μSv (Bq·m ⁻³)
H-3	9.6E-02	4.8E-02	9.9E+00
C-14	4.0E-02	1.9E+00	1.0E-01
Cr-51	5.8E-04	3.2E-03	9.2E-01
Mn-54	7.8E-05	9.2E-02	4.3E-03
Fe-59	1.7E-04	6.1E-02	1.4E-02
Co-58	8.0E-05	3.5E-02	1.2E-02
Co-60	8.2E-05	1.7E+00	2.4E-04
Zn-65	1.9E-04	3.3E-01	2.9E-03
Kr-85	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Kr-85m	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Kr-87	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Kr-88	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Zr-95	1.3E-04	1.1E-01	6.2E-03
Nb-95	9.4E-05	9.9E-02	4.7E-03
Ru-103	7.4E-05	8.1E-03	4.5E-02
Ru-106	6.0E-04	1.0E+00	2.9E-03
Ag-110m	6.2E-05	2.2E-01	1.4E-03
I-131	8.4E-05	1.6E-01	2.5E-03
Xe-131m	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Xe-133	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Xe-133m	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Xe-135	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Xe-135m	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Xe-138	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Cs-134	6.4E-05	4.3E-01	7.4E-04
Cs-137	6.6E-05	1.6E+00	2.0E-04
Ba-140	4.8E-04	8.9E-02	2.7E-02
La-140	2.0E-04	2.5E-03	4.1E-01
Ce-141	7.6E-05	4.8E-03	7.9E-02
Ce-144	2.2E-04	2.7E-01	4.0E-03
Noble Gases	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
Gross Alpha	6.6E-06		
Gross Beta	1.7E-05		

A1.02 Milk

Typical LLDs for the nuclides of interest in milk (a 3.6 L sample counted for 50 000 s for gamma; 6 mL sample counted for 100 min for tritium) are listed in Table A.02 for the time of sample collection.

Table A.02 Annual Dose at the LLD for Milk

<i>Nuclide</i>	<i>LLD (Bq·L⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·L⁻¹)</i>
H-3	2.4E+01	3.1E-01	3.9E+02
Cr-51	6.4E-01	1.0E-02	3.1E+02
Mn-54	9.2E-02	1.9E-02	2.5E+01
Fe-59	2.2E-01	2.2E-01	5.1E+00
Co-58	9.0E-02	7.5E-02	6.0E+00
Co-60	1.1E-01	9.0E-01	6.1E-01
Zn-65	2.4E-01	5.3E-01	2.3E+00
Zr-95	1.6E-01	4.3E-02	1.8E+01
Nb-95	9.2E-02	1.2E-01	3.8E+00
Ru-103	8.4E-02	1.9E-02	2.2E+01
Ru-106	7.8E-01	2.7E+00	1.4E+00
Ag-110m	8.2E-02	5.5E-02	7.4E+00
I-131	9.4E-02	1.8E+00	2.6E-01
Cs-134	7.8E-02	3.1E-01	1.3E+00
Cs-137	9.8E-02	3.1E-01	1.6E+00
Ba-140	3.4E-01	2.1E-01	8.1E+00
La-140	1.1E-01	8.9E-02	6.1E+00
Ce-141	1.2E-01	3.0E-02	2.1E+01
Ce-144	5.0E-01	9.5E-01	2.6E+00

A1.03 Water

The LLDs in Table A.03 apply to the midpoint between the start and end of sampling for a 3.6 L sample counted for 5000 s for gamma and a 6 mL sample counted for 100 min for tritium. Alpha/beta results (a 200 mL sample counted for 100 min) represent the long-lived activity present several days after sample collection.

The LLDs are based on typical data for rainwater (the only water sample that has significant decay before analysis). Since decay of radionuclides is accounted for in the LLD calculations, Well Water and other water sample types will have lower LLDs than these. The major assumptions are that the sample is taken at one kilometre from the point of emissions, that the level is maintained for the year and the sample type is the major source of drinking water. Obviously this is not the case but it gives a simple "worst case" that is easy to monitor and calculate.

Table A.03 Annual Dose at the LLD for Water

<i>Nuclide</i>	<i>LLD (Bq·L⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv, (Bq·L⁻¹)</i>
H-3	2.4E+01	3.4E-01	3.6E+02
Cr-51	5.4E+01	7.4E-02	3.7E+03
Mn-54	5.0E-01	1.7E-01	1.4E+01
Fe-59	1.3E+00	9.1E-01	7.1E+00
Co-58	5.6E-01	3.7E-01	7.5E+00
Co-60	4.6E-01	4.5E+00	5.1E-01
Zn-65	1.1E+00	2.3E+00	2.4E+00
Zr-95	9.8E-01	4.0E-01	1.2E+01
Nb-95	6.8E-01	4.0E-01	8.5E+00
Ru-103	6.4E-01	1.8E-01	1.8E+01
Ru-106	4.6E+00	1.7E+01	1.4E+00
Ag-110m	4.6E-01	6.2E-01	3.7E+00
I-131	2.4E+00	3.9E+00	3.1E+00
Cs-134	4.4E-01	4.8E+00	4.6E-01
Cs-137	5.2E-01	3.9E+00	6.6E-01
Ba-140	5.4E+00	2.7E+00	1.0E+01
La-140	2.2E+00	9.1E-01	1.2E+01
Ce-141	8.4E-01	3.4E-01	1.2E+01
Ce-144	2.4E+00	1.1E+01	1.1E+00
Gross Alpha	1.2E-01		
Gross Beta	8.4E-02		

A1.04 Food

The LLDs in Table A.04 apply to the time of sample collection. Samples are counted for 5000 s (size varies). The LLDs are based on typical data for garden vegetables. Garden vegetables have significant radioactive decay before analysis (the local residents harvest them and store them in their freezers for varying lengths of time). Since decay of radionuclides is accounted for in the LLD calculations, berries and other food sample types (which experience less radioactive decay) will have lower LLDs than these.

Table A.04 Annual Dose at the LLD for Food

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	3.0E+01	5.9E-02	2.5E+03
Mn-54	3.4E+00	1.3E-01	1.3E+02
Fe-59	7.8E+00	8.4E-01	4.6E+01
Co-58	3.6E+00	3.0E-01	6.0E+01
Co-60	3.8E+00	3.9E+00	4.9E+00
Zn-65	9.0E+00	2.2E+00	2.1E+01
Zr-95	6.2E+00	3.3E-01	9.4E+01
Nb-95	4.0E+00	3.6E-01	5.6E+01
Ru-103	3.8E+00	1.7E-01	1.1E+02
Ru-106	3.0E+01	1.3E+01	1.1E+01
Ag-110m	3.0E+00	4.7E-01	3.2E+01
I-131	1.0E+01	6.9E+00	7.6E+00
Cs-134	3.0E+00	3.6E+00	4.2E+00
Cs-137	3.4E+00	2.9E+00	6.0E+00
Ba-140	2.4E+01	3.5E+00	3.5E+01
La-140	9.4E+00	1.2E+00	4.0E+01
Ce-141	4.2E+00	1.9E-01	1.1E+02
Ce-144	1.4E+01	4.9E+00	1.4E+01

A1.05 Soil

The LLDs in Table A.05 apply to the time of sample collection. Samples of approximately 200 g are counted for 5000 s.

Table A.05 Annual Dose at the LLD for Soil

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	4.0E+01	2.5E-01	7.9E+02
Mn-54	5.8E+00	1.2E+00	2.5E+01
Fe-59	1.2E+01	3.1E+00	1.9E+01
Co-58	5.0E+00	1.1E+00	2.2E+01
Co-60	5.8E+00	3.2E+00	9.1E+00
Zn-65	1.3E+01	1.7E+00	3.9E+01
Zr-95	1.0E+01	5.1E+00	9.9E+00
Nb-95	6.0E+00	9.9E-01	3.0E+01
Ru-103	4.8E+00	5.1E-01	4.7E+01
Ru-106	4.6E+01	1.9E+00	1.2E+02
Ag-110m	5.2E+00	2.7E+00	9.7E+00
I-131	6.8E+00	5.2E-01	6.6E+01
Cs-134	5.2E+00	1.5E+00	1.7E+01
Cs-137	5.6E+00	7.1E-01	3.9E+01
Ba-140	2.2E+01	1.1E+01	9.6E+00
La-140	7.2E+00	*	*
Ce-141	6.8E+00	1.2E-01	2.8E+02
Ce-144	2.4E+01	2.9E-01	4.2E+02
TLD	2.0E+01 μSv	2.0E+01	5.0E+00 μSv
*Dose for Ba-140 assumes equilibrium with La-140 (contribution from both)			

A1.06 Seawater

The LLDs in Table A.06 apply to the time of sample collection (for a 3.6 L sample counted for 5000 s for gamma; a 6 mL sampled counted for 100 min for tritium). The dose is small due to the simple facts that the Bay of Fundy is frigid at the best of times (occupancy factor is low) and no one drinks salt water.

Table A.06 Annual Dose at the LLD for Seawater

<i>Nuclide</i>	<i>LLD (Bq·L⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·L⁻¹)</i>
H-3	2.4E+01	9.2E-11	1.3E+12
Cr-51	2.2E+00	2.6E-10	4.3E+10
Mn-54	2.8E-01	7.9E-10	1.8E+09
Fe-59	6.2E-01	2.6E-09	1.2E+09
Co-58	2.8E-01	9.1E-10	1.5E+09
Co-60	3.2E-01	2.4E-09	6.8E+08
Zn-65	6.8E-01	1.3E-09	2.6E+09
Zr-95	5.2E-01	1.2E-09	2.2E+09
Nb-95	3.0E-01	9.3E-10	1.6E+09
Ru-103	2.8E-01	4.4E-10	3.2E+09
Ru-106	2.6E+00	1.6E-09	8.3E+09
Ag-110m	2.6E-01	2.3E-09	5.7E+08
I-131	3.6E-01	2.3E-09	8.0E+08
Cs-134	2.6E-01	1.3E-09	1.0E+09
Cs-137	3.0E-01	5.2E-10	2.9E+09
Ba-140	1.2E+00	2.6E-08	2.4E+08
La-140	4.6E-01	*	*
Ce-141	4.0E-01	1.1E-10	1.8E+10
Ce-144	1.6E+00	2.7E-10	3.0E+10

* Dose for Ba-140 assumes equilibrium with La-140 (contribution from both)

A1.07 Clams

Typical LLDs are given in Table A.07 for the edible portions of clams, decay corrected to the time of sample collection. Samples are counted for 5000 s (size varies). The major assumptions are that the sample is taken at Dipper Harbour and that the level is maintained for the year.

Table A.07 Annual Dose at the LLD for Clams

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	5.0E+01	2.0E-02	1.3E+04
Mn-54	7.0E+00	6.5E-02	5.4E+02
Fe-59	1.4E+01	3.1E-01	2.3E+02
Co-58	7.2E+00	1.3E-01	2.7E+02
Co-60	6.4E+00	1.8E+00	1.8E+01
Zn-65	1.4E+01	8.8E-01	7.8E+01
Zr-95	1.2E+01	1.5E-01	3.7E+02
Nb-95	6.6E+00	1.4E-01	2.3E+02
Ru-103	6.0E+00	5.5E-02	5.5E+02
Ru-106	5.8E+01	6.5E+00	4.5E+01
Ag-110m	5.8E+00	2.2E-01	1.3E+02
I-131	7.2E+00	9.5E-01	3.8E+01
Cs-134	6.6E+00	1.6E+00	2.1E+01
Cs-137	6.8E+00	1.5E+00	2.2E+01
Ba-140	2.4E+01	7.7E-01	1.6E+02
La-140	9.4E+00	2.2E-01	2.1E+02
Ce-141	7.4E+00	8.0E-02	4.6E+02
Ce-144	3.2E+01	2.6E+00	6.3E+01

A1.08 Fish

Typical LLDs are given in Table A.08 for the edible portions of fish, decay corrected to the time of sample collection. Samples are counted for 5000 s (size varies).

Table A.08 Annual Dose at the LLD for Fish

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	1.3E+01	1.6E-02	4.0E+03
Mn-54	1.5E+00	5.1E-02	1.5E+02
Fe-59	3.8E+00	2.8E-01	6.8E+01
Co-58	1.5E+00	9.2E-02	8.0E+01
Co-60	1.4E+00	1.3E+00	5.4E+00
Zn-65	3.0E+00	7.0E-01	2.2E+01
Zr-95	2.2E+00	1.1E-01	1.0E+02
Nb-95	1.4E+00	1.1E-01	6.6E+01
Ru-103	1.5E+00	4.9E-02	1.5E+02
Ru-106	1.1E+01	4.4E+00	1.2E+01
Ag-110m	1.2E+00	1.7E-01	3.5E+01
I-131	7.8E+00	1.3E+00	3.1E+01
Cs-134	1.0E+00	1.2E+00	4.5E+00
Cs-137	1.4E+00	1.0E+00	7.1E+00
Ba-140	1.0E+01	7.8E-01	6.4E+01
La-140	4.6E+00	2.4E-01	9.6E+01
Ce-141	1.8E+00	6.0E-02	1.5E+02
Ce-144	5.8E+00	1.6E+00	1.8E+01

A1.09 Lobster

Typical LLDs are given in Table A.09 for the edible portions of lobster, decay corrected to the time of sample collection. Samples are counted for 5000 s (size varies).

Table A.09 Annual Dose at the LLD for Lobster

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	3.0E+01	1.3E-02	1.2E+04
Mn-54	2.8E+00	2.1E-02	6.7E+02
Fe-59	9.0E+00	1.5E-01	2.9E+02
Co-58	3.2E+00	6.7E-02	2.4E+02
Co-60	3.8E+00	5.4E-01	3.5E+01
Zn-65	7.8E+00	3.4E-01	1.2E+02
Zr-95	5.4E+00	6.8E-02	4.0E+02
Nb-95	4.4E+00	9.0E-02	2.4E+02
Ru-103	4.0E+00	3.1E-02	6.4E+02
Ru-106	3.0E+01	2.4E+00	6.3E+01
Ag-110m	3.4E+00	8.8E-02	1.9E+02
I-131	1.7E+01	3.3E+00	2.6E+01
Cs-134	2.8E+00	6.4E-01	2.2E+01
Cs-137	3.4E+00	4.5E-01	3.8E+01
Ba-140	3.4E+01	1.2E+00	1.4E+02
La-140	1.2E+01	4.2E-01	1.4E+02
Ce-141	4.4E+00	4.3E-02	5.1E+02
Ce-144	1.3E+01	8.7E-01	7.4E+01

A1.10 Dulse

Typical LLDs are given in Table A.11 for dulse, decay corrected to the time of sample collection. Samples are counted for 5000 s (size varies). The major assumptions are that the sample is taken at Dipper Harbour and that the level is maintained for the year.

Table A.11 Annual Dose at the LLD for Dulse

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	2.0E+01	2.4E-03	4.2E+04
Mn-54	3.4E+00	7.4E-03	2.3E+03
Fe-59	8.0E+00	4.4E-02	9.0E+02
Co-58	3.4E+00	1.5E-02	1.1E+03
Co-60	3.4E+00	2.1E-01	7.9E+01
Zn-65	8.2E+00	1.1E-01	3.9E+02
Zr-95	6.6E+00	1.6E-02	2.1E+03
Nb-95	3.6E+00	1.9E-02	9.5E+02
Ru-103	2.8E+00	7.1E-03	2.0E+03
Ru-106	2.6E+01	6.7E-01	2.0E+02
Ag-110m	3.0E+00	2.3E-02	6.4E+02
I-131	5.4E+00	3.0E-01	9.1E+01
Cs-134	2.8E+00	1.9E-01	7.3E+01
Cs-137	3.2E+00	1.3E-01	1.2E+02
Ba-140	1.6E+01	1.6E-01	4.9E+02
La-140	5.4E+00	2.8E-02	9.7E+02
Ce-141	3.4E+00	8.8E-03	1.9E+03
Ce-144	1.4E+01	2.4E-01	2.9E+02

A1.11 Sediment

The LLDs in Table A.11 apply to the time of sample collection. Samples weighing approximately 200 g are counted for 5000 s. The major assumptions are that the sample is taken at Dipper Harbour and that the level is maintained for the year.

Table A.12 Annual Dose at the LLD for Sediment

<i>Nuclide</i>	<i>LLD (Bq·kg⁻¹)</i>	<i>Dose at LLD (μSv)</i>	<i>Activity That Gives 5 μSv (Bq·kg⁻¹)</i>
Cr-51	1.7E+01	2.1E-01	4.2E+02
Mn-54	2.8E+00	7.9E-01	1.8E+01
Fe-59	6.2E+00	2.3E+00	1.3E+01
Co-58	2.6E+00	8.4E-01	1.5E+01
Co-60	2.8E+00	2.3E+00	6.1E+00
Zn-65	6.8E+00	1.3E+00	2.7E+01
Zr-95	4.8E+00	3.9E+00	6.1E+00
Nb-95	3.0E+00	7.2E-01	2.1E+01
Ru-103	2.4E+00	3.9E-01	3.1E+01
Ru-106	2.0E+01	1.5E+00	6.6E+01
Ag-110m	2.2E+00	2.1E+00	5.3E+00
I-131	3.4E+00	4.7E-01	3.6E+01
Cs-134	2.0E+00	1.2E+00	8.7E+00
Cs-137	2.8E+00	6.2E-01	2.3E+01
Ba-140	1.2E+01	1.0E+01	5.8E+00
La-140	3.8E+00	*	*
Ce-141	3.0E+00	8.9E-02	1.7E+02
Ce-144	1.1E+01	2.1E-01	2.7E+02
gamma meter	0.01 μSv·h ⁻¹	3.0E+00	1.7E-02
* Dose for Ba-140 assumes equilibrium with La-140 (contribution from both)			

Appendix B: Sample Collection and Analytical Techniques

B1 Analytical Techniques

All environmental samples are analysed at the Health Physics Environmental Laboratory in Fredericton. The following pages provide a general summary of the analytical techniques used in the laboratory. Sample collection, preparation and analysis are briefly described, but can be found in detail in the laboratory procedures.

The major analytical techniques and the instruments used in routine environmental analyses are summarised in the Table B.01.

Table B.01 Summary of Analytical Techniques

Analytical Technique	Instrumentation
Gamma Spectroscopy	Canberra 24% efficient* intrinsic, Ge detector in an Applied Physical Technology 10 cm graded lead cave; Canberra S-100 MCA
Liquid Scintillation (tritium and C-14)	Beckman LS 6000TA Liquid Scintillation Counter
Gross Alpha/Beta (Wet Chemical Analysis for Sr-89 and Sr-90)	Tennelec LB-5100 Alpha/Beta Counting System
Gamma Surveys	Eberline Model FH 40G-10 low range gamma survey meter (range 10 nSv·h ⁻¹ to 1 Sv·h ⁻¹ for 30 keV to 3 MeV photons).
Thermoluminescent Dosimetry	Panasonic UD-710A Automatic TLD Reader and UD-814A1 (CaSO ₄) dosimeters

*relative to a 3x3 inch sodium iodide detector

In gamma spectroscopy analysis, all significant peaks in the spectrum are identified either by reference to a database library of about 150 radionuclides, or by manual reference to compilations of all known radionuclides. In addition, approximately 20 selected radionuclides are specifically searched for in every sample with the exception of Air Iodine samples in which only I-131 is selected. The selected radionuclides include those that are produced in PLGS, and which would be readily detectable because of their abundance (high fission yield) and high branching ratios for gamma emissions. Naturally occurring gamma emitters, with the exception of Be-7, K-40 and Ac-228, are not included in this report. These excepted radionuclides are sometimes useful as general indicators of the consistency of the analytical techniques.

The peak search and analysis program SAMPO is used to process spectra. The library of radionuclides uses data of the Oak Ridge Laboratory. There are three categories of radionuclides evaluated:

- 1) selected nuclides of key fission and activation products
- 2) all other identified radionuclides, including natural radionuclides
- 3) detected energy peaks for which no identification can be readily made.

The three categories cover all possible eventualities in a spectral analysis and ensure that no significant radionuclides or photon energies will be overlooked.

The usefulness of gross alpha/beta analysis lies primarily in screening samples (to determine whether more detailed analyses should be performed) and showing trends. The reported alpha and beta values are assessed with respect to Am-241 and Sr-Y-90 calibration sources, respectively.

Wet chemical analysis for Sr-89,90 on GEM and LEM samples follow the American Society for Testing and Materials procedure (using column chromatography).

Liquid samples, other than milk, are acidified upon receipt to keep radionuclides from plating out on the container walls. Perishable samples are refrigerated or frozen.

B2 Sample Collection and Analysis

B2.01 Airborne Particulates

Airborne particulates are collected on a 47 mm diameter Gelman Type A glass fibre filter, through which air is drawn at about $60 \text{ L} \cdot \text{min}^{-1}$ (approximately 2400 m^3 for a 28 day continuous sample). The volume of air sampled is measured with an in-line integrating dry gas meter. Every month the filters are replaced and the used ones are returned to the laboratory for analysis. Sampling is therefore continuous throughout the year, the only interruption (other than power failure or pump breakdown) being the few minutes for a filter change.

Air particulate filters are analysed by gamma spectroscopy as soon as possible after collection to minimise loss of information through radioactive decay (ensure detection of any short lived gamma emitters that may be present, and to minimise any decay corrections). Samples are counted for 5000 s on the Ge detector.

Approximately three days after the end of the sample collection interval, each filter is counted for 100 minutes for the simultaneous determination of gross alpha and gross beta activities. Counting is delayed to allow for the decay of the short-lived radon progeny that would otherwise complicate the analysis.

If significant alpha/beta levels are detected (twice the normal level), further investigation is initiated (longer gamma counts or radiostrontium determinations).

If significant levels of Sr-89,90 (indicating 1% of Weekly DEL) are detected in the chemical analysis of GEM filters, then the air monitoring station particulate filters are also to be analysed for these radionuclides.

B2.02 Airborne Radioiodines

Airborne radioiodines are collected in an activated charcoal cartridge placed downstream of the particulate filter. The cartridges are Nuclear Consulting Services NUSORB® (47 mm diameter and 48 mm length), containing 5% TEDA by weight. For a 28 day continuous sample approximately 2400 m³ of air is sampled at a flow rate of about 60 L·min⁻¹. The volume of air sampled is measured with an in-line integrating dry gas meter.

Iodine-131 is the major nuclide of interest on the charcoal cartridges. The cartridges are counted in groups of four for 50 000 s on the gamma spectrometer. Counts are performed as soon as possible after collection because of the relatively short-half life of I-131 (8 days). If radioiodines are detected, then the cartridges are re-analysed individually. Other fission product radioiodines, with much shorter half-lives (minutes to hours), decay before they reach the sample location or during the time the sample is being collected. If a significant release of radioiodines were noted from the station in this interval, the samples would be changed and analysed earlier to minimise errors from decay corrections.

B2.03 Airborne Tritium

A fraction of the flow in the air monitoring sample station is diverted through a molecular sieve container (Linde type 13X sieve material), to extract water vapour from the sampled air. Sample volume is measured with an in-line integrating dry gas meter.

Sampling is continuous at each location throughout the year, but is interrupted for a few minutes every month to exchange sieve containers. Since the amount of water absorbed by the molecular sieve from a given volume of air depends upon absolute humidity, flow rates are adjusted seasonally (using a Dwyer flow meter) to avoid saturation of the sieve material and to ensure adequate sample collection.

For tritium analysis by liquid scintillation counting, 6 mL of water taken from the molecular sieve condensate is counted for 100 minutes.

B2.04 Airborne Carbon-14

An aquarium pump bubbles air through 2N NaOH (1 L), into which carbon dioxide from the air is absorbed. Any C-14 as CO₂ is also absorbed.

Carbon dioxide, in the form of sodium carbonate, is regenerated by acidification and analysed for the determination of C-14 activity. The carbon dioxide is passed through a silica gel trap to

remove moisture and tritium and then absorbed into the chemical Carbo-sorb[®] E until saturation is reached. After the addition of the scintillation cocktail Permafluor[®] E⁺, the sample is analysed for 100 minutes by liquid scintillation counting.

B2.05 Environmental Gamma Radiation (TLD)

The environmental TLD is composed of one element of natural lithium borate with no extra filtration, and three elements of calcium sulphate with lead filtration of about $700 \text{ mg}\cdot\text{cm}^{-2}$. The badge is sealed in plastic, placed in a screw cap plastic container and suspended about 1 m above the ground for a period of three months. This will measure the ambient gamma dose, whether it is from activity in the air, from the ground or cosmic in origin.

Readout is by the Panasonic UD-710A Automatic Reader. For typical quarterly measurements in the region of 150-200 μSv , measurements can be made to $\pm 10\%$ at the 95% confidence level.

B2.06 Soil

Soil samples are collected in undisturbed locations away from nearby buildings or trees. Level areas with some vegetation are preferred. A representative sample (approximately 1.6 kg) of the top 25 mm of a 20 cm by 20 cm area of soil is placed in a disposable polyethylene container.

The soil is air dried overnight. If excessive moisture is present, the sample is dried on a disposable aluminum tray (at 100°C). Organic matter and stones are removed. Approximately 0.25 kg of dry soil is counted by gamma spectroscopy for 5000 s.

B2.07 Food

Garden produce and berries, which are either collected or purchased, require no special preparation. The edible portion is put in a calibrated container and weighed (size varies). This is counted by gamma spectroscopy for 5000 s.

B2.08 Milk

A 4L sample is purchased and placed in a clean polyethylene container.

For gamma spectroscopy, a 3.6 L aliquot is measured into a marinelli beaker. The remainder is distilled, and a 6 mL aliquot is analysed by liquid scintillation counting for 100 minutes. Count times are 50 000 s for gamma spectroscopy and 100 min for tritium analysis.

B2.09 Water

A 4L sample of well water, pond water, lake water or surface runoff is collected in a clean polyethylene container.

A portion is removed for tritium analysis, and the remainder is acidified (15 mL of 70% nitric acid per 4 L sample). Of this, 3.6 L is measured into a marinelli beaker for gamma spectroscopy. After gamma analysis, well water samples (125-500 mL, depending upon the dissolved solids content) are evaporated to dryness on stainless steel planchets for gross alpha/beta analysis. For tritium analysis by liquid scintillation techniques, a 6 mL aliquot is analysed by liquid scintillation counting. For gamma spectroscopy, the sample is counted for 5000 s. For tritium and gross alpha/beta analyses, samples are counted for 100 min. A level twice the normal level for alpha/beta will initiate further investigation (longer gamma counts and/or Sr-89,90 analyses).

Measurements of gross alpha and beta are made about two weeks after sample collection. This delay avoids analytical interference from radon progeny whose activity is tied to that of the parent, which decays with a half-life of about 3.8 days. Natural radon and radon progeny occur in well waters everywhere and are known to reach high concentrations in many New Brunswick locations.

B2.10 Vegetation

The only vegetation types routinely collected and analysed are tree lichen (Spanish moss) and various ground mosses such as *Cladonia* and *Lycopodium*. They concentrate a wide range of radionuclides, both natural and man-made. This makes them sensitive indicators of radionuclides in the environment even though they are not identified in the pathway to humans.

About 25 g or more of each of the samples is collected and air-dried before analysis. No special preparation is required. The sample is placed in a calibrated container and weighed. This is counted by gamma spectroscopy for 5000 s.

B2.11 Precipitation

Rain is collected continuously during the milder months.

A portion is removed for tritium analysis, and the remainder is acidified (15 mL of 70% nitric acid per 4 L sample). Of this, 3.6 L is measured into a marinelli beaker for gamma spectroscopy. For tritium analysis by liquid scintillation techniques, a 6 mL sample of water is counted for 100 min. For gamma spectroscopy, the sample is counted for 5000 s.

B2.12 Sediment and Beach Surveys

Beach sediment samples are collected near the low tide mark, with preference being given to the top 10 mm of the fine sediment characteristic of tidal mud flats. A disposable polyethylene container is used to collect about 1 kg of sample. In addition, direct gamma radiation dose rate measurements are made at each sediment site using an Eberline Model FH 40G-10 low range gamma survey meter (range $10 \text{ nSv}\cdot\text{h}^{-1}$ to $1 \text{ Sv}\cdot\text{h}^{-1}$ for 30 keV to 3 MeV photons). The meter is held for one minute at a point one metre above the intertidal surface. After the sediment sample has been collected, this is repeated.

The sample is transferred to a disposable aluminum tray for drying at 80°C . Dried, caked samples are broken into their original free granular form with a porcelain mortar and pestle, and sieved through a 0.5 mm mesh to collect the fines for analysis (a 1 mm sieve is used for coarse sediments). Approximately 0.25 kg of dried sediment is counted by gamma spectroscopy for 5000 s.

B2.13 Seafood

The inshore fishery throughout the Maritimes has declined since the OERMP was started in 1982. Some of it has been closed to any kind of harvesting. However, species of local seafood are collected when available from local fishermen. Sampling focuses on fish, lobsters and clams. Some of the areas where clam harvesting is prohibited are sampled with the permission of the Department of Fisheries and Ocean. Other seafood species are more mobile and can sometimes be found throughout the area: crab, periwinkles, aquaculture salmon, scallops, herring, mackerel, dogfish, cod, haddock, sea urchin, mussels, and flounder. The severe restrictions placed on the inshore fishery as well as the depletion of stocks make many of these samples unavailable most of the time (sometimes spanning years). However, whenever they are available an effort is made to collect as many samples as possible. Approximately 0.5 kg of fresh seafood is collected per sample.

Approximately 0.25 kg of each sample is prepared for gamma spectroscopy. Lobsters are cooked first, and the edible meat is removed for analysis. Clams, periwinkles, and crab are analysed whole, with a yield factor applied to account for the mass of the inedible shell. Usually the edible portion of fish is analysed, although sometimes the whole fish is analysed. Samples are counted for 5000 s.

B2.14 Aquatic Plants

Dulse (*Rhodymenia palmata*), an edible seaweed which is commercially harvested in the area, is collected monthly when available. Other species of seaweed concentrate a wide range of radionuclides, both natural and man-made. This makes them sensitive indicators of radionuclides in the environment even though they are not identified in the pathway to humans.

A portion of the seaweed or dulse is put in a calibrated container and weighed (size varies). This is counted by gamma spectroscopy for 5000 s.

B2.15 Seawater

A 4 L sample is collected in a clean polyethylene container.

A portion is removed for tritium analysis, and the remainder is acidified (15 mL of 70% nitric acid per 4 L sample). Of this, 3.6 L is measured into a marinelli beaker for gamma spectroscopy. For tritium analysis by liquid scintillation techniques, a 6 mL sample of water is counted for 100 min. For gamma spectroscopy, the sample is counted for 5000 s.

If significant levels of Sr-89,90 (indicating 1% of Monthly DEL) are detected in the chemical analysis of the LEM composite, then the seawater is also to be analysed for these radionuclides.

B2.16 Miscellaneous Samples

This category encompasses all of those samples collected that do not fall within the other categories. It is a mechanism by which the lab can track and evaluate media for potential inclusion in the program. It gives the program flexibility and freedom and encourages the scientific curiosity of laboratory staff. A few of the media types started out this way. As many as 50 samples per year are analysed, including deer liver, mud puddles, snow, sea urchin and mussels.

B2.17 Bore Holes

A 4 L sample of water is pumped out of the bore hole into a clean polyethylene container.

A portion is removed for tritium analysis, and the remainder is acidified (15 mL of 70% nitric acid per 4 L sample). Of this, 3.6 L is measured into a marinelli beaker for gamma spectroscopy. For tritium analysis by liquid scintillation techniques, a 6 mL sample of water is counted for 100 min. For gamma spectroscopy, the sample is counted for 5000 s.

B2.18 Parshall Flume

PLGS staff collect a 4 L sample of water from the Parshall flume systems.

A portion is removed for tritium analysis, and the remainder is acidified (15 mL of 70% nitric acid per 4 L sample). Of this, 3.6 L is measured into a marinelli beaker for gamma spectroscopy. For tritium analysis by liquid scintillation techniques, a 6 mL sample of water is counted for 100 min. For gamma spectroscopy, the sample is counted for 5000 s.

B2.19 Hemlock Knoll Regional Sanitary Landfill

In December 1999, PLGS began disposing of its non-active waste at the public landfill facility. A monitoring program was established prior to the first shipment. It includes sampling of water from the leachate, bore holes and various holding ponds; and dosimeter placement at key locations.

Although some extra precautions are observed due to the potential biohazard of some of these samples, they are analysed according to established procedures previously described.

Appendix C: Location Codes

A 5m	PLGS Dry Fuel Storage Facility - 5 m NNE from perimeter fence
A 10m	PLGS Dry Fuel Storage Facility - 10 m NNE from perimeter fence
A 15m	PLGS Dry Fuel Storage Facility - 15 m NNE from perimeter fence
A 20m	PLGS Dry Fuel Storage Facility - 20 m NNE from perimeter fence
A 25m	PLGS Dry Fuel Storage Facility - 25 m NNE from perimeter fence
A 50m	PLGS Dry Fuel Storage Facility - 50 m NNE from perimeter fence
A 75m	PLGS Dry Fuel Storage Facility - 75 m NNE from perimeter fence
A 100m	PLGS Dry Fuel Storage Facility - 100 m NNE from perimeter fence
A 118m	PLGS Dry Fuel Storage Facility - 118 m NNE from perimeter fence
A01R	Bocabec – GPS Reading – L 45° 10.111N, Lo 67° 0.378 W
A02R	Bocabec – field across from A01R
A03R	Bocabec – inter-tidal zone
A04	Bayside – Fairmile Farm
A05R	Letete
A06	Digdeguash
A07	Beaver Harbour
A08	Back Bay
A09	Chamcook
A10R	Grand Manan
A12	St. Andrews

A11	Oak Bay / Waweig
AECL	Atomic Energy of Canada Ltd., Chalk River (QA)
B 5m	PLGS Dry Fuel Storage Facility – 5 m WNW from perimeter fence
B 10m	PLGS Dry Fuel Storage Facility – 10 m WNW from perimeter fence
B 15m	PLGS Dry Fuel Storage Facility – 15 m WNW from perimeter fence
B 20m	PLGS Dry Fuel Storage Facility – 20 m WNW from perimeter fence
B 25m	PLGS Dry Fuel Storage Facility – 25 m WNW from perimeter fence
B 50m	PLGS Dry Fuel Storage Facility – 50 m WNW from perimeter fence
B 75m	PLGS Dry Fuel Storage Facility – 75 m WNW from perimeter fence
B 100m	PLGS Dry Fuel Storage Facility – 100 m WNW from perimeter fence
B 150m	PLGS Dry Fuel Storage Facility – 150 m WNW from perimeter fence
B 200m	PLGS Dry Fuel Storage Facility – 200 m WNW from perimeter fence
B01	New River Beach - inter-tidal zone
B02	Pocologan
B03	New River Beach - park
B04	New River Harbour to Pocologan Harbour
B10	Pennfield
BAXR	Baxter's Dairy
BB	PLGS – Boiler Blow-down
BD	Belledune GS

C01	Lepreau Harbour – inter-tidal zone
C03	Lepreau
CCW	PLGS – Condenser Cooling Water Duct
CH	Chatham GS
COG	CANDU Owners Group
D01	Little Lepreau Basin - inter-tidal zone (remnants of clam shack)
D02	Little Lepreau
D03	Little Lepreau – GPS Reading – L 45° 08.030 N, Lo 66° 27.686 W
D04	Little Lepreau Basin – inter-tidal zone (remnants of boat wreck)
DH	Dalhousie GS
DOE	US Department of Energy (QA)
DUMP	PLGS – onsite landfill
DWC	PLGS – drinking water fountains
E01	Maces Bay –GPS Reading–L 45° 06.306 N, Lo 66° 28.651 W
E02	Maces Bay – Fundy Senior Citizens Centre
E03	Maces Bay – inter-tidal zone
E04	Maces Bay Cemetery
E05	Fundy Shores Elementary School – outside (Thompson/Trynor's Field)
E06	Fundy Shores Elementary School – inside
E07	Near intersection of route 790, Maces Bay Rd. and County Line Rd.
E11	28 Ridge Rd., Dipper Harbour

E12	22 Ridge Rd., Dipper Harbour
E13	16 Ridge Rd., Dipper Harbour
E14	10 Ridge Rd., Dipper Harbour
E15	4 Ridge Rd., Dipper Harbour
EDU	Edutech Enterprises
EPA	US Environmental Protection Agency (QA)
F01	Welch Cove–GPS Reading–L 45° 04.782N, Lo 66° 27.986 W
F02	Welch Cove – inter-tidal zone
F03	190 Welch Cove Rd., Maces Bay
F04	195 Welch Cove Rd., Maces Bay
F05	181 Ridge Rd., Maces Bay
F06	132 Ridge Rd., Maces Bay
F07	68 Ridge Rd., Maces Bay
G01	Indian Cove – inter-tidal zone
G02	Point Lepreau – lighthouse
G03	offshore – within 2 km of Point Lepreau lighthouse
G04	PLGS – inter-tidal zone 1 km south of CCW out-fall
GEM	PLGS – Gaseous Effluent Monitor
GL	Grand Lake GS
H01	Duck Cove – duck pond
H02	offshore – close to PLGS condenser cooling water out-fall

H03	Duck Cove - inter-tidal zone
H04	PLGS – across the road from old site of Information Centre building
H05	PLGS - start of nature trail near old site of Information Centre trailers
HS	Hanson Stream Reservoir
I00	PLGS SRWMF Phase 1– general site area
I01	PLGS SRWMF Phase 1
I02	PLGS SRWMF Phase 2
I03	PLGS SRWMF Phase 2 – general site area
I10A	PLGS SRWMF Phase 1 Bore Hole A (BHA)
I10B	PLGS SRWMF Phase 1 Bore Hole B (BHB)
I10C	PLGS SRWMF Phase 1 Bore Hole C (BHC)
I10D	PLGS SRWMF Phase 1 at I01 Barn (Shallow Bore Hole)
I10E	PLGS SRWMF Phase 1 at I01 Barn (Deep Bore Hole)
I10F	PLGS SRWMF Phase 1 Bore Hole southeast from C structure
I10G	FUTURE BORE HOLE
I10H	FUTURE BORE HOLE
I10I	FUTURE BORE HOLE
I11A	PLGS SRWMF Phase 1 - south fence (east side)
I11B	PLGS SRWMF Phase 1 - south fence (centre)
I11C	PLGS SRWMF Phase 1 - south fence (west side)
I11D	PLGS SRWMF Phase 1 - west fence (south side)

I11E	PLGS SRWMF Phase 1- west fence (centre)
I11F	PLGS SRWMF Phase 1 - west fence (north side)
I11G	PLGS SRWMF Phase 1 - north fence (west side)
I11H	PLGS SRWMF Phase 1 - north fence (centre)
I11I	PLGS SRWMF Phase 1 - north fence (east side)
I11J	PLGS SRWMF Phase 1 - east fence (north side)
I11K	PLGS SRWMF Phase 1 - east fence (centre)
I11L	PLGS SRWMF Phase 1 - east fence (south side)
I1A1	PLGS SRWMF Phase 1 – Cell 1A1
I1A2	PLGS SRWMF Phase 1 – Cell 1A2
I20A	PLGS SRWMF PHASE 2 – well #4 (shallow) BH4
I20B	PLGS SRWMF PHASE 2 – well #4 (deep) BH4
I20C	PLGS SRWMF PHASE 2 - well #7 (shallow) BH7
I20D	PLGS SRWMF PHASE 2 - well #7 (deep) BH7
I20E	PLGS SRWMF PHASE 2 – well #6 (shallow) BH6
I20F	PLGS SRWMF PHASE 2 - well #6 (deep) BH6
I20G	PLGS SRWMF PHASE 2 – well #5 (shallow) BH5
I20H	PLGS SRWMF PHASE 2 – well #5 (deep) BH5
I20I	PLGS SRWMF PHASE 2 – well #2 (shallow) BH2
I20J	PLGS SRWMF PHASE 2 - well #2 (deep) BH2
I20K	PLGS SRWMF PHASE 2 - well #3 (shallow) BH3

I20L	PLGS SRWMF PHASE 2 – well #3 (deep) BH3
I20M	PLGS SRWMF PHASE 2 – well #1 (shallow) BH1
I20N	PLGS SRWMF PHASE 2 – well #1 (deep) BH1
I20P	PLGS SRWMF PHASE 2 – north from bore hole 1
I20Q	PLGS SRWMF PHASE 2 – south from bore hole 2 (shallow)
I20S	PLGS SRWMF PHASE 2 – south from bore hole 2 (deep)
I20T	PLGS SRWMF PHASE 2 – north from bore hole 2
I20U	PLGS SRWMF PHASE 2 – well #8 shallow (BH8)
I20V	PLGS SRWMF PHASE 2 – well #8 deep (BH8)
I21A	PLGS SRWMF PHASE 2 – Periphery – south fence (east side)
I21B	PLGS SRWMF PHASE 2 - Periphery – south fence (centre)
I21C	PLGS SRWMF PHASE 2 - Periphery – south fence (west side)
I21D	PLGS SRWMF PHASE 2 - Periphery – west fence (south side)
I21E	PLGS SRWMF PHASE 2- Periphery - west fence (centre)
I21F	PLGS SRWMF PHASE 2 - Periphery - west fence (north side)
I21G	PLGS SRWMF PHASE 2 – Periphery – north fence (west side)
I21H	PLGS SRWMF PHASE 2 - Periphery – north fence (centre)
I21I	PLGS SRWMF PHASE 2 - Periphery – north fence (east side)
I21J	PLGS SRWMF PHASE 2 – Periphery – east fence (north side)
I21K	PLGS SRWMF PHASE 2 – Periphery – east fence (centre)
I21L	PLGS SRWMF PHASE 2 - Periphery – east fence (south side)

I70	PLGS – woods between plant & SRWMF
I71	PLGS - Near Plant Monitoring Well MW01-10, northeast from RB
I75	PLGS – north 73° east, 85 m from the stack (on pole)
I86	PLGS – 2 nd pole from SRWMF driveway heading toward outer gate
I87	PLGS – 3 rd pole from SRWMF driveway heading toward outer gate
I88	PLGS – 4 th pole from SRWMF driveway heading toward outer gate
I89	PLGS – 5 th pole from SRWMF driveway heading toward outer gate
I90	At distribution line on west side of Point Lepreau Rd.
I91	100 m north of distribution line on west side of Point Lepreau Rd.
I92	200 m north of distribution line on west side of Point Lepreau Rd.
I93	300 m north of distribution line on west side of Point Lepreau Rd.
I94	400 m north of distribution line on west side of Point Lepreau Rd.
I95	500 m north of distribution line on west side of Point Lepreau Rd.
I96	on the old Dupont warning sign at the end of the old “dynamite road”
I97	on the west side of the clearing at the end of the old “dynamite road”
I98	PLGS – north of SRWMF PHASE 2 (200 m north of transmission line)
I99	PLGS – north of SRWMF PHASE 2 – (100 m north of transmission line)
IAEA	International Atomic Energy Agency (QA)
J00	PLGS – south, 180 m from the stack (on fence)
J01	PLGS - Near Plant Monitoring Well MW01-1, near surge shaft
J02A	PLGS - Near Plant Monitoring Well MW01-2 (shallow), SSE from RB

J02B	PLGS - Near Plant Monitoring Well MW01-2 (deep), SSE from RB
J20	PLGS - south 19° east, 115 m from the stack (on fence)
J35	PLGS - south 34° east, 135 m from the stack (on sign)
J70	PLGS - south 69° east, 70 m from the stack (on pole)
K00	PLGS - Near Plant Monitoring Well MW01-3 south from RB
K01	PLGS - 95 m west of south gate leading to the lighthouse
K02	PLGS Cooling Water Pump-house - east fence near surge shaft
K03	PLGS - Near Plant Monitoring Well MW01-4 SSW from RB
K03C	PLGS sewage lagoon (chlorine contact tank)
K03E	PLGS inactive drainage (east lagoon)
K03W	PLGS inactive drainage (west lagoon)
K04	PLGS - Near Plant Monitoring Well MW01-5, WSW from RB
KDRP	KD Radpro
L01	PLGS - site of old cement plant
L02	PLGS - switchyard
L03	PLGS - outer security building (main gate)
L04	PLGS - construction stores
L05	PLGS - Near Plant Monitoring Well MW01-6, WNW from RB
L06	PLGS - Near Plant Monitoring Well MW01-7, paved staff parking lot
L07	PLGS - Near Plant Monitoring Well MW01-8, construction parking lot
L08	PLGS - Near Plant Monitoring Well MW01-9, N beyond fire training area

LAB	Fredericton - Health Physics Laboratory
LEM	PLGS - Liquid Effluent Monitor
M02	PLGS - Administration Building (2 nd floor)
MISC	Miscellaneous locations
MQ	Mactaquac GS
N01	Dipper Harbour - GPS Reading - L 45° 05.399 N, Lo 66° 25.154 W
N02	Dipper Harbour - GPS Reading - L 45° 06.106 N, Lo 66° 24.949 W
N03	Dipper Harbour - GPS Reading - L 45° 05.551 N, Lo 66° 25.449 W
N04	Dipper Harbour - inter-tidal zone
N05	Dipper Harbour - beach behind restaurant
N06	Dipper Harbour - offshore
NTS	Nuclear Technology Services Inc. (QA)
P01	Chance Harbour - GPS Reading - L 45° 07.494 N, Lo 66° 21.456 W
P02	Little Dipper Harbour
P03	Liberty Hill - GPS Reading - L 45° 07.043 N, Lo 66° 21.498
P04	Round Meadow Farm
P05	Chance Harbour - 2 km offshore
PLGS	PLGS - general
Q01R	Lorneville
RPB	Radiation Protection Bureau, Health Canada (QA)
RPC	Research and Productivity Council

S00	Saint John and surrounding area
S10	Hammond River
SPL	Spruce Lake reservoir
TAYR	Taymouth
X03R	Fredericton - Chestnut Complex lab
X04R	Fredericton – reference seafood
X05R	Fredericton – reference milk test
X06R	West of Fredericton (Silverwood)
X10	Fredericton Junction – Atlantic Dairy Institute
X12	York Mills
Y#####	Hemlock Knoll Regional Sanitary Landfill

Appendix D: Abbreviations

<i>CCW</i>	Condenser Cooling Water
<i>CL</i>	Critical Level
<i>CNSC</i>	Canadian Nuclear Safety Commission
<i>COG</i>	CANDU Owners Group
<i>CSA</i>	Canadian Standards Association
<i>DEL</i>	Derived Emission Limit
<i>FWHM</i>	Full Width Half Maxima
<i>GEM</i>	Gaseous Effluent Monitor
<i>IAEA</i>	International Atomic Energy Agency
<i>ISO</i>	International Organization for Standardization
<i>LEM</i>	Liquid Effluent Monitor
<i>LLD</i>	Lower Limit of Detection
<i>LSC</i>	Liquid Scintillation Counter
<i>NBEMO</i>	New Brunswick Emergency Measures Organization
<i>NIST</i>	National Institute of Standards and Technology
<i>NRC</i>	National Research Council
<i>NTS</i>	Nuclear Technology Services
<i>OERMP</i>	Operational Environmental Radiation Monitoring Program
<i>PLGS</i>	Point Lepreau Generating Station
<i>PROD</i>	Power Reactor Operation Division
<i>QA</i>	Quality Assurance
<i>QC</i>	Quality Control
<i>REPD</i>	Radiation and Environmental Protection Division
<i>RPB</i>	Radiation Protection Bureau
<i>SEA</i>	Significant Environmental Aspect
<i>SRWMF</i>	Solid Radioactive Waste Management Facility
<i>TLD</i>	Thermoluminescent Dosimeter
<i>USDOE</i>	United States Department of Energy

Appendix E: Environmental Reports of Previous Years

PRE-OPERATIONAL (1976 - 1981)

Pre-Operational Environmental Radiation Monitoring Data for Point Lepreau Generating Station. October 1, 1976 to June 30, 1979. NBEPC-HP-79-1. J.A. Flanigan and J.J. Paciga. Sept. 1979.

Pre-Operational Environmental Radiation Monitoring Data for Point Lepreau Generating Station. January 1, 1979 to December 31, 1979. NBEPC-HP-80-1. J.A. Flanigan. Sept. 1980.

Pre-Operational Environmental Radiation Monitoring Data for Point Lepreau Generating Station. January 1, 1980 to December 31, 1980. NBEPC-HP-81-1. J.K. Sutherland and J.A. Flanigan. July 1981.

Pre-Operational Environmental Radiation Monitoring Data for Point Lepreau Generating Station. January 1, 1981 to December 31, 1981. NBEPC-HP-82-1. J.K. Sutherland. February 1982.

OPERATIONAL (1982 - 2002)

Environmental Radiation Monitoring Data for Point Lepreau Generating Station. January 01, 1982 (to 1997) to December 31, 1982 (to 1997). HP-07000-83 (to 98)-1. J.K. Sutherland. March 1983 (to 1998).

Environmental Radiation Monitoring Data for Point Lepreau Generating Station. January 01, 1998 (to 2002) to December 31, 1998 (to 2002). HP-07000-1999 (to 2003)-1. J.C. McCulley. April 1999 (to 2003).

Appendix F: References

1. Fisher, M., *Review of Environmental Monitoring Program at the Point Lepreau Generating Station*, Gemtec Limited, 2003.
2. Acer Environmental Services Limited in Association with Beak International Incorporated, *Point Lepreau Generating Station Ecological Effects Review*, 2003.
3. Barnes, J. and Stephenson, M., *Point Lepreau Solid Radioactive Waste Management Facility Modifications Environmental Assessment Study Report*, Jacques Whitford Environment Limited, 2003.
4. Nason, J., *Radiation Protection Directives RD-01364-L2 Rev.4*, Point Lepreau Generating Station Reference Document, 2001.
5. *Point Lepreau Generating Station - Safety Report - Solid Radioactive Waste Management Facility - July 2002 Edition*, Document Number 0087-79100-3009-001-SR-A-00, Point Lepreau Generating Station, 2002.
6. McWilliams, R., *Online Monitoring and Control of Liquid and Airborne Effluents SI-01365-L20 Rev.0*, Point Lepreau Generating Station Station Instruction, 2003.
7. Sutherland, J., *Derived Emission Limits for Radionuclides in Airborne and Liquid Effluents RD-01364-L1*, Point Lepreau Generating Station Reference Document, 1996.
8. Flood, C., *Environmental Management System (EMS) RD-01364-P22 Rev. 1*, Point Lepreau Generating Station Reference Document, 2001.
9. National Standards of Canada, *Environmental Management Systems - Specification With Guidance for Use (Adopted ISO 14001:1996) CAN/CSA-ISO 14001-96 (R2001)*, 1996.
10. Flood, C., *Provide Environmental Services PRR-00660-SU-2 Rev. 0*, Point Lepreau Generating Station Process Reference, 2002.
11. Flanigan, J., *Pre-Operational Radiological Environmental Monitoring Program for Point Lepreau Nuclear Generating Station. NBEPC-HP-75-1*. 1975.
12. McCulley, J., *Operational Environmental Radiation Monitoring Program RD-01364-L15 Rev. 7*, Point Lepreau Generating Station Reference Document, 2000.
13. National Standards of Canada, *Guidelines for Radiological Monitoring of the Environment CAN/CSA-N288.4-M90*, 1990.
14. Federal Provincial Subcommittee on Drinking Water of the Federal Provincial Committee on Environmental and Occupational Health, *Guidelines for Canadian Drinking Water Quality, Sixth Edition*, Health Canada, 1996.

15. Bryant, P., *Methods of Estimation of the Dispersion of Windborne Materials and Data to Assist in Their Application*. UKAEA Report AHSB(RP)R42, 1964.
16. *Environmental Radiation Monitoring Program Procedures, HP-03541-2-EN*, Point Lepreau Generating Station Procedure Document, 2001.
17. *External Beta/Gamma Dosimetry Program, HP-03541-2-TL Rev. 4*, Point Lepreau Generating Station Procedure Document, 2001.
18. NBS Special Publication 456, *Measurements for the Safe Use of Radiation*, US Department of Commerce, 1976.

Appendix G: Distribution List

R.M. White	Vice President, Nuclear	New Brunswick Power Corporation Head Office Fredericton
G.M. Wilson	Director, Environmental Affairs	
C.N. Hickman	Manager, Environmental Assessment and Assurance	
K.E. Knorr	Document Management	
W.S. Pilkington	Site Director	New Brunswick Power Corporation Point Lepreau Generating Station
J.J. McCarthy	Station Manager	
L.J.P. Comeau	Manager, Personnel Safety and Environment	
J.C. Nason	Senior Health Physicist	
H.M. Carrier	Supervisor, Health Physics PLGS Lab	
Document Control		
D.J. Wilson	Senior Technical Advisor, Nuclear Safety	
Performance Group		
W. Woodworth	Independent Assessment Group Supervisor	
V.J. Connell	Technical Specialist – Nuclear	
M.M. Mersereau	System Engineer (SRWMF)	
C.M. Arbeau	Administation	
K.L. McIntyre	EMS Coordinator	
Library		
R.P. Mapplebeck	Senior Technical Specialist, Nuclear	New Brunswick Power Corporation Health Physics Fredericton Laboratory Fredericton
J.E. Lovely	Engineer/Scientist I-IV, Nuclear	
J.K. Sutherland	Retired	
File		
Original		
Change Copy		

Library		Canadian Nuclear Safety Commission P.O. Box 1046 Ottawa, ON K1P 5S9
F. Leduc	Project Officer, Wastes and Geosciences Division	
P.A. Thompson	Director, Environmental Protection and Audit Division	
D. Bottomly	Specialist, Wastes and Geosciences Division	
R. Avadhanula	Environmental Protection Specialist, Environmental Protection and Audit Division	
J. Kurias	Environmental Protection Specialist, Environmental Protection and Audit Division	
S. Munger	Environmental Protection Specialist, Environmental Protection and Audit Division	
A. Ray	Environmental Protection Specialist, Health Physics and Environmental Protection Division	Canadian Nuclear Safety Commission Point Lepreau G.S. PO Box 600 Lepreau, NB E5J 2S6
C. McDermott	Director, Point Lepreau Compliance and Licensing Division (2)	
J.N. Meade		
J.M. Brake		
D. Meyerhof		Radiation Protection Bureau Health Canada Brookfield Road Ottawa, ON K1A 1C1
L. Swami		Ontario Power Generation 700 University Avenue Toronto, ON M5G 1X6
D. Wismer		
I. Benovich		
J.R. LaMarre		

N. Lamarche		Hydro Québec Centrale Nucléaire Gentilly 4900 Boulevard Bécancour Gentilly, Québec G0X 1G0
E. Dion		
M. Lupien		
J.N. Smith		Marine Environmental Sciences Division Bedford Institute of Oceanography Rm 305, VS Bldg 1 Challenger Drive Dartmouth, NS B2Y 4A2
B. Fowlie	Minister, Environment and Local Government	P.O. Box 6000 Fredericton, NB E3B 5H1
B. Fitch	Minister, Energy	
K. Ashfield	Minister, Natural Resources	
Manager, Environmental Technologies Branch		Atomic Energy of Canada Ltd. Chalk River, ON K0J 1J0
Manager, Environmental Protection		
Manager, Radiation Biology and Health Physics Branch		
R. Lambert		
K. Dormuth		
J. Tamm		
C. Boss		
Main Library (2)		Atomic Energy of Canada Ltd. Station 13 Chalk River, ON K0J 1J0
J. Bond		Atomic Energy of Canada Ltd. Station 19 Chalk River, ON K0J 1J0
C. Davison		Atomic Energy of Canada Ltd. Station 51A Chalk River, ON K0J 1J0

N.B. Legislature (4)	Legislative Library P.O. 6000 The Legislature Fredericton, NB E3B 5H1
Library	Atomic Energy of Canada Ltd. CANDU Operations Sheridan Park Comm. Centre Mississauga, ON L5K 1C7
Library	National Library of Canada Government Documents Ottawa, ON K1A 0N4
J. Hilbig	Bruce Power B21 Box 1540 Tiverton, ON NOG 2T0
B. Stepaniak	

